

# REPORTING REQUIREMENTS: BAKER LAKE

N6L4-1191 (B)

## Licence Information:

Effective Date: Sept. 1, 1993

Expiry Date: August 31, 1999

Water use should not exceed 100,000 cubic metres annually (from Baker Lake)

Security Deposit: N/A

Annual Water Fees Due: N/A

## Conditions Applying to Sewage Disposal

Type of System: Lake - Lagoon

Receiving Env't: Wetland

Effluent Standards: Fecal Coliforms 10,000 CFU/dL

BOD 80 mg/L

TSS 100 mg/L

Oil and Grease 5 mg/L

pH 6-9

Description	WB Approval	Submission Due	Received	Status
Annual Report		March 31st		1996 report not received yet
Water Quality Study		September 1995		Conducted by DIAND and returned to Hamlet Dec. 96 for submission to Board.
A&R Plan		6 months prior to abandonment of any Waste Disposal Facilities		
O & M Plan		March 1, 1994	Nov. 18/96	Needs Board approval

Revised: May 29, 1997

## COMMENTS:

SNP sampling requires sampling monthly during periods of open water. SNP data should be submitted annually with the Annual Report.