August 28, 1997

Mr. Leo Caouette CWMS Trainer Hamlet of Baker Lake, Baker Lake, NT X0E 0A0

RE: MODIFICATION OF WATER INTAKE FACILITIES

Dear Mr. Caouette:

Further to the discussion on August 27, 1997, in which you mentioned upcoming modification to the area and associated intake infrastructure for the communities water supply. The NWB would like to offer the following, to ensure compliance with the terms and conditions of the municipal water licence N6L3-1191:

As required under Part F: Conditions Applying to Modifications

- 1. The Licensee may, without written consent from the Board, carry out modification to the Water Supply and Waste Disposal Facilities provided that such modification are consistent with the terms of this licence and the following requirement are met:
 - a. The Licensee has notified the Board in writing of such proposed modification at least sixty (60) days prior to beginning the modifications;
 - b. Such modification do place the Licensee in contravention of either the Licence or the Act;
 - c. The Board has not, during the sixty (60) days following the notification of the proposed modifications, informed the Licensee that review of the proposal will required more than the sixty (60) days; and
 - d. The Board has not rejected the proposed modifications.
- 2. Modification for which all of the condition referred to in Part F, Item 1, have not been met, can be carried out only with written approval from the Board.
- 3. The Licensee shall provide as-built plans and drawings of the modifications referred to in this licence within ninety (90) days of completion of the modifications.

Please do not hesitate to contact me at 403-360-6338, should you require additional information.

Mr. Leo Caouette RE: MODIFICATION OF WATER INTAKE FACILITIES Page 2 August 28, 1997

Sincerely,

Dionne Filiatrault, MIT Technical Advisor