
RE: Cambridge Bay Municipal Water License Inspection of 11 August 2020

Alam, Shah <SAlam@gov.nu.ca>

Wed, Oct 7, 2020 at 4:25 PM

To: "Pedersen, Baba (AADNC/AANDC)" <baba.pedersen@canada.ca>, SAO Cambridge Bay <mlimousin@cambridgebay.ca>

Cc: "licensing@nwb-oen.ca" <licensing@nwb-oen.ca>, "Hack, Justin (AADNC/AANDC)" <justin.hack@canada.ca>

Thank you Baba,

Appreciated for your Report.

As I know, CGS has collected bids for Fuel tank installation and replacement – which will go through evaluation process and will take action/hire the contractor, otherwise will look alternative method including consultation with Hamlet (if feasible) to complete the work by the scheduled time as committed.

For Lagoon clean up, it would be taken another step in coming year as well as the monitoring plan ongoing, the same for liner cells inside the Metal Dump.

For waste water reduction, I have forwarded a method that I received from Kugluktuk implemented this year.

Regards,

Shah Alam, P. Eng. E.P. CAPM

Municipal Planning Engineer,

Government of Nunavut

Community and Government Services

Kitikmeot Region, Cambridge Bay, Nu

Phone: 867-983-4156, fax: 867-983-4124

salam@gov.nu.ca<<mailto:salam@gov.nu.ca>>

From: Pedersen, Baba (AADNC/AANDC) <baba.pedersen@canada.ca>
Sent: October 7, 2020 3:08 PM
To: SAO Cambridge Bay <mlimousin@cambridgebay.ca>
Cc: licensing@nwb-oen.ca; Hack, Justin (AADNC/AANDC) <justin.hack@canada.ca>; Alam, Shah <SAlam@GOV.NU.CA>
Subject: Cambridge Bay Municipal Water License Inspection of 11 August 2020

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

To Marla Limousin, CAO, Hamlet of Cambridge Bay

Hello Marla,

Attached you will find my Inspection Report for the Hamlet of Cambridge Bay's Municipal Water License 3BM-CAM2030. I did the Inspection on August 11, 2020 and I was accompanied by Shah Alam from the GN CGS. Wiz Mohammed from your staff took us around for the Inspection.

The following are updates to some of my findings in my Report that have developed between the time of the Inspection and now;

Item 1 Fuel Tank at Water Intake Pump House

As per email correspondence with Wiz, I have set a New Deadline of July 15, 2021 for the Removal of the Fuel Tank that is less than 30 Meters from the high water mark. I must stress that if this deadline is not met then I will have no choice but to consider further Enforcement Action.

Item 2 Debris along the Edge of the Sewage Lagoon

As per email correspondence and photos supplied by Wiz, I confirm that all Debris has been removed as per my request. Thank you very much.

Item 6 Bermed Area within the Metal Dump

As per email correspondence and photos supplied by Wiz, I confirm some removal and clean-up has happened this season. I look forward to the completion of this area of work in the summer of 2021.

Item 7 Signage at Sample Station CAM-6

As per email correspondence and photos supplied by Wiz, I confirm that appropriate Signage has been replaced at Sample Station CAM-6. Thank you very much.

I would like to thank both yourself and Wiz for your cooperation and assistance during the Inspection Process.

If you have any questions or concerns, please feel free to contact me at any time.

I have shared this with the Nunavut Water Board in Gjoa Haven, the GN CGS in Cambridge Bay and CIRNAC in Iqaluit for their information and files.

Koana,

Baba

Baba Pedersen

Resource Management/Water Resource Officer

CIRNAC - Kitikmeot Region

Kugluktuk, NU

Baba.pedersen@canada.ca

Cell 867-222-2839