cant factors in the failure of wastewater treatment facilities to adequately meet the effluent limitations for which they were designed has been inferior process equipment.

Our experience indicated that there was no one best means of procurement and bidding format. During our initial stages, we evaluated five methods individually and in combination:

 Conventional open bid. Competition is encouraged because the contractors are free to negotiate with all interested parties. However, this method also permits the contractor the opportunity to offer products that while complying with the salient requirements of the specifications and project intent may not be the exact equipment or process envisioned in the design. This process also encourages prebid packaging, post bid shopping, and may lead to the possibility of disputes during construction.

- 2. Base bid. Contractors are required to base their prices on equipment named on a fixed list. Competition tends to be discouraged, except among the named "base bid" manufacturers. Because the products and equipment in the base bid have been evaluated in the design process, fewer problems tend to arise during construction and start-up phases. Bid protests may occur because suppliers are not listed in the specifications or bid form.
- 3. Base/substitute bid. The contractor is allowed to enter equipment names and deduct amounts to the bid package. The bids can be evaluated either before or after the substitutions have been included. Similar to the base bid format, competition is limited and generally prebid packaging is discouraged. The concerns with bid protests are similar to the problems that could be encountered with the base bid process.
- 4. Evaluated bid. Equipment is selected based on total cost, life-cycle cost, or some other method of evaluation. This format maintains equipment selection with the owner and designer, provides for competition, tends to eliminate prebid packaging, and fulfills all the legal requirements for bidding of federally funded projects. Since the project is designed around a specific type of equipment, disputes are generally minimized during construction.
- 5. Pre-selection of major equipment. This method is very similar to the evaluation bid format since the engineer and owner play a critical role in selecting not only the type, but also the brands of equipment installed. The primary difference is that it does not generally permit competition, since the equipment has already been chosen prior to the bid; however, it

leaves open the possibility for a fair competition during the equipment proposal process.

It was determined that a combination of methods 2 and 5 provided a number of advantages, such as:

- 1. Equipment selection decisions stay with the owner and engineer.
- New and innovative processes and equipment are encouraged.
- 3. Pre-bid packaging and post-bid shopping are discouraged.
- Disputes during construction are minimized.
- 5. The method is legal and enforceable.

A number of primary components of the wastewater facilities were evaluated during the pre-selection/evaluation process. The premise of the pre-selection process was to select the major pieces of equipment prior to bidding. With the bidding format process chosen, the contractor was still required to purchase the equipment and be responsible for its installation, as with typical construction contracts.

The process equipment that was determined to be the most important components of the wastewater treatment facilities to meet the effluent limitations contained in

the Consent Agreement and was theref evaluated and pre-selected prior to bidd included the biological nutrient remorprocess, the method of filtration, and to instrumentation package. The primary at of our evaluation was the biological nutrier removal was tewater treatment processince it was the heart of the system.

A number of biological nutrient remove treatment processes were evaluated, incluing the Eimco 5-stage Bardenpho process. Envirex Orb Simpre process, and sequential batch reators. Each of the process suppliers we invited to submit proposals on technic merit and cost. The criteria for the procese evaluation, identical for all proposals, ir cluded influent and effluent characteristics, operating conditions, and site considerations.

Evaluations of technical proposals wer based on capital and operating costs, labo and maintenance requirements, operating experience and reliability, the ability to mee the effluent criteria, performance guaran tees, and other miscellaneous items (e.g. odors, aerosols). Moreover, during the process proposal stage of the project, we visited a number of wastewater facilities that utilized the treatment processes to develop a subjective analysis of them.

It was determined that an Eimco 5-stage

Bardenphofacility was the biological nutrient removal treatment process that met the requirements for the UCCNSB.

The methods of filtration that were evaluated were travelling bridge and continuous backwash deep bed filters, and they were evaluated in a similar fashion to the biological nutrient removal processes. It was determined that the continuous backwash deep bed filters were the most appropriate method of filtration for this project and site.

The evaluation of the instrumentation package was more difficult because of the many suppliers available. Since the primary goal was to select a system that could efficiently operate with the selected biological nutrient removal process, one of the key evaluation criteria was experience with other biological nutrient removal processes. It was determined that the Kruger instrumentation package met all the requirements of the evaluation.

Since Kruger and Eimco are competitors in the marketing of biological nutrient removal process equipment, it was thought that integrating the Kruger instrumentation package with the Eimco equipment would be difficult. It was quite the contrary, since both organizations, along with the project team, worked effectively together to develop a successful instrumentation package that met the needs of the project.

This was the first project in the United States to successfully integrate the Eimco Bardenpho treatment technology with the Kruger controls and instrumentation system in a bidding package.

We believe that this method of pre-selection of the major process equipment enabled the city and the project team to select the most appropriate equipment for the project. It also enabled the project design team to work with the city and the various suppliers and determine what will work best for the facility. Since the project required the selection of specialized equipment, it was determined that this method of pre-selection was useful.

At the preliminary and 60-percent-final design stages, the project underwent an intensive value engineering study to identify potential savings in capital and/or operating costs. A savings of approximately \$540,000 was realized.

When the design was completed the engineering drawings were forwarded to five major general contractors for a feasibility and constructability review. Additionally, the review process provided information regarding special construction techniques, alternative layouts, and other cost saving measures. The information from the five reviews was evaluated and, where possible, incorporated into the final bidding documents.

Results

The project went out for bid in September 1997. Nine bids, ranging from \$16,156,705 to \$18,725,000, were received. The low bid by Indian River Industrial Contractors, Inc., of Jacksonville resulted in a cost per gallon of \$2.69. As of September 1998, the project is approximately 70 percent complete. It has had one change order—to add two additional filters to enable the treatment of an additional 1.0 MGD from the cooling tower of a proposed new electrical power plant that will be constructed adjacent to the project site. The \$214,882 cost of the change order will be

borne by the owner of the power plant. The wastewater treatment facility is currently in the process of being repermitted to treat an average daily flow of 7.0 MGD. Using the rerated flows and the additional costs from the change order, the cost per gallon was now \$2.33.

The design and bidding format allowed the owner and engineer to implement a program that meets project needs, will minimizes disputes during construction, and is cost effective. Compared to recent bids from similar sized and type facilities in Florida, savings of at least \$4,000.000 were realized.


Wastewater

Technology Fact Sheet Wetlands: Subsurface Flow

DESCRIPTION

Wetland systems are typically described in terms of the position of the water surface and/or the type of vegetation grown. Most natural wetlands are free water surface systems where the water surface is exposed to the atmosphere; these include bogs (primary vegetation mosses), swamps (primary vegetation trees), and marshes (primary vegetation grasses and emergent macrophytes). A subsurface flow (SF) wetland is specifically designed for the treatment or polishing of some type of wastewater and are typically constructed as a bed or channel containing appropriate media. An example of a SF wetland is shown in Figure 1. Coarse rock, gravel, sand and other soils have all been used, but a gravel medium is most common in the U.S. and Europe. The medium is typically planted with the same types of emergent vegetation present in marshes, and the water surface is designed to remain below the top surface of the medium. The main advantages of this subsurface water level are prevention of mosquitoes and odors, and elimination of the risk of public contact with the partially treated wastewater. In contrast, the water surface in natural marshes and free water surface (FWS) constructed wetlands is exposed to the atmosphere with the attendant risk of mosquitoes and public access.

The water quality improvements in natural wetlands had been observed by scientists and engineers for many years and this led to the development of constructed wetlands as an attempt to replicate the water quality and the habitat benefits of the natural wetland in a constructed ecosystem. Physical, chemical, and biochemical reactions all contribute to water quality improvement in these wetland



Source: Adapted from drawing by S.C. Reed, 2000.

FIGURE 1 SUBSURFACE FLOW WETLAND

systems. The biological reactions are believed due to the activity of microorganisms attached to the available submerged substrate surfaces. In the case of FWS wetlands these substrates are the submerged portion of the living plants, the plant litter, and the benthic soil layer. In SF wetlands the available submerged substrate includes the plant roots growing in the media, and the surfaces of the media themselves. Since the media surface area in a SF wetland can far exceed the available substrate in a FWS wetland, the microbial reaction rates in a SF wetland can be higher than a FWS wetland for most contaminants. As a result, a SF wetland can be smaller than the FWS type for the same flow rate and most effluent water quality goals.

The design goals for SF constructed wetlands are typically an exclusive commitment to treatment functions because wildlife habitat and public recreational opportunities are more 12. FWS wetlands The

TABLE 5 CAPITAL AND O&M COSTS FOR 100,000 GALLONS PER DAY SF WETLAND

İtem	Cost \$*		
	Native Soil Liner	Plastic Membrane Liner	
Land Cost	\$16,000	16,000	
Site Investigation	3,600	3,600	
Site Clearing	6,600	6,600	
Earthwork	33,000	33,000	
Liner	0	66,000	
Gravel Media**	142,100	142,100	
Plants	5,000	5,000	
Planting	6,600	6,600	
Inlets/Outlets	<u>16,600</u>	<u>16,600</u>	
Subtotal	\$229,500	\$295,500	
Engineering, legal, etc.	<u>\$133,000</u>	<u>\$171,200</u>	
Total Capital Cost	\$362,500	\$466,700	
O & M Costs, \$/yr	\$6,000/yr	\$6,000/yr	

^{*} June 1999 costs, ENR CCI = 6039

TABLE 6 COST COMPARISON SF WETLAND AND CONVENTIONAL WASTEWATER TREATMENT

Cost Item	Pro	ocess
Cost item	Wetland	SBR
Capital Cost	\$466,700	\$1,104,500
O &M Cost	\$6,000/yr	\$106,600/yr
Total Present Worth Costs*	\$530,300	\$2,233,400
Cost per 1000 gallons treated**	\$0.73	\$3.06

^{*}Present worth factor 10.594 based on 20 years at 7 percent interest (June 1999 costs, ENR CCI = 6039).

Source: WEF, 2000.

Table 6 compares the life cycle costs for this wetland to the cost for a conventional treatment system designed for the same flow and effluent water quality. The conventional process is a sequencing batch reactor (SBR).

REFERENCES

Other Related Fact Sheets

Free Water Surface Wetlands EPA 832-F-00-024 September, 2000


Other EPA Fact Sheets can be found at the following web address:

http://www.epa.gov/owmitnet/mtbfact.htm


^{**12,000} cy of 0.75 in. gravel

^{**}Daily flow rate for 365 d/yr, for 20 yr, divided by 1000 gallons

Appendix I P-Lake Access Road Route Photographs



View of Existing Road Looking Toward Saddle. Wetland / Lagoon Location at Top Of Saddle.



View From Top of Saddle Looking Toward Possible Road Route.



Cape Dorset Sewage Management Review

PROJECT NO.

031943-1000


DATE

July 2003


TITLE

PROJECT

FIGURE NO.



View of Wetland and Possible Lagoon Location



View of Wetland Outlet To Ocean



PROJECT

TITLE

Cape Dorset Sewage Management Review

PROJECT NO.

031943-1000

DATE

July 2003

FIGURE NO

Dillon Consulting Limited Cape Dorset Sewage Options File: 031943-1000

Access Road Assumptions

Road Length		
Fill Road Mill Width	850	
TAUGVAIDA OL	16	m
Fill Slope	10	m
	0.5 H:1V	m
CCese D	3H:1V	

Access Road	3H:1V	-	
Road - Cut	Volume	Unit Rate	
Road - Fill Road Base	12,000		Cost
Total Road	43,000 7,500	\$100 \$40 \$40	\$1,200,000 \$1,720,000
Lagoon Assumptions Lagoon Constructed in Flat Ground Total Volume (2 Cells)		Sav	\$3,220,000
College Volume (2 Cells) Flat Ground			\$3,200,000

Lagoon Co- "Prions	
Total Value Constructed in Co.	
Tagoon Constructed in Flat Total Volume (2 Cells)	Ground

		m
agoon	1.3	m
	2.0	
· ,eepoard	3.3	
Liquid Level Freeboard	3H:1V	
Liquid	2H:1V	m
Berm Height	2	
Outside Ci-		m
"ISIDE SIG-	214	m
Derm Wide	110	тз
Cell Length	96,725	
Total Volume (2 Cells) Cell Width		
Total Value Total		

Lagoon Quantity Unit Rate Cost		2.0		
Earthworks (m3) Quantity Unit Rate Cost Site Preparation and Drainage 39,000 \$40 \$1,560,000 Fencing (m) 1 \$25,000 \$25,000 Inlet and Outlet Controls 1 \$25,000 \$275,000 Total Lagoon \$25,000 \$25,000 \$25,000 Note: **Note: **Note: **Note:	Lagoon	1.3	m	
Site Preparation and Drainage 39,000 \$40 \$1,560,000 Fencing (m) 1 \$25,000 \$25,000 Inlet and Outlet Controls 1 \$25,000 \$275,000 Total Lagoon \$25,000 \$25,000 \$25,000 Note: \$25,000 \$25,000 \$25,000			m	
Site Preparation and Drainage 39,000 \$40 \$1,560,000 Fencing (m) 1 \$25,000 \$25,000 Inlet and Outlet Controls 1 \$25,000 \$275,000 Total Lagoon \$25,000 \$25,000 \$25,000 Note: \$25,000 \$25,000 \$25,000				
Site Preparation and Drainage 39,000 \$40 \$1,560,000 Fencing (m) 1 \$25,000 \$25,000 Inlet and Outlet Controls 1 \$25,000 \$275,000 Total Lagoon \$25,000 \$25,000 \$25,000 Note: \$25,000 \$25,000 \$25,000	Earthworks (max	Quantity	I I I	
Fencing (m) 1 \$25,000 \$25,000 \$1,560,000 \$1,0	Site Prena		Unit Rate	
Total Lagoon Note: 1 \$40 \$1,560,000 \$1,560,000 \$25,000 \$25,000 \$25,000 \$25,000 \$25,000	Fencing American and Drain	200		Cost
Total Lagoon 1 \$250 \$25,000 1 \$25,000 \$275,000 Note:	Inlet and (m)	39,000	645	
Total Lagoon 1 \$250 \$25,000 1 \$25,000 \$275,000 Note:	octana Outlet Contact	1	\$40 T	64 =
Note:	Tolling	1100	<u>\$25,000</u>	\$1,560,000
Note:	Total Lagoon	1	_ \$250 +	- \$25.000
Note: \$25,000			\$25,000	\$275,000
Note:			1,000	\$25,000
Costs do not include any Fouri	Note			7.000
Costs do not include any Epuis	note:			5.1
Costs do not include any Four	Costs do not in		say	\$1,885,000
	Costs do not include any Faut	.		\$1,900,000

Costs do not include any Environmental Assessments and Permitting, Sealift, and Taxes.

Dillon Consulting Limited Cape Dorset Sewage Options

File: 031943-1000

P - Lake Sewage Lagoon and Access Road - NPV

ltem	Cost	
Access Road	\$3,200,000	
Sewage Lagoon	\$1,900,000	
Total Capital Cost	\$5,100,000.00	
Engineering and Geotechnical @ 10%	\$510,000.00	
Contingency @ 25%	\$1,275,000.00	
Total	\$6,885,000.00	
Operating Cost @ 2.0% of Lagoon Cost	\$38,000	
	6+0-000	

say

\$40,000

Note:

Costs Do Not Include Taxes, Sewage Collection and Haulage, Road Maintenance, and Snow Clearing

NPV ANALYSIS

	Sewage Lagoon
Construction Year	\$6,885,000.00
1	\$40,000
2	\$40,000
3	\$40,000
4	\$40,000
5	\$40,000
6	\$40,000
7	\$40,000
8	\$40,000
9	\$40,000
10	\$40,000
11	\$40,000
12	\$40,000
13	\$40,000
14	\$40,000
15	\$40,000
16	\$40,000
17	\$40,000
18	\$40,000
19	\$40,000
20	\$40,000
NPV @ 2%	\$7,539,057
NPV @ 4%	\$7,428,613
NPV @ 8%	\$7,277,726