



MUNICIPAL WATER USE INSPECTION FORM

DATE: 16/8/8 COMPANY REP: Fred schell
LICENSEE: Municipality of Cape Dorset LICENCE #: 3BM-CAP0810

WATER SUPPLY

Source(s): Lee Lake Quantity Used (to date): estimate
Owner/operator: Municipality of Cape Dorset
(estimate or actual):

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Intake Facilities A Storage Structures A Treatment Systems A Chem. Storage U
Flow Meas. Device A Conveyance Lines A Pumping Stations A

Comments: Chlorine Pails (2) nearly empty during period of inspection. Intake records available and reviewed. chemical storage must be addressed.

WASTE DISPOSAL

Sewage: Sewage Treatment System (primary, secondary or tertiary) pumping
Natural Water body / Continuous Discharge (land or water) land
Seasonal Discharge / Wetlands Treatment / Trench /
Solid Waste: Owner/Operator: Hamlet of Cape Dorset
Landfill / Burn & Landfill / Other /

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Disch. Quality U Decant Structure / Erosion U
Disch. Meas. Dev. N/A Dyke Inspection N/A Seepages U
Dams, Dykes U Freeboard U Spills NI
Construction / O & M Plan U A & R Plan U
Periods of Discharge / Effluent Discharge Rate: U

Comments: New lagoon full of water, water in marshes, No thermistors installed. Emergency lagoons at capacity, 3 tier lagoon leaking and third tier has failed in one place that threatens integrity of whole third cell.

FUEL STORAGE

Owner Gov of Nu. Operator O.E.C. Condition of Tanks A
Berms & Liners A Water within berm: / Evidence of Leaks: /
Drainage Pipes / Pump Station and Catchment Beam /
Pipeline Condition A Not Applicable: /

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) /
(DIAND) potable, Leachate, Effluent
Signs Posted: SNP wood Warning /
Record & Reporting Report present for Review

Geotechnical Inspection: /

Non-Compliance of Act or Licence: The municipality will be issued a direction to address the 3 cell lagoon, the road to water intake, new road and new lagoon. The municipality will be provided 60 days to address these issues.

Page 2 attached ☐ Yes ☐ No

MAYOR OF CAP6 DORSET
Licensee Representative's Title

Fred Schell
Licensee Representative's Signature

A. Keim
Inspector's Name

[Signature]
Inspector's Signature