



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᓂᓕᓂᓪ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYINGI

**File No: NWB3CAP0207**

*Via Fax (867) 897-8030*

August 4, 2004

Mr. Art Stewart  
Senior Administrative Officer  
Hamlet of Cape Dorset  
General Delivery  
Cape Dorset, NU X0A 0R0

**Subject: Annual Report Requirement NWB3CAP0207**

Dear Mr. Stewart:

The Nunavut Water Board (NWB) has reviewed the "Annual Report for the Hamlet of Cape Dorset (2003)" documents submitted to the Board on April 29, 2004 in accordance with Part B, Item 1 of your water licence. The NWB herein approves the 2003/04 Annual Report as presented and thanks the Hamlet of Cape Dorset for their submission.

It was noted in the review of the Annual Report submitted that the Hamlet does not currently have a Monitoring Plan in place for their solid waste and wastewater management facilities. The NWB reminds the Licensee that, in accordance with Part H, Item 2 of water license NWB3CAP0207, the Hamlet of Cape Dorset is required to sample monthly at Monitoring Stations CAP-2 and CAP-3 during the months of May to August, inclusive. The NWB, however, is aware of the challenges associated with developing, and implementing, such a sampling program. Accordingly, staff of the NWB will be contacting you within the next several weeks, to determine if we can assist you in developing, and implementing a Monitoring Plan, as is required by your water license.

It was also noted that the water supply line for the Hamlet of Cape Dorset has been replaced. The NWB requests that the Hamlet of Cape Dorset forward the Abandonment and Restoration Plan for the redundant water supply line to the Board, as soon as is practicable, so that the Plan may be distributed for Regulatory review and approval.

Please contact the undersigned at (867) 360-6338 or e-mail Jim Wall (Technical Advisor, Municipal) at [tech1@nwb.nunavut.ca](mailto:tech1@nwb.nunavut.ca) if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "P. di Pizzo". The signature is fluid and cursive, with the first name "Philippe" and last name "di Pizzo" clearly distinguishable.

Philippe di Pizzo  
Executive Director