



ᑎᓄᓐᓂᓐ ᓂᓄᓐᓂᓐ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File: 3BM-CAP0810

November 9, 2018

Bhabesh Roy, M.A.Sc., P.Eng.
Municipal Planning Engineer
Community Government Services
Baffin Region, Government of Nunavut
P.O.Box 379, Pond Inlet, X0A 0S0

Email: broy@gov.nu.ca

RE: Licence No. 3BM-CAP0810 Type “B”; Hamlet of Cape Dorset; 2017 Annual Report Review

Dear Mr. Roy:

The Nunavut Water Board (NWB) has completed a technical review of the 2017 Annual Report (the Report) for Type “B” Water Licence 3BM-CAP0810 (the Licence). The Report was received on March 29, 2018 from the Government of Nunavut - Community & Government Services (GN-CGS or the Licensee), submitted as a requirement under Part B of the Licence.

Copies of all documents received during Report review can be accessed through the NWB’s Public Registry and FTP site using the following link:

[ftp://ftp.nwb-oen.ca/registry/3%20MUNICIPAL/3B/3BM%20-%20Municipality/3BM-CAP0810/3%20TECH/1%20GENERAL%20\(B\)/2%20ANNUAL%20RPT/2017/](ftp://ftp.nwb-oen.ca/registry/3%20MUNICIPAL/3B/3BM%20-%20Municipality/3BM-CAP0810/3%20TECH/1%20GENERAL%20(B)/2%20ANNUAL%20RPT/2017/)

NWB noted the following deficiencies in the course of the Report review:

- 1) Water use is indicated in litres;
- 2) Sewage quantity is estimated, which does not comply with Licence Part H, Item 17;
- 3) Revisions to management plans are indicated as not required; however, in the course of the review of the application for renewal, it was determined that plans do indeed require revision;
- 4) There were unauthorized discharges; however, their list and follow-up actions are absent in the Report;
- 5) Units of measurement are missing in the data table;
- 6) There are a number of exceedances of effluent limits reported in the data table;

- 7) The sample points in the data table do not correspond to the prescribed monitoring stations;
- 8) Colour code in the data table is not referenced.

In addition, it is noted that the Licence expired on March 1, 2010; however, the Licensee applied for a renewal, and the application review process is ongoing.

The Licensee is requested to eliminate the deficiencies in the next annual report. If you have any questions, please contact the undersigned at assol.kubeisinova@nwb-oen.ca or (867) 360 6338.

Regards,

Assol Kubeisinova
Nunavut Water Board,
Technical Advisor

Copy: Distribution list - Qikiqtani