



File No: **3BM-CLY1924**

July 08, 2024

James Arreak
 Senior Administrative Officer
 Municipality of Clyde River
 P.O. Box 205
 Clyde River,
 Nunavut X0A 0E0

Megan Lusty
 Manager, Municipal Works
 Community and Government Services
 Government of Nunavut
 P.O. Box 1000, Stn 700, Iqaluit
 Nunavut X0A 0H0

Email: cao@clyderiver.ca

Email: mlusty@gov.nu.ca

RE: NWB Technical Review of 2020, 2021, 2022 and 2023 Annual Reports for the Hamlet of Clyde River; Water Licence No: 3BM-CLY1924

Dear James Arreak and Megan Lusty,

The Nunavut Water Board (NWB or Board) has completed the technical review of the 2020, 2021, 2022 and 2023 Annual Reports (Reports) for the type B Water Licence No: 3BM-CLY1924 (Licence).

On June 17, 2024, the NWB acknowledged the receipt of the Annual Report for the year 2023 and provided it to the Qikiqtani distribution list for information. No comments have been received to date.

Table 1 provides a list of issues identified during the technical review of the Reports along with the recommended actions.

Table 1 List of Issues Identified and the Recommended Actions

SN	NWB Recommendations and Concerns	Recommended actions
1	The Annual Report did not include daily water withdrawal and daily waste discharge information as per Part B, Item 1c and 1d of the Licence.	<p>The Licensee is requested to provide all relevant information required by the Licence in all subsequent annual reports.</p> <p>Additionally, the formal names of the monitoring stations in the table detailing the quantity of water obtained and quantity of waste discharged shall be used instead of using “all sources”.</p>
2	The NWB has not received an updated	The Licensee is requested to provide the

	version of the plan entitled “ <i>Clyde River Truck-fill Operations and Maintenance Manual</i> ” as per Part F, Item 3 of the Licence.	updated plan.
3	The NWB notes that the annual reports did not include information for all monitoring stations as required by Part H of the Licence.	The Licensee is requested to provide all relevant information required by the Licence in all subsequent annual reports.
4	The NWB has not received any annual assessments of the geotechnical and geothermal performance of the Enhanced Sewage Disposal Facility as per Part H, Item 12 of the Licence.	The Licensee is requested to provide all relevant information required by the Licence in all subsequent annual reports.
5	There are a number of non-compliances identified and comments provided by the Inspector in the 2021 inspection report.	The Licensee is requested to address the identified issues and report the actions taken in the next annual report.

In case, data or information is unavailable, please provide a discussion explaining:

- what information is missing;
- why it was not collected; and
- steps taken to collect it in the future.

The Licensee is also reminded that the current Licence will expire on **August 19, 2024** and that it is the responsibility of the Licensee to apply to the NWB for its renewal. The renewal process and timing may vary depending on the scope of the application; however, a minimum of sixty (60) days is required from time of acceptance by the NWB.

Should you have any questions, please feel free to contact the undersigned at (867) 360-6338 (extension 32) or nidhi.singh@nwb-oen.ca, at your earliest convenience.

Sincerely,



Nidhi Singh
Nunavut Water Board,
Technical Advisor

Cc: Distribution List – Qikiqtani