File No: NWB3CLY

VIII.		$\textbf{PUBLIC HEALTH} \ (\textit{To be filled by the Regional Environmental Health Officer})$			
	1.	Date:	February 27, 2001		
	2.	Municipality:	Clyde River		
	3.	Contact: (Environmental Health Officer Contact) Bonnie Segal			
			Telephone #: 867-979-7656		
			Fax #: 867-979-7659		
	4.	Have there been any problems or health/environmental concerns with drinking water?  YesNo			
		If yes, describe			
	5.	Have there been any problems or health/environmental concerns with sewage disposal/treatment?  Yes No			
		If yes, describe			
	The lagoon appears to reach capacity quickly during the year and by the beginning of the summer there is minimal freeboard. The potential for breaches in the structure to occur is a concern. There is an obvious need for expansion of the lagoon capacity and an investigation into the integrity of the berms.				
	6.	Have there beed disposal?  Yes	en any problems or health/environmental concerns with solid waste _ No		
		If yes, describe	e		

Only minimal segregation of waste is occurring at the solid waste disposal site. Open burning at the site occurs regularly and often contains items that should not be part of the burn such as plastics. There is no provision for the separate safe storage of hazardous waste at this solid waste site. There is the potential for hazardous materials entering the burn pile. Waste is often blown off site due to the inadequacy of the fencing. The fence should enclose the facility.

## Monitoring Program

1.		Does the Regional Health Board perform water quality sampling? No				
	a.	methodology.				
		Membrane filtration method is used to examine the potable water supply for total coliforms and E. coli.				
b.	Briefly describe any monitoring of wastewater effluent and leachate.  None  c. Who is responsible for sampling?					
		The samples are collected by Environmental Health Office Name: Position: Telephone #: Fax #: Level of training				
d.		Recognized laboratory performing analysis of samples.				
		Name:	Environmental Health Office Health & Social Services, Baffin			
		Address:	P.O. Box 1000, Station 1046			
		Telephone #:	867-979-7656			
		Fax #:	867-979-7659			
e.		Are any changes planned in the water quality monitoring program? YesNo If yes, describe.				