

C.O.C.: 130044

REPORT No. B08-16962

Report To:

Hamlet of Clyde River
Box 89
Clyde River, Nunavut, X0A 0E0

Attention: Bill Buckle

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa, Ontario, K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 03-Jun-08

JOB/PROJECT NO.: Lagoon Water

DATE REPORTED: 11-Jun-08


P.O. NUMBER:

SAMPLE MATRIX: Water

WATERWORKS NO.

Parameter:	BOD	Total Suspended Solids			
Units:	mg/L	mg/L			
M.D.L.:	3	3			
Reference Method:	SM 5210	SM 2540			
Date/Site Analyzed:	06-Jun-08/O	05-Jun-08/O			

Client I.D.	Sample I.D.	Date Collected				
Lagoon Water - Sample #1	B08-16962-1	01-Jun-08	380	--		
Lagoon Water - Sample #2	B08-16962-2	01-Jun-08	420	--		
Lagoon Water - Sample #3	B08-16962-3	01-Jun-08	417	--		
Lagoon Water - Sample #4	B08-16962-4	01-Jun-08	--	72		
Lagoon Water - Sample #5	B08-16962-5	01-Jun-08	--	144		
Lagoon Water - Sample #6	B08-16962-6	01-Jun-08	--	70		



Krystyna Pipin, M. Sc.
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,P-Peterborough,M-Moncton

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B08-19579

Report To:

Hamlet of Clyde River
Box 89
Clyde River, Nunavut, X0A 0E0

Attention: Bill Buckle

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa, Ontario, K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 24-Jun-08

JOB/PROJECT NO.:

DATE REPORTED: 02-Jul-08

P.O. NUMBER:


SAMPLE MATRIX: Water

WATERWORKS NO.

Parameter:	BOD	Total Suspended Solids			
Units:	mg/L	mg/L			
M.D.L.:	3	3			
Reference Method:	SM 5210	SM 2540			
Date/Site Analyzed:	25-Jun-08/O	02-Jul-08/O			

Client I.D.	Sample I.D.	Date Collected				
Bottle #1	B08-19579-1	18-Jun-08	408 ¹	--		
Bottle #2	B08-19579-2	18-Jun-08	389 ¹	--		
Bottle #3	B08-19579-3	18-Jun-08	399 ¹	--		
Bottle #4	B08-19579-4	18-Jun-08	--	20		
Bottle #5	B08-19579-5	18-Jun-08	--	26		
Bottle #6	B08-19579-6	18-Jun-08	--	24		

¹ Passed holding time



Krystyna Pipin, M. Sc.
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,P-Peterborough,M-Moncton

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.

C.O.C.: 18107

REPORT No. B09-07174

Report To:

Hamlet of Clyde River
 Box 89
 Clyde River, Nunavut, X0A 0E0

Attention: David Arreak

Caduceon Environmental Laboratories

2378 Holly Lane
 Ottawa, Ontario, K1V 7P1
 Tel: 613-526-0123
 Fax: 613-526-1244

DATE RECEIVED: 16-Mar-09

JOB/PROJECT NO.: Lagoon Sample

DATE REPORTED: 24-Mar-09


P.O. NUMBER:

SAMPLE MATRIX: Water

WATERWORKS NO.

Parameter:	BOD	Total Suspended Solids			
Units:	mg/L	mg/L			
M.D.L.:	3	3			
Reference Method:	SM 5210	SM 2540			
Date/Site Analyzed:	19-Mar-09/O	17-Mar-09/O			

Client I.D.	Sample I.D.	Date Collected				
Lagoon	B09-07174-1	11-Mar-09	442	56		
Flow End	B09-07174-2	11-Mar-09	424	78		
Ground	B09-07174-3	11-Mar-09	441	62		



Krystyna Pipin, M. Sc.
 Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,P-Peterborough,M-Moncton

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from
 Caduceon Environmental Laboratories.