

From: [Andrew Keim](#)
To: ["Phyllis Beaulieu"](#); [Bill Buckle](#)
Cc: [Bhabesh Roy](#)
Subject: RE: Decanting of Sewage Lagoon - Clyde River
Date: Wednesday, March 25, 2009 11:27:25 AM

Thank you for the up-date Bill.

Please keep us all poste on your progress.

Andrew Keim
Water Resources Officer
INAC Nunavut Regional Office
P.O. Box 2200
Iqaluit, Nunavut X0A 0H0
NEW Email: Andrew.Keim@inac-ainc.gc.ca
Phone: (867) 975-4289
Fax: (867) 979-6445

>>> "Bill Buckle" <saoclyde2005@qiniq.com> 3/24/2009 11:09 AM >>>
We have been having problems keeping the decanting going, we are currently down (not decanting) our pump housing broke from the extreme cold and we are waiting for parts to come from Montreal. It is the only pump available in the community other than using a sewage vacuum truck to pump out over the berm. When it was pumping it was extremely slow. We are still awaiting the test results from Caduceon for the first set of samples we sent out. At the current rate we are going we have almost refilled what we pumped out from the lagoon. As of right now we are not decanting and we have no indication how long it will take to get the parts and start pumping again.

Bill Buckle
Senior Administrative Officer
Municipality of Clyde River
P.O. Box 89
Clyde River, Nunavut
X0A 0E0
Phone: 867-924-6220
Fax: 867-924-6293

From: Bill Buckle [<mailto:saoclyde2005@qiniq.com>]
Sent: Friday, March 13, 2009 2:44 PM
To: 'Phyllis Beaulieu'
Cc: Roy, Bhabesh; Andrew Keim
Subject: Decanting of Sewage Lagoon - Clyde River

We started the process of decanting the sewage lagoon on Wednesday March 11. The first test samples have been sent to Caduceon Laboratories in Ottawa as of yesterday. We have had a few problems with trying to keep the pump going and it's hitting -40 overnight so we pull the pump out each night. The pump casing already has a small hairline fracture so we are ordering a new casing. We are looking at ways to keep the pump warm. It is also dangerous for our staff as the small hollow being created underneath the ice has started the ice cracking and buckling. Slow process, we are estimating a couple of weeks to get it down to a reasonable level.

Bill Buckle

Senior Administrative Officer

Municipality of Clyde River

P.O. Box 89

Clyde River, Nunavut

X0A 0E0

Phone: 867-924-6220

Fax: 867-924-6293