

ANNUAL REPORT FOR THE HAMLET OF CORAL HARBOUR

Nunavut Water
Board

MAR 31 2011

Public Registry

YEAR BEING REPORTED: 2010-2011

The following information is compiled pursuant to the requirements of Part B, Item 1 of Water License # 3BM COR0813 issued to the Hamlet of Coral Harbour.

- i)- iii) tabular summaries of all data generated under the "Monitoring Program"; monthly and annual quantities in cubic metres of freshwater obtained from all sources; monthly and annual quantities in cubic metres of each and all wastes discharged;

Attached are results for Monitoring station COR-1, COR-2, as well as detailed chemical, physical and biological analysis required at COR-3 and COR-4a and COR-4B and COR-4C and Core-5 (for the months of May to August, inclusive)

Month Reported	Quantity of Water Obtained from all sources	Quantity of Sewage Waste Discharged
January	2,575,571.80 L	2,575,571.80 L
February	2,632,698.30 L	2,632,698.30 L
March	2,984,616.10 L	2,984,616.10 L
April	2,746,412.70 L	2,746,412.70 L
May	2,930,325.80 L	2,930,325.80 L
June	2,534,795.90 L	2,534,795.90 L
July	2,774,212.30 L	2,774,212.30 L
August	3,024,774.20 L	3,024,774.20 L
September	2,617,839.60 L	2,617,839.60 L
October	2,824,267.40 L	2,824,267.40 L
November	2,616,217.40 L	2,616,217.40 L
December	2,907,580.80 L	2,907,580.80 L
ANNUAL TOTAL	33,168,068.30 L	33,168,068.30 L

ANNUAL REPORT FOR THE HAMLET OF CORAL HARBOUR

Please indicate volumes in cubic metres - 1 cubic meter equals 1000 litres

- iv. a summary of modifications and/or major maintenance work carried out on the Water Supply and Waste Disposal Facilities, including all associated structures and facilities;

replaced chlorinator pump, water supply pipe from post river to reservoir were repaired in September and reservoir refilled for the winter.

- v. a list of unauthorized discharges and summary of follow-up action taken;

none

- vi. a summary of any abandonment and restoration work completed during the year and an outline of any work anticipated for the next year;

none

- vii. a summary of any studies requested by the Board that relate to waste disposal, water use or reclamation, and a brief description of any future studies planned;

none

- viii. any other details on water use or waste disposal requested by the Board by November

**ANNUAL REPORT
FOR THE HAMLET OF (name)**

1st of the year being reported; and

n/a

ix. updates or revisions to the approved Operation and Maintenance Plans.

n/a

ADDITIONAL INFORMATION THAT THE LICENSEE DEEMS USEFUL:

Dalhousie University research team visited during the summer and is working on lagoon/sewage wasteland, waste water project for 2010 and 2011, site visit community consultation on February 23, 2011 and will be back during the summer to conduct more research.

FOLLOW-UP REGARDING INSPECTION/COMPLIANCE CONCERNS:

none
