

**From:** [Andrew Keim](#)  
**To:** [Bryan Purdy](#)  
**Cc:** [Phyllis Beaulieu](#); [munch@qiniq.com](mailto:munch@qiniq.com)  
**Subject:** Re: FW: Municipal Water Licence Inspection 3BM-COR0813  
**Date:** Thursday, May 13, 2010 10:59:36 AM

---

Hi Brian,

In relation to the requirements of the License.

Part F section 3 reads as follows;

3. An inspection of all engineered facilities related to the management of water and waste shall be carried out annually in July or August by a Geotechnical Engineer. The engineer's report shall be submitted to the Board within sixty (60) days of the inspection, including a covering letter from the Licensee outlining an implementation plan addressing each of the Engineer's recommendations.

I believe that the license indicates that these inspections are to be done annually and not just upon completion .

I hope this helps.

Andrew Keim  
Water Resources Officer  
INAC Nunavut Regional Office  
P.O. Box 100  
Iqaluit, Nunavut X0A 0H0  
\*NEW Email: \* [Andrew.Keim@inac-ainc.gc.ca](mailto:Andrew.Keim@inac-ainc.gc.ca)  
Phone: (867) 975-4289  
Fax: (867) 979-6445

>>> "Purdy, Bryan" <[BPurdy@GOV.NU.CA](mailto:BPurdy@GOV.NU.CA)> 5/12/2010 4:00 PM >>>  
Hi Andrew I am working with the Sao of Coral Harbour

Andrew all the engineering work that was done since 2003 are already filed with the Nunavut Water Board

Jacques Whitford did all the engineering work on the sewage wetland and assessing the gravel berms that were constructed in 2003 on which the caribou fencing was built this area is now known as the sewage lagoon

All of Jacques Whitford's report are registered on NWB Ftp site for Coral Harbour

I can obtain them from Jacques Whitford as courtesy If that would be helpful

The SAO (CHRIS) has sent in his annual report

Is it satisfactory or can we do more for you ?

---

From: SAO Coral [<mailto:munch@qiniq.com>]  
Sent: May 12, 2010 1:37 PM  
To: Purdy, Bryan  
Cc: Andrew Keim  
Subject: Municipal Water Licence Inspection 3BM-COR0813

Hi Brian,

As per our discussion, this is what the inspector require.

"Engineers report on the required Geotechnical Inspection of all engineered facilities Part F(3) "

He is referring to the sewage lagoon only.

Thanks

Kind regards,

Chris Chai

SAO

Hamlet of Coral Harbour

867-925-8867 (ph)

867-925-8233 (fax)