

MUNICIPAL APPLICATION: GJOA HAVEN

November 26, 1998

	Comments
<b>General</b>	Annual report to be provided. Waste disposal and SNP signs should be posted.
<b>Water Use</b>	The community has trucked water from Water supply lake and utilizes approx. 23,360 cubic meters per year. Intake is screened. <b>Recommended: 35,000 cubic meters per year to allow for population growth. Recommends fencing due to proximity of the community and skidoos. Also conditions should include minimum freeboard limit on dyke. Filtration disconnected should be addressed???</b> as recommendation
<b>Waste Disposal: Sewage</b>	Community discharge of sewage to a lagoon. Discharge chutes need to be repaired. Community has a honey bag pit that should be reclaimed. <b>Recommend engineer should inspect lagoon in an efforts to correct design flaw.</b>
<b>Waste Disposal: Solid Waste</b>	The solid waste disposal area is mismanaged. <b>Recommend: Segregation and proper fencing and implementation of OM Manual.</b>
<b>Spill Contingency</b>	Community has spill contingency plan for spills. <b>Recommend this be formalized in general contingency plan. Conditions for reporting spills to the hotline with copy of reporting form. Recommend spill response training for municipal employees.</b>
<b>Operation and Maintenance</b>	<b>Recommend plan to ensure proper OM to assess status of current facilities and practices. This plan useful to identify training needs in the community. OM of waste oil pit needs to be addressed and water supply facilities.</b>
<b>Abandonment and Restoration</b>	<b>Recommend: confirmation of ownership and submission of AR plan prior to reclamation.</b>
<b>SNP</b>	Water/Leachate samples by DIAND once a year. Bacteria testing performed by health center. <b>Recommend community implement a monitoring program. Leachate monitoring from the dumps past and present.</b>