

**ANNUAL REPORT
FOR THE HAMLET OF GJOA HAVEN**

YEAR BEING REPORTED: 2000

The following information is compiled pursuant to the requirements of Part B, Item 1 of Water Licence NWB3GJO9904 issued to the Hamlet of Gjoa Haven.

- a)- c) tabular summaries of all data generated under the "Surveillance Network Program"; monthly and annual quantities in cubic metres of freshwater obtained from all sources; monthly and annual quantities in cubic metres of each and all wastes discharged;

Attached Laboratory results for SNP station GJO-2 and GJO-3

Month Reported	Quantity of Water Obtained from all sources	Quantity of Sewage Waste Discharged
January	2,316,457.00	2,316,457.00
February	2,331,040.00	2,331,040.00
March	2,576,279.00	2,576,279.00
April	2,452,563.00	2,452,563.00
May	2,623,295.00	2,623,295.00
June	2,426,738.00	2,426,738.00
July	2,453,620.00	2,453,620.00
August	2,558,308.50	2,558,308.50
September	2,217,901.80	2,217,901.80
October	2,402,886.79	2,402,886.79
November	2,594,036.15	2,594,036.15
December	2,774,594.52	2,774,594.52
ANNUAL TOTAL	29,727,719.76	29,727,719.76

Please indicate volumes in cubic metres - 1 cubic meter equals 1000 litres

**ANNUAL REPORT
FOR THE HAMLET OF GJOA HAVEN**

- d. a summary of modifications and/or major maintenance work carried out on the Water Supply and Waste Disposal Facilities, including all associated structures and facilities;

- New intake screen for water supply to address
'bloodworm' concerns.
- fencing installed @ solid waste site

- e. a list of unauthorized discharges and summary of follow-up action taken;

2 Feb 2000; Anti freeze/Coolant overflow on
water lake, during freeze up.

Action: Ice chips removed to holding drums &
storage with other local hazardous

30 May 2000: P5c approx 92L tank valve broke.

Scrape ground with loader bucket material in 45 gal drums
spread for proper disposal.

- f. a summary of any abandonment and restoration work completed during the year and an outline of any work anticipated for the next year;

- g. a summary of any studies requested by the Board that relate to waste disposal, water use or reclamation, and a brief description of any future studies planned;

Part G, Item 1: Operation and Maintenance Manual

Contract Dillon Consulting in Igloolik to prepare
O.M. plan

Part H, Item 1: Abandonment and Restoration Plan

No

Part H, Item 5: Report on ownership of Abandoned Facilities

Application to ECR Action to reclaim old dumpsites
in municipal boundary.

**ANNUAL REPORT
FOR THE HAMLET OF GJOA HAVEN**

- h. any other details on water use or waste disposal requested by the Board by November 1st of the year being reported; and

- i. updates or revisions to the approved Operation and Maintenance Plans.

ADDITIONAL INFORMATION THAT THE HAMLET DEEMS USEFUL:

Sanage posted at all municipal services as required
under the licence

FOLLOW-UP REGARDING INSPECTION/COMPLIANCE CONCERNS:

- CG+T issued Request for proposal on Planning
Study to Select new water Supply
- Hamlet requested CG+T to look into upgrade
or getting new facility
- Discharge chute ^{was} ~~the~~ repaired before fall 2000
