

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

PLAN FOR COMPLIANCE TEMPLATE

Column 1	Column 2	Column 3	Column 4	Column 5	Column 6
License Condition (Add or delete as required)	Status of Compliance	Short Term Plan for Compliance	Schedule for Implementation of Short Term Plan for Compliance (including funding status where applicable to municipal developments)	Long Term Plan for Compliance	Schedule for Implementation of Long Term Plan for Compliance (including funding status where applicable to municipal developments)
Part B - General Conditions					
B - 1 The Licensee shall file an Annual Report with the Board not later than March 31st of the year following the calendar year reported which shall contain the following information:	Yes, The Annual Report is attached with the renewal application.	N/A	N/A	N/A	N/A
B - 1 - a tabular summaries of all data generated under the "Monitoring Program"; and an indication of wastewater treatment levels upstream and downstream of the welland Area.	Not in compliance	The Hamlet is planning to start this summer.	Summer 2011	This process will be maintained	Until the life expectancy of this facility.
B - 1 - b modifications to the "Monitoring Program" in accordance with Part H, Item 9;	Not in compliance	The Hamlet is planning to use the lab services in Ottawa.	Expiring this summer 2011	This process will be maintained	N/A
B - 1 - c the monthly and annual quantities in cubic meters of fresh water obtained at the Water Supply Facilities;	In compliance. This is indicated in the annual Report	N/A	N/A	N/A	N/A
B - 1 - d the monthly and annual quantities in cubic meters of each and all waste discharged;	In compliance. The waste discharge is considered the same quantity as water consumption.	N/A	N/A	N/A	N/A
B - 1 - e the annual quantity in cubic meters and tonnes of sludge removed from the Sewage Disposal Facility along with the treatment, storage, and disposal provided as required in Part H Item 6.	Not in compliance. This process is not applicable	N/A	N/A	N/A	N/A
B - 1 - f the results of sampling and analyses of sewage sludge in accordance with the operations and maintenance Manual referred to in Part F Item 2 and as required in Part H Item 5;	Not in compliance.	N/A	N/A	N/A	N/A
B - 1 - g a summary of modifications and/or major maintenance work carried out on the Water Supply and Waste Disposal Facilities, including all associated structures and facilities;	In Compliance. Water supply-NIL; Sewage Lagoon-NIL; Waste management-Nil	N/A	N/A	N/A	N/A
B - 1 - h a list of unauthorized discharges and summary of follow-up action taken;	In Compliance.	N/A	N/A	N/A	N/A
B - 1 - i a summary of any abandonment and restoration work completed during the year and an outline of any work anticipated for the next year.	In Compliance. Nothing done last year. The waste management project was started but put on hold right now.	Waiting for Head quarter's direction.	Unknown	The new facility for waste management will be built to satisfy the water License requirements.	The Existing landfill site will be decommissioned soon after the new facility is in operation.
B - 1 - j any updates or revisions for manuals and plans (i.e., Operations and Maintenance Manual) as required by changes in operation and/or technology; may be subject to Board	Not in compliance. Manuals for sewage lagoon and landfill site are not available.	Waiting for Head quarter's direction to start back the solid waste management project.	Currently unknown	Expiring to start back design works sometimes later in 2011	Expiring to start building the new Solid waste management site in 2012 and commission in 2013.
B - 1 - k detailed minutes of any public consultation and participation with local organizations and the residents of the community regarding license amendments;	NIL	N/A	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

License Condition (as stated, if required)	Status of Compliance	Short Term Plan for Compliance	Schedule for Implementation of Compliance (including funding plans where applicable and anticipated development)	Long Term Plan for Compliance (including funding plans where applicable and anticipated development)	Schedule for Implementation of Long Term Plan for Compliance (including funding plans where applicable and anticipated development)
B - 1 - i a summary of any studies or reports requested by the Board that relate to water use and waste disposal or restoration, and a brief description of any future studies planned; and	Yes. Studies on waste management is in progress.	Currently on hold.	Currently unknown.	Expecting to start back design works sometimes later in 2011	Expecting to start building the new Solid waste management site in 2012 and commission in 2013.
B - 1 - ii any other details on water use or waste disposal requested by the Board by November 1st of the year being reported.	Yes. Segregation of hazardous wastes into a containment area as well as the removal of waste oil barrels into a lined containment was suggested by the INAC Inspector in his report dated August 22, 2010.	Will be followed once the new facility is built.	No Schedule is set up yet.	Expecting to start back design work sometimes later in 2011. Segregation of hazardous wastes will be carried out at the same time when the contractor will be available at the community for building the new solid waste site.	Expecting to start building the new Solid waste management site in 2012 and commission in 2013.
B - 2 The Licensee shall comply with the "Monitoring Program" described in this License, and any amendments to the "Monitoring Program" as may be made from time to time, pursuant to the conditions of this License.	Not in Compliance.	Hamlet's plan to start this summer 2011.	N/A	N/A	N/A
B - 3 The "Monitoring Program" and compliance dates specified in the License may be modified at the discretion of the Board.	Yes, it will be followed.	Considering far northern smallest community in Nunavut, monitoring program and compliance plan are required to modify.	No Plan is set up yet.	N/A	N/A
B - 4 Meters, devices or other such methods used for measuring the volumes of water used and waste discharged shall be installed, operated and maintained by the Licensee.	Water use is calculated on the basis of water delivered to the residents. The waste volume is considered as the same volume of water consumption.	Financial record is maintained for water delivery	N/A	This process will be maintained	N/A
B - 5 The Licensee shall, within ninety (90) days after the first visit by the Inspector following issuance of this License, post the necessary signs to identify the stations of the "Monitoring Program". All signage postings shall be in the Official Languages of Nunavut.	Not in compliance	The GPS coordinates and Signage will be installed as soon as the new waste management facility is commissioned.	Expecting to start design works this summer 2012	These will be maintained	These will be maintained until the service life of this facilities.
B - 6 The Licensee shall post signs in the appropriate areas to inform the public of the location of the Water Supply Facilities and the Waste Disposal Facilities. All signage postings shall be in the official languages of Nunavut.	In compliance. Signage is there.	N/A	N/A	N/A	N/A
B - 7 The Licensee shall immediately report to the 24-Hour Spill Report Line (867-920-8130) any spills of Waste, which are reported to, or observed by the Licensee, within the municipal boundaries or in the areas of the Water Supply or Waste Disposal Facilities.	The Hamlet is following 24-hours Spill hot line for any spill emergency.	This process will be maintained.	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911 Hamlet of Grise Fiord

Licence Condition (add/delete as required)	Status/Compliance	Short Form Plan or Compliance	Schedule for implementation of compliance (including funding issues where applicable to municipal development)	Long Form Plan or Compliance	Schedule for implementation of compliance (including funding issues where applicable to municipal development)
B - 8 The Licensee shall ensure a copy of this License is maintained at the Municipal Office at all times. Any communication with respect to this License shall be made in writing to the attention of: (a) Manager of Licensing: Nunavut Water Board P.O. Box 119 Gjoa Haven, NU X0B 1J0 Telephone: (867) 360-6338 Fax: (867) 360-6369 Email: licensing@nunavutwaterboard.org (b) Inspector Contact: Water Resources Officer Nunavut District, Nunavut Region P.O. Box 100 Igloodit, NU X0A 0H0 Telephone: (867) 975-4295 Fax: (867) 979-6445	In compliance. The hamlet office has always a hard copy document available to the public.	N/A	N/A	N/A	N/A
B - 9 The Licensee shall submit one paper copy and one electronic copy of all reports, studies, and plans to the Board. Reports or studies submitted to the Board by the Licensee shall include a detailed executive summary in Inuktitut.	This is being followed in the license application and renewal process	N/A	N/A	N/A	N/A
B - 10 The Licensee shall ensure that all document(s) and correspondence submitted by the Licensee, to the Board, are received and acknowledged by the Manager of Licensing.	This is always being followed.	N/A	N/A	N/A	N/A
B - 11 The Licensee shall submit to the Board approval, within ninety (90) days of License issuance or upon the filing of any application in relation to the Licensee within that time, a "Plan of Compliance" that clearly demonstrates the measures the Licensee will undertake, including an implementation schedule, to achieve full compliance with the conditions of this License, including the issues in the Inspector's Reports.	This spread sheet is the Plan of Compliance document.	N/A	No funding issue	N/A	N/A
B - 12 The Licensee shall, for all Plans submitted under this License, include a proposed timetable for implementation. Plans submitted, can not be undertaken without subsequent written Board approval and direction. The Board may alter or modify a Plan if necessary to achieve the legislative objectives and will modify the Licensee in writing of acceptance, rejection or alteration of Plan.	Yes, it will be followed.	N/A	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911 Hamlet of Grise Fiord

Licence Condition (Additional Section 44 required)	Status of Compliance	Short-Term Compliance (Compliance to be achieved within 12 months)	Short-Term Compliance (Compliance to be achieved within 12 months)	Long-Term Compliance (Compliance to be achieved within 12 months)	Short-Term Compliance (Compliance to be achieved within 12 months)
B-13 The Licensee shall, for all Plans submitted under this License, implement the Plan as approved by the Board in writing.	This will be followed.	N/A	N/A	N/A	N/A
B-14 Every Plan to be carried out pursuant to the terms and conditions of this License shall become a part of this License, and any additional terms and conditions imposed upon approval of a Plan by the Board become part of this License. All terms and conditions of the License should be contemplated in the development of a Plan where appropriate.	This will be followed.	N/A	N/A	N/A	N/A
B-15 This License is not assignable except as provided in Section 44 of the Act.	Yes, the license is only assigned to Senior Administrative officer (SAO) of the Hamlet.	N/A	N/A	N/A	N/A
Part C: Conditions Applying to Water Use					
C-1 The Licensee shall obtain all fresh water from glacier melt water using the Water Supply Facilities or as otherwise approved by the Board in writing.	In compliance. This is being followed.	N/A	N/A	N/A	N/A
C-2 The annual quantity of water, used for all purposes, shall not exceed 7,720 cubic meters.	In compliance. The consumption is 5,733 cubic meters which is less than the permit quantity.	The quantity remains within the limit.	N/A	N/A	N/A
C-3 The Licensee shall not remove any material from below the ordinary high water mark of any water body unless otherwise approved by the Board in writing.	In compliance. This regulation is being followed.	N/A	N/A	N/A	N/A
C-4 The Licensee shall not cause erosion to the banks of any body of water and shall provide necessary controls to prevent such erosion.	In compliance. The regulation is being followed.	This will be maintained.	N/A	N/A	N/A
C-5 Sediment and erosion control measures shall be implemented prior to and maintained during the operation to prevent entry of sediment into water.	Yes, these will be implemented as required.	N/A	N/A	N/A	N/A
Part D: Conditions Applying to Waste Disposal					
D-1 The Licensee shall direct all Sewage to the Sewage Disposal Facility.	In compliance. Hamlet is dumping the entire quantity of sewage into the sewage lagoon daily.	N/A	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

Licence Condition (as required)	Status of Compliance	Short-Term Plan for Compliance	Short-Term Plan for Compliance (including handling of any deviations)	Long-Term Plan for Compliance (including handling of any deviations)
D-2 All Effluent discharged from the Sewage Disposal Facility at Monitoring Program Station GRI-4 shall not exceed the following effluent quality limits: BOD = 120mg/L; Total suspended Solids = 180mg/L; Fecal Coliforms = 1*10 ⁶ CFU/100 mL; Oil and Grease : not visible sheen and pH= between 6 and 9.	Not in compliance.	Hamlet is planning to start testing effluent in this summer 2011	This process will be continued in each summer.	This process will be continued until the life expectancy of this facility.
D - 3 A Freeboard limit of 1.0 meter, or as recommended by a qualified geotechnical Engineer and as approved by the Board in writing, shall be maintained at all dams, dykes, or structures intended to contain, withhold, divert or retain water or wastes.	In Compliance. 1.0m free board is maintained	N/A	N/A	N/A
D - 4 The Licensee shall provide at least ten (10) days notification to an Inspector, prior to initiating any decant of the sewage lagoon.	In compliance. This regulation is being followed	N/A	N/A	N/A
D - 5 The Sewage Disposal Facility shall be maintained and operated, in such a manner as to prevent structural failure.	In Compliance. Yes, the structural integrity is being maintained	N/A	Normally inspection is done in summer.	N/A
D - 6 The Licensee shall dispose of and permanently contain all Solid Wastes at the Solid Waste Disposal Facility or as otherwise approved by the Board in writing.	In compliance. Hamlet is dumping the entire quantity of wastes to the landfill site daily.	N/A	N/A	The new facility will be built and commissioned in 2013.
D - 7 The Licensee shall segregate and store all hazardous materials and/or hazardous waste, including waste oil, within the Solid Waste Disposal Facility in a manner as to prevent the deposit of deleterious substances into any water until such a time as proper disposal arrangements are made.	Not in compliance.	N/A	N/A	Hamlet will satisfy this requirement once the contractor will be available at the community to build the new waste management facility. It is expected in 2012-13.
D - 8 The Licensee shall implement measures to control wind-blown litter at the Solid Waste Disposal Facility.	Not in Compliance.	Action will be taken following the completion of the feasibility study.	Hamlet burns wastes in summer	The new facility is expected to be built and commissioned in 2013.
D - 9 The Licensee shall use clean material for construction, operation, and maintenance activities that is obtained from an approved source and which has been demonstrated not to produce acid rock drainage and to be non-metal leaching.	The Contractor is responsible for this cleaning process.	N/A	N/A	N/A
Part E: Conditions Applying to Modification and Construction				

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

Licence Condition (Additional Conditions Required)	Status of Compliance	Short Term Plan for Compliance	Sediment Compliance (including funding requirements and applicable regulations)	Long Term Plan for Compliance	Sediment Compliance (including funding requirements and applicable regulations)
E - 1 The Licensee shall submit to the Board for approval, design drawings stamped and signed by a qualified engineer registered in Nunavut, 6 months prior to the construction of any dams, dykes or structures intended to contain, withhold, divert or retain water or wastes.	In Compliance. This will be followed.	N/A	N/A	N/A	N/A
E - 2 The Licensee may, without written approval from the Board, carry out modifications to the Water Supply and Waste Disposal Facilities provided that such modifications are consistent with the terms of this License and the following requirements are met: a. the Licensee has notified the Board in writing of such proposed modifications at least sixty (60) days prior to beginning the modifications; b. these modifications do not place the Licensee in contravention of the License or the Act; c. the Board has not, during the sixty (60) days following notification of the proposed modifications, informed the Licensee that review of the proposal will require more than sixty (60) days; and d. the Board has not rejected the proposed modifications.	In Compliance.	N/A	N/A	N/A	N/A
E - 3 Modifications for which all of the conditions referred to in Part E, Item 3, have not been met, may only be carried out upon written approval from the Board. The Licensee shall provide as-built plans and drawings of the Modifications referred to in this License within ninety (90) days of completion of the Modification. These plans and drawings shall be stamped by an Engineer.	In compliance. The as-built drawing signed and stamped by the Engineer will be submitted to Board.	N/A	N/A	N/A	N/A
E - 4 All activities shall be conducted in such a way as to minimize impacts on surface drainage and the Licensee shall immediately undertake any corrective measures in the event of any impacts on surface drainage.	In compliance. No disturbances to surface drainage.	N/A	N/A	N/A	N/A
E - 5 The Licensee shall ensure that sediment and erosion control measures are implemented prior to and maintained during activities carried out under this Part to prevent the release of sediment and minimize erosion.	In compliance.	N/A	N/A	N/A	N/A
E - 6 The construction or disturbance of any stream/lake bed or banks of any definable water course are not permitted, unless authorized by the Board in writing.	In compliance. No disturbances to any stream/lake bed or bank.	N/A	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

Licence Condition (Additional Conditions Required)		Status of Compliance	Short Term Plan for Compliance	Schedule for Implementation of Compliance (including funding arrangements and development)	Long Term Plan for Compliance	Schedule for Implementation of Compliance (including funding arrangements and development)
Part 1	Conditions Applying to Operation and Maintenance					
F - 1	The Licensee shall submit to the Board for approval, within ninety (90) days following issuance of the License, an Operation and Maintenance (O&M) Manual for the Sewage Disposal Facility and Solid Waste Disposal Facility, prepared where appropriate in accordance with the "Guidelines for the Preparation of an Operation and Maintenance Manual for Sewage and Solid Waste Disposal Facilities in the Northwest Territories, 1996". The Manual shall take into consideration the comments received during the application review process and shall contain the following plans: (e) Sewage Operation and Maintenance Plan; (b) Solid Waste Operation and Maintenance Plan; (c) Hazardous Waste Management Plan; (d) Sludge Management Procedures; (e) Spill Contingency Plan; and (f) Monitoring Program Quality Assurance/Quality Control Plan (QA/QC Plan).	Not in compliance. The O&M manual of the sewage lagoon and the land fill site are not available.	The land fill site (waste management) project is on hold.	No exact schedule is set up yet.	Expecting to start back design works of the solid waste site in summer 2011.	O&M manual will be available once the solid waste site is built and commissioned. It is expected in 2013.
F - 2	The Licensee shall review the O&M Manual referred to in Part F, items 1 and 2 as required by changes in operation and/or technology and modify accordingly. Revisions are to be submitted in the form of an Addendum to be included with the Annual Report.	Not in compliance.	NIL	NIL	The O&M manual for waste management will be developed in 2012-13.	The manual of the new facility for waste management is expected to be available in 2013 and maintained until the life expectancy of the facility.
F - 3	An inspection of all engineered facilities related to the management of water and waste shall be carried out annually in July or August by a Geotechnical Engineer. The engineer's report shall be submitted to the Board within sixty (60) days of the inspection, including a covering letter from the Licensee outlining an implementation plan addressing each of the Engineer's recommendations.	In compliance. Annual inspection is done by GN-QGS Regional Municipal Planning Engineer.	N/A	N/A	N/A	This process will be continued until the life expectancy of all the facilities.

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

Licence Conditions (as required)	Status of Compliance	Short Term Plan for Compliance	Schedule Implementation of Compliance (including funding and other available resources)	Long Term Plan for Compliance	Schedule Implementation of Compliance (including funding and other available resources)
F-4 If, during the period of this Licence, an unauthorized discharge of waste occurs, or if such a discharge is foreseeable, the Licensee shall: a. employ the appropriate contingency measures as approved under the Operation and Maintenance Manual for the Hamlet of NAME b. report the incident immediately via the 24-Hour Spill Reporting Line at (867) 920-8130 and to the Inspector at (867) 975-4295; and c. submit to the Inspector, a detailed report on each occurrence, not later than thirty (30) days after initially reporting the event, that provides the necessary information on the location (including the GPS coordinates), initial response action, remediation/clean-up, status of response (ongoing, complete), proposed disposal options for dealing with contaminated materials and any preventative measures to be implemented.	N/A In compliance. No unauthorized discharge took place.	N/A	N/A	N/A	N/A
Part G: G-1 Conditions Applying to Abandonment and Restoration The Licensee shall submit to the Board for approval an Abandonment and Restoration Plan, at least six (6) months prior to (a) abandoning of any facilities and (b) the construction of new facilities to replace existing ones. Where applicable, the Plan shall include information on the following: a. solid waste facility; b. water intake facilities; c. the water treatment and waste disposal sites and facilities; d. petroleum and chemical storage areas; e. any site affected by waste spills; f. leachate prevention; g. an implementation schedule; h. maps delineating all disturbed areas, and site facilities; i. consideration of altered drainage patterns; j. type and source of cover materials; k. future area use; l. hazardous wastes; and m. a proposal identifying measures by which restoration costs will be financed by the Licensee upon abandonment.	N/A Not applicable right now.	N/A	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

License Condition (Additional to the License)	Short Term Compliance	Short Term Remedial Compliance	Short Term Remedial Compliance (including funding status, where applicable, and applicable dates)	Long Term Remedial Compliance	Short Term Remedial Compliance (including funding status, where applicable, and applicable dates)
G-2 The Licensee shall complete the restoration work within the time schedule specified in the Plan, or as subsequently revised and approved by the Board.	Hamlet will try to accommodate this requirement.	N/A	N/A	N/A	N/A
Part H-1					
H-1 The Licensee shall maintain Monitoring Program Stations and implement the program as described in the table below and the conditions under this Part. Stations GRI-1, GRI-2, GRI-3 and GRI-4.	Not in compliance right now.	Hamlet wants to start monitoring program this summer 2011	N/A	N/A	This process will be continued until the life expectancy of all the facilities.
H-2 The Licensee shall confirm the locations and GPS coordinates for all monitoring stations referred to in Part H Item 1 with an Inspector.	Not in compliance.	The GPS coordinates will be installed for Monitoring stations as described in the license this summer 2011.	Summer 2011	N/A	The stations will be maintained until the life expectancy of all the facilities.
H-3 The Licensee shall collect samples at Monitoring Program Stations GRI-2 and GRI-4, according to the frequency provided in Part H Item 1. Samples shall be analyzed for the following parameters: Biochemical Oxygen Demand – BOD ₅ Faecal Coliforms Total Suspended Solids pH Conductivity, Nitrate-Nitrite Oil and Grease (Visual), Total Phenols Magnesium, Calcium Sodium, Potassium Chloride, Sulphate Total Hardness, Total Alkalinity Ammonia Nitrogen, Total Zinc Total Cadmium, Total Iron Total Cobalt, Total Manganese Total Chromium, Total Nickel Total Copper, Total Lead Total Aluminum, Total Arsenic Total Mercury, Total Organic Carbon (TOC) Total Petroleum Hydrocarbons (GRI_2 only)	Not in compliance right now.	This is an accredited lab in Ottawa where wastewater effluent samples are planned to get tested.	Hamlet will do all these testings in summer 2011	N/A	This process will be continued until the life expectancy of the sewage lagoon.
H-4 The Licensee shall measure and record in cubic meters, the monthly and annual quantities of water pumped from Monitoring Program Station GRI-1 for all purposes and effluent pumped or discharged from Monitoring Program Station GRI-4.	In compliance. Hamlet is maintaining this record	Submitted to NWB along with the annual report. Annual water consumption is recorded equal volume to the wastewater discharge.	N/A	N/A	N/A

PLAN FOR COMPLIANCE LICENCE NO. 3BM-GRI 0911

Hamlet of Grise Fiord

License Condition (add or delete as required)	Status of Compliance	Short Term Plan for Compliance	Schedule for Implementation of Compliance (including funding and other where applicable to multiple dates/approvals)	Long Term Plan for Compliance	Schedule for Implementation of Compliance (including funding and other where applicable to multiple dates/approvals)
H-5 The Licensee shall measure and record the annual quantities of sludge removed from the Sewage Disposal Facility along with the methods of treatment, storage, and disposal provided.	Not in compliance. This process is not applicable to the current situation.	N/A	N/A	N/A	N/A
H-6 The Licensee shall, within ninety (90) days of License issuance, submit to the Analyst for approval, a Quality Assurance/ Quality Control (QA/QC) Plan. The Plan shall include up to date field sampling methods to all applicable standards acceptable to an accredited laboratory as required by Part J, item 8 and Part J, item 9. The Plan shall include a covering letter from the accredited laboratory confirming acceptance of the Plan for analysis to be performed under this License.	Not in compliance. Hamlet will follow the Lab standard QA/QC guidelines.	This will be implemented in summer 2011.	N/A	N/A	N/A
H-7 The license shall annually review the QA/QC plan submitted under Part J, item 6 and modify it as necessary. Revised plans shall be submitted to the NWB with an approval letter from an accredited lab that meets standards set in Part J, item 8 and Part J, item 9.	Not in Compliance.	N/A	QA/QC for drinking water supply is maintained by GN--Department of Health on monthly basis. Whereas Hamlet is monitoring chlorine residual of the drinking water directly from the truck	This process will be continued.	QA/QC for water supply, wastewater effluent and solid waste management will be established and is expected to operate fully by 2013.
H-8 All sampling, sample preservation and analysis shall be conducted in accordance with methods prescribed in the current edition of Standard methods for the Examination of Water and Wastewater, or by such other methods approved by the Board in writing.	Not in compliance. Chemical parameters of raw water and all the parameters for wastewater mentioned in the water License are planned to be tested by the accredited lab in Ottawa.	Hamlet will maintain the account	This process will be established. Hamlet will use the lab as necessary.	This process will be continued.	This process will be continued until the life expectancy of the facility.
H-9 All analysis shall be performed in a laboratory accredited according to ISO/IEC Standard 17025. The Accreditation shall be current and in good standing.	Not in compliance. This monitoring program will be implemented for the new sewage lagoon.	N/A	N/A	N/A	N/A
H-10 Modifications to the Monitoring Program may be made only upon written approval from the NWB. Requests for changes to the Monitoring Program should be forwarded to the NWB in writing, and should include the justification and appropriate evidence to support the change.	Not in compliance. The Lab has a QA/QC plan which is being followed by the Hamlet.	Hamlet will be following INAC template QA/QC for monitoring wells as well.	N/A	This process will be continued.	This process will be continued until the life expectancy of the facility.