

'የየ∿Ċ౨∿୮ 〈I°Ժ‹I°Dc ሒԺ'I' bLት' Baffin Regional Health Services

EP 1 3

S CHART CHICA

C

U M A Engineering Ltd. Box 2545 Yellowknife, N.T. X1A 2P8

Att: Gary S. Craig.

SEP 1 4 1995

GRISE FIORD

WATER RESOURCES DIVISION YELLOWKNIFE, NT

September 1, 1995.

Re: GRISE FIORD SEWAGE LAGOON.

I have reviewed the plans dated August 14, 1995 for the above project.

My only concern was the truck discharge method utilizing a 150 mm hose adapter and a length of 100 mm hose discharging to a 500 mm pipe .

I was concerned that there might be problems with ice build up and freezing in the 500 mm pipe, and that there could be spillage at the rear of the truck if the hose became disconnected or if there was any other malfunction.

However, upon your assurance that this system has proven workable in another northern community, I would have no objection to assessing this method in the northernmost location in the Baffin Region; with the proviso that should problems be encountered the system would revert to direct discharge to a larger diameter flume.

Sincerely,

Bruce Stephen

Sr. Environmental Health Officer.

c.c. Mike Ferris

M.A.C.A. D.I.A.N.D. Igaluit

Paul Smith Gordon Wray

lqaluit

Bordon Wray Water Boai

Water Board Yellowknife