

C.O.C.: G35587

REPORT No. B13-18903

Report To:

Hamlet of Grise Fiord

P.O. Box 77 Grise Fiord,
Grise Fiord NU X0X 0J0

Attention: Janice Anderson

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 23-Jul-13

JOB/PROJECT NO.:

DATE REPORTED: 08-Aug-13

P.O. NUMBER:


SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

			Client I.D.	Raw Drinking Water			
			Sample I.D.	B13-18903-1			
			Date Collected	20-Jul-13			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Total Dissolved Solids	mg/L	3	SM 2540D	24-Jul-13/O	20		
Dissolved Organic Carbon	mg/L	0.2	EPA 415.1	24-Jul-13/O	0.5		
Chloride	mg/L	0.5	SM4110C	23-Jul-13/O	2.6		
Fluoride	mg/L	0.1	SM4110C	23-Jul-13/O	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	23-Jul-13/O	0.1		
Sulphate	mg/L	1	SM4110C	23-Jul-13/O	2		
Phenolics	mg/L	0.001	MOEE 3179	25-Jul-13/O	< 0.001		
Total Cyanide	mg/L	0.005	SM 4500CN	25-Jul-13/K	< 0.005		
Arsenic	mg/L	0.0001	EPA 200.8	24-Jul-13/O	< 0.0001		
Barium	mg/L	0.001	SM 3120	24-Jul-13/O	< 0.001		
Cadmium	mg/L	0.00002	EPA 200.8	24-Jul-13/O	< 0.00002		
Chromium	mg/L	0.002	SM 3120	24-Jul-13/O	< 0.002		
Chromium (VI)	mg/L	0.01	MOEE 3056	24-Jul-13/O	< 0.01 ¹		
Iron	mg/L	0.005	SM 3120	24-Jul-13/O	0.016		
Lead	mg/L	0.00002	EPA 200.8	24-Jul-13/O	0.00005		
Manganese	mg/L	0.001	SM 3120	24-Jul-13/O	< 0.001		
Selenium	mg/L	0.001	EPA 200.8	24-Jul-13/O	< 0.001		
Silver	mg/L	0.00002	EPA 200.8	24-Jul-13/O	< 0.00002		
Zinc	mg/L	0.005	SM 3120	24-Jul-13/O	< 0.005		
Surfactants Content	mg/L	0.05	SM-5540-C	08-Aug-13/O	< 0.05 ²		

1. Chromium (VI) result is based on total chromium

2. Subcontracted to Niagara Analytical



Gord Murphy
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.