

C.O.C.: ---

REPORT No. B14-14696

Report To:

Hamlet of Hall Beach
P.O. Box 3,
Hall Beach NU X0A 0K0 Canada

Attention: Tracy Laine

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 20-Jun-14

JOB/PROJECT NO.:

DATE REPORTED: 08-Jul-14


P.O. NUMBER:

SAMPLE MATRIX: Leachate

WATERWORKS NO.

Client I.D.	Leaking Sewage Lagoon Samples			
Sample I.D.	B14-14696-1			
Date Collected	11-Jun-14			

Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Fecal Coliform	cfu/100mL	1	MOE E3371	20-Jun-14/O	6000			
BOD	mg/L	3	SM 5210B	23-Jun-14/O	68			
Total Suspended Solids	mg/L	3	SM 2540D	25-Jun-14/O	8			
Hardness (as CaCO ₃)	mg/L	1	SM 3120	25-Jun-14/O	217			
Conductivity @25°C	µmho/cm	1	SM 2510B	23-Jun-14/O	1260			
Alkalinity(CaCO ₃) to pH4.5	mg/L	5	SM 2320B	23-Jun-14/O	315			
pH @25°C	pH Units		SM 4500H	23-Jun-14/O	7.48			
Total Organic Carbon	mg/L	0.2	EPA 415.1	20-Jun-14/O	42.5			
Chloride	mg/L	0.5	SM4110C	23-Jun-14/O	152			
Nitrite (N)	mg/L	0.1	SM4110C	25-Jun-14/O	< 0.1			
Nitrate (N)	mg/L	0.1	SM4110C	25-Jun-14/O	< 0.1			
Sulphate	mg/L	1	SM4110C	23-Jun-14/O	34			
Ammonia (N)-Total	mg/L	0.01	MOEE 3364	26-Jun-14/O	43.6			
Phosphorus-Total	mg/L	0.01	E3199A.1	04-Jul-14/K	4.84			
Phenolics	mg/L	0.001	MOEE 3179	25-Jun-14/O	0.132			
Aluminum (total)	mg/L	0.01	SM 3120	25-Jun-14/O	0.09			
Arsenic	mg/L	0.0005	EPA 200.8	23-Jun-14/O	0.0023			
Cadmium	mg/L	0.005	SM 3120	25-Jun-14/O	< 0.005			
Calcium	mg/L	0.02	SM 3120	25-Jun-14/O	59.8			
Cobalt	mg/L	0.005	SM 3120	25-Jun-14/O	< 0.005			
Copper	mg/L	0.002	SM 3120	25-Jun-14/O	0.054			
Chromium	mg/L	0.002	SM 3120	25-Jun-14/O	< 0.002			
Iron (Total)	mg/L	0.005	SM 3120	25-Jun-14/O	0.256			
Lead	mg/L	0.02	SM 3120	25-Jun-14/O	< 0.02			



Gord Murphy

Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B14-14696

Report To:

Hamlet of Hall Beach
P.O. Box 3,
Hall Beach NU X0A 0K0 Canada

Attention: Tracy Laine

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 20-Jun-14

JOB/PROJECT NO.:


DATE REPORTED: 08-Jul-14

P.O. NUMBER:

SAMPLE MATRIX: Leachate

WATERWORKS NO.

			Client I.D.		Leaking Sewage Lagoon Samples			
			Sample I.D.		B14-14696-1			
			Date Collected		11-Jun-14			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Magnesium	mg/L	0.01	SM 3120	25-Jun-14/O	16.5			
Manganese (Total)	mg/L	0.001	SM 3120	25-Jun-14/O	0.045			
Mercury	mg/L	0.00002	SM 3112 B	23-Jun-14/O	< 0.00002			
Nickel	mg/L	0.01	SM 3120	25-Jun-14/O	< 0.01			
Potassium	mg/L	0.1	SM 3120	25-Jun-14/O	17.9			
Sodium	mg/L	0.2	SM 3120	25-Jun-14/O	96.6			
Zinc	mg/L	0.005	SM 3120	25-Jun-14/O	0.060			
Acenaphthene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Acenaphthylene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Anthracene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Benzo(a)anthracene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Benzo(a)pyrene	µg/L	0.01	EPA 8270	27-Jun-14/K	< 0.01			
Benzo(b)fluoranthene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Benzo(b+k)fluoranthene	µg/L	0.1	EPA 8270	27-Jun-14/K	< 0.1			
Benzo(g,h,i)perylene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Benzo(k)fluoranthene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Chrysene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Dibenzo(a,h)anthracene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Fluoranthene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Fluorene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Indeno(1,2,3,-cd)pyrene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Methylnaphthalene,1-	µg/L	0.05	EPA 8270	27-Jun-14/K	0.25			
Methylnaphthalene,2-	µg/L	0.05	EPA 8270	27-Jun-14/K	0.28			
Naphthalene	µg/L	0.05	EPA 8270	27-Jun-14/K	0.16			



Gord Murphy
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B14-14696

Report To:

Hamlet of Hall Beach
P.O. Box 3,
Hall Beach NU X0A 0K0 Canada

Attention: Tracy Laine

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 20-Jun-14

JOB/PROJECT NO.:


DATE REPORTED: 08-Jul-14

P.O. NUMBER:

SAMPLE MATRIX: Leachate

WATERWORKS NO.

			Client I.D.		Leaking Sewage Lagoon Samples			
			Sample I.D.		B14-14696-1			
			Date Collected		11-Jun-14			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Phenanthrene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Pyrene	µg/L	0.05	EPA 8270	27-Jun-14/K	< 0.05			
Benzene	µg/L	0.5	EPA 8260	23-Jun-14/O	< 0.5			
Toluene	µg/L	0.5	EPA 8260	23-Jun-14/O	0.7			
Ethylbenzene	µg/L	0.5	EPA 8260	23-Jun-14/O	< 0.5			
Styrene	µg/L	0.5	EPA 8260	23-Jun-14/O	< 0.5			
Xylene, m,p-	µg/L	0.4	EPA 8260	23-Jun-14/O	< 0.4			
Xylene, o-	µg/L	0.1	EPA 8260	23-Jun-14/O	0.2			
PHC F1 (C6-C10)	µg/L	20	MOE E3421	23-Jun-14/O	< 20			
PHC F2 (>C10-C16)	µg/L	50	MOE E3421	23-Jun-14/O	60			
PHC F3 (>C16-C34)	µg/L	400	MOE E3421	23-Jun-14/O	< 400			
PHC F4 (>C34-C50)	µg/L	400	MOE E3421	23-Jun-14/O	< 400			
Comment-extractable	-		-	23-Jun-14	-			
Comment-purgeable	-		-	23-Jun-14/O	-			
Oil & Grease-Total	mg/L	1.0	SM 5520	30-Jun-14/K	3.5			



Gord Murphy
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.