

JUL-19-01 15:08 FROM: WARDROP

ID: 1284988646

PAGE 2/2



N.W.T. SPILL REPORT

24-Hour Report Line

24-Hour Report Line

DATE: JUL 19 15:00

 24-Hour Report Line
 1-800-455-6868
 1-800-455-6868

A Incident date and time JULY 19 @ 15:00		B Date and time of spill DETECTED JAN 19 @ 10:30		C Incident number 01-234	
D Location and description of spill HALL BEACH / NORTHERN STORE, NONADIT					
E Primary responsible for spill NORTHERN STORE					
F Products spilled and estimated quantities (include name, volume, weight, etc.) HEATING FUEL - APPROX 475 LITRES					
G Cause of spill BELIEVED TO BE LEAKING (OVER THE MET MOUTH) FROM THE SHUT-OFF VALVE					
H Is spill hazardous? ☒ Yes ☐ No		I Is spill toxic? ☐ Yes ☐ No		J Is spill flammable? ☒ Yes ☐ No	
K Is spill corrosive? ☐ Yes ☐ No		L Is spill reactive? ☐ Yes ☐ No		M Is spill radioactive? ☐ Yes ☐ No	
N Action taken to contain, control, clean-up or disposal of spill and surrounding area LEAKING TANK HAS BEEN DRAINED					
O Damage to property, equipment, etc. ☐ None ☐ Minor ☐ Major					
P Possible threats to people, property, or environment, and the ability to contain, control, clean-up or disposal of spill MAY FLOW INTO HARBOUR?					
Q Overall spill recommendation: FUEL IS NOT HARMFUL WE ARE UNAWARE OF HOW FAR THE FUEL MAY HAVE TRAVELED THROUGH THE GROUND BUT IT SEEMS UNLIKELY THAT DIGGING TYPICAL WILL BE USEFUL AT THIS POINT SINCE THERE ARE NO WELLS IN THE COMMUNITY AND THE QUANTITY IS LIMITED. WE RECOMMEND THAT THE FUEL BE LEFT IN PLACE TO DEGRADE NATURALLY. THE AREA AROUND THE WATER WILL BE MONITORED, AND FURTHER ACTION UNDERTAKEN AS NECESSARY.					
Reported by E. SCHROTH		Position, Signature, Location CONSULTANT, WARDROP, WARDROP, MB		Telephone 204-956-0980	
Reviewed by ROB ENO		Position, Signature, Location MANAGER OF POLLUTION CONTROL		Telephone 967-475-5401	

 INTERNAL
 COPY

 18/184
 87-19-01 16:03 TOTAL STATION/SPILL LINE

 87-19-01 16:03 TOTAL STATION/SPILL LINE
 FROM: 1284988646

87-19-01 16:03 TOTAL STATION/SPILL LINE