



N.W.T. SPILL REPORT

24-Hour Report Line

Phone/DKBC (03) 920-8130

Fax/DKBC (03) 873-8824

A Report date and time JULY 23 / 02		B Date and time of spill (if known) JULY 21, 2002 (suspected)		C Original report Update no. 1		Spill number 02-432	
D Location and map coordinates (if known) and direction of moving HWS Radar Station Hall beach, Nunavut							
E Party responsible for spill Nasitug Corporation							
F Products spilled and estimated quantities (provide metric volumes/weights if possible) suspected Jet A1 fuel, estimated volume 14,000 litres							
G Cause of spill suspected leak in underground POL line							
H Is spill terminated? [X] yes [] no		If spill is continuing, give estimated rate N/A		J Is further spillage possible? [] yes [X] no		K Extent of contaminated area (in square metres if possible) Not known	
L Factors affecting spill or recovery (weather conditions, terrain, snow cover, etc.) underground POL line				M Containment (federal, provincial, dykes, etc.) Not known			
N Action, if any, taken or proposed to contain, recover, clean up or dispose of product(s) and contaminated materials upon suspecting a possible POL spill pumping of Jet A-1 between tanks was discontinued the pipeline is not being used, now							
O Do you require assistance? [X] yes [] no				P Possible hazards to persons, property, or environment; e.g. fire, drinking water, fish or wildlife not this time			
Q Comments and/or recommendations This remains to be a suspected fuel leak, between tanks, there was a discrepancy noted in the tank clips, hence the estimated 14,000 liter volume, there is no physical evidence of a spill. Nasitug Corporation is in meetings on this situation and will have hydrostatic pressure tests conducted on the line to determine if the line is broken and where the break is located. Dennis Martin will remain in contact with Environment Canada for any further updates							
Reported by Paula Pacholek		Position, Employer, Location N. Environmental Assessment Coord. / Env. Can. / Yellowknife		FOR SPILL LINE USE ONLY Local Agency EC Spill significance Local Agency contact: 24 time FAX/DKBC (03) 873-8824			
Reported to SPILL LINE		Position, Employer, Location SPILL LINE		Telephone 867 6694741 Telephone DKBC			