

C.O.C.: G35591

REPORT No. B13-12638

Report To:

Hamlet of Kimmirut

P.O Box 120,

Kimmirut Nu X0A 0N0

Attention: Saqiqtaq Tamela

Caduceon Environmental Laboratories

2378 Holly Lane

Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 28-May-13

JOB/PROJECT NO.:

DATE REPORTED: 07-Jun-13

P.O. NUMBER:


SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

			Client I.D.	Raw Drinking Water			
			Sample I.D.	B13-12638-1			
			Date Collected				
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Surfactants Content	mg/L	0.05	SM-5540-C	06-Jun-13/O	< 0.05 ²		
Total Dissolved Solids	mg/L	3	SM 2540D	28-May-13/O	20		
Chloride	mg/L	0.5	SM4110C	28-May-13/O	5.2		
Fluoride	mg/L	0.1	SM4110C	28-May-13/O	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	28-May-13/O	0.3		
Sulphate	mg/L	1	SM4110C	28-May-13/O	5		
Dissolved Organic Carbon	mg/L	0.2	EPA 415.1	01-Jun-13/O	0.8		
Total Cyanide	mg/L	0.005	SM 4500CN	05-Jun-13/K	< 0.005		
Arsenic	mg/L	0.0001	EPA 200.8	30-May-13/O	0.0001		
Barium	mg/L	0.001	SM 3120	29-May-13/O	0.001		
Cadmium	mg/L	0.00002	EPA 200.8	30-May-13/O	< 0.00002		
Chromium	mg/L	0.002	SM 3120	29-May-13/O	< 0.002		
Chromium (VI)	mg/L	0.01	MOEE 3056	29-May-13/O	< 0.01 ¹		
Copper	mg/L	0.002	SM 3120	29-May-13/O	< 0.002		
Iron	mg/L	0.005	SM 3120	29-May-13/O	< 0.005		
Lead	mg/L	0.00002	EPA 200.8	30-May-13/O	0.00058		
Manganese	mg/L	0.001	SM 3120	29-May-13/O	0.003		
Selenium	mg/L	0.001	EPA 200.8	30-May-13/O	< 0.001		
Silver	mg/L	0.00002	EPA 200.8	30-May-13/O	< 0.00002		
Zinc	mg/L	0.005	SM 3120	29-May-13/O	< 0.005		
Phenolics	mg/L	0.001	MOEE 3179	30-May-13/O	< 0.001		

¹ Chromium (VI) result is based on total chromium

² Subcontracted to Niagara Analytical



Gord Murphy

Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.