



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYINGI  
OFFICE DES EAUX DU NUNAVUT

File: 3BM-KIM0207

Nov 05, 07

The following information is provided in review of an application for Municipal Water Licence Renewal for the Hamlet of Kimmirut.

**Subject: Assessment of Administrative Compliance for Municipal Water Licence Renewal**

The Nunavut Water Board ("NWB") has taken the opportunity ~~the~~ upon the receipt of the application for renewal of Licence 3BM-KIM0207 on Aug 20, 07 to review the public registry files and confirms that the following information is on file with the NWB, with respect to requirements of the Licence and is available upon request, for review along with the application.

**LICENCE**

Original Licence issued: Sep 1, 02

Renewal of Licence:

Amendment issued:

Licence expiry: Aug 31, 07

**SCOPE, DEFINITIONS AND ENFORCEMENT**

Inspection Report:

Year and date of Inspection:

Jul 30, 01

Aug 1, 02

Jul 31, 03

Aug 26, 03

2004 to 2006

Received:

Oct 2, 01

Dec 4, 02

Aug 26, 03

Apr 28, 04

Not received

Issues raised (In the last inspection report):

- As per the provision of current license part D, item 6 the Licensee was not maintaining the sewage disposal facilities to the satisfaction of the inspector. Furthermore, the Licensee was not maintaining a copy of the Water Licence at the municipal office at all times as stipulated in the licence part B, general conditions item 7.
- The chlorine system was leaking and required maintenance.
- The Solid Waste Disposal Facility is in very poor operational condition. Waste oil drums were not properly cleaned in an upright position, signs of leakage from waste drums was visible.
- The sewage truck discharge shall be relocated (down stream about 10 meters) to minimize the flow of sewage through the dump.

Compliance Report:

- 

Licence No. 3BM-KIM0207

## **GENERAL CONDITIONS**

Annual Report:

Year Reporting:

2002

2003

2004

2005

2006

Received:

Apr 3, 03

Nov 26, 04

Nov 22, 05

Jun 15, 06

Jun 5, 07

## **WATER USE**

Fees Provided: Not Applicable

## **WASTE DISPOSAL**

Notification of Discharge provided: No

## **MODIFICATION AND CONSTRUCTION**

As-built plans/drawings submitted: Yes

## **OPERATION AND MAINTENANCE**

Operation and Maintenance Plan required by: September 1, 2003

- Not Submitted

## **ABANDONMENT AND RESTORATION**

Required six (6) months prior to closure of any licensed facilities.

- No Plans Submitted to date.

## **MONITORING PROGRAM**

All data collected under the Monitoring Program to be submitted with the Annual Report.

- Incomplete

Prepared by:

Devendra Bhandari  
Technical Advisor  
Nunavut Water Board