



NWB Tools

Ida Porter <ida.porter@nwb-oen.ca>

[Licensing] 3BM-KIM0911 Water Licence Renewal - AANDC comments on January 10, 2014 review

3 messages

Sonia Aredes <sonia.aredes@nwb-oen.ca>

Tue, Jul 14, 2015 at 2:46 PM

To: Jean.Allen@aandc-aadnc.gc.ca, "Roy, Bhabesh" <broy@gov.nu.ca>, Licensing Department <licensing@nwb-oen.ca>

This email is referred to the review you performed on January 10, 2014 on the 3BM-KIM0911 Water Licence Renewal Application submitted by the Hamlet of Kimmirut; I am the Tech assigned to this file.

On the Review results, Wastewater Treatment, Enhanced Sewage Disposal Facility, item No.9, referring to the 3 year site-specific study on the wetland planned by the Hamlet in order to determine its efficiency, you recommended that a Plan for this study be submitted to the NWB for review prior to commissioning of the enhanced sewage disposal site "to ensure that issues pertaining to eventual compliance architecture are not overlooked".

I am writing you regarding a conversation I had on this subject with Bhabesh the engineer representative of the Hamlet for the Water Licence Renewal; we concluded that would be of big help to the Hamlet to have a general scheme of what this Plan will look like, i.e a table of contents or more details on AANDC expectations about the Plan. This would help the Hamlet to formulate its requirements to the consulting firm they hire for this work and also to have a Plan according to the reviewers expectations.

Your help on this will be much appreciated

Regards

Sonia Aredes

Jean Allen <Jean.Allen@aandc-aadnc.gc.ca>

Wed, Jul 15, 2015 at 11:21 AM

To: Bhabesh Roy <broy@gov.nu.ca>, Licensing Department <licensing@nwb-oen.ca>, Sonia Aredes <sonia.aredes@nwb-oen.ca>

Hi Sonia,

I think a framework for the 3-year wetland study would be sufficient...we were just looking for more information on the study regarding methods, proposed monitoring (locations, frequency, parameters, etc.), analysis, QA/QC, mitigation measures, etc. I remember there was some good information provided in the O&M Manual and the Environmental Monitoring Program document but I think they were both specific to licence requirements and I'm not sure if there are other monitoring locations within the wetland area that will be tested other than Kim-7 and Kim-8? I'm assuming there will be a few monitoring locations in between to check treatment efficiency as effluent moves through the wetland? Sorry, I may have to review some of the documents again as it has been awhile since I last reviewed this. Please let me know if you require additional clarification. To summarize, I don't think a detailed plan is required at this point...a framework would meet our needs to provide an idea of what the plan is going forward and I'm thinking more detailed information will be provided in the evaluation reports and the final summary report that are to be submitted with the annual report.

Jean

On the Review results, Wastewater Treatment, Enhanced Sewage Disposal Facility, item No.9 , referring to the 3 year site-specific study on the wetland planned by the Hamlet in order to determine its efficiency, you recommended that a Plan for this study be submitted to the NWB for review prior to commissioning of the enhanced sewage disposal site "to ensure that issues pertaining to eventual compliance architecture are not overlooked".*

[Quoted text hidden]

Fri, Jul 17, 2015 at 9:51 AM

Does this need to be save into central? or printed for Technical Transmittal? please respond

Regards,



Licence Administrator- Administratrice des permis
ՀԿՐՆ ԳԾԸՌ- Litsaligirumun Ikayuti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᐅᑦ ᐱᓕᓕᓂᐅᑦ ᑲᓂᓕᐅᑦ - NUNAVUT IMALIRIYIN KATIMAYINGI
www.nwb-oen.ca

Titigacaqvia 119
Uqhuqhuq, NII, X013 130

Tel / Téléphone / ᐱᑦᓴᐅᑕ / Hivayaula: (867) 360-6338 | Fax / Télécopieur / ᐱᑦᓴᐅᑕ / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐱᑦᓴᐅᑕᐱᑦ / Akiittug: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

[Quoted text hidden]

>>> Sonia Aredes <sonia.aredes@nwb-oen.ca> 7/14/2015 4:46 PM >>>

{Quoted text hidden}