



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓐ ᐃᓕᓕᓂᓐ ᑲᓂᓕᓂᓐ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File: 3BM-KIM0207

Nov 05, 07

The following information is provided in review of an application for Municipal Water Licence Renewal for the Hamlet of Kimmirut.

Subject: Assessment of Administrative Compliance for Municipal Water Licence Renewal

The Nunavut Water Board ("NWB") has taken the opportunity ~~the~~ upon the receipt of the application for renewal of Licence 3BM-KIM0207 on Aug 20, 07 to review the public registry files and confirms that the following information is on file with the NWB, with respect to requirements of the Licence and is available upon request, for review along with the application.

LICENCE

Original Licence issued: Sep 1, 02
Renewal of Licence:
Amendment issued:
Licence expiry: Aug 31, 07

SCOPE, DEFINITIONS AND ENFORCEMENT

Inspection Report:

Year and date of Inspection:
Jul 30, 01
Aug 1, 02
Jul 31, 03
Aug 26, 03
2004 to 2006

Received:
Oct 2, 01
Dec 4, 02
Aug 26, 03
Apr 28, 04
Not received

Issues raised (In the last inspection report):

- As per the provision of current license part D, item 6 the Licensee was not maintaining the sewage disposal facilities to the satisfaction of the inspector. Furthermore, the Licensee was not maintaining a copy of the Water Licence at the municipal office at all times as stipulated in the licence part B, general conditions item 7.
- The chlorine system was leaking and required maintenance.
- The Solid Waste Disposal Facility is in very poor operational condition. Waste oil drums were not properly cleaned in an upright position, signs of leakage from waste drums was visible.
- The sewage truck discharge shall be relocated (down stream about 10 meters) to minimize the flow of sewage through the dump.

Compliance Report:

•

Licence No. 3BM-KIM0207

GENERAL CONDITIONS

Annual Report:

Year Reporting:

2002

2003

2004

2005

2006

Received:

Apr 3, 03

Nov 26, 04

Nov 22, 05

Jun 15, 06

Jun 5, 07

WATER USE

Fees Provided: Not Applicable

WASTE DISPOSAL

Notification of Discharge provided: No

MODIFICATION AND CONSTRUCTION

As-built plans/drawings submitted: Yes

OPERATION AND MAINTENANCE

Operation and Maintenance Plan required by: September 1, 2003

- Not Submitted

ABANDONMENT AND RESTORATION

Required six (6) months prior to closure of any licensed facilities.

- No Plans Submitted to date.

MONITORING PROGRAM

All data collected under the Monitoring Program to be submitted with the Annual Report.

- Incomplete

Prepared by:

Devendra Bhandari
Technical Advisor
Nunavut Water Board

Licence No. 3BM-KIM0207