

C.O.C.: DW 15133

REPORT No. B14-15133

Report To:

Hamlet of Kimmirut

P.O Box 120,

Kimmirut Nu X0A 0N0

Attention: Saqiqtaq Tamela

Caduceon Environmental Laboratories

2378 Holly Lane

Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 24-Jun-14

JOB/PROJECT NO.:

DATE REPORTED: 04-Jul-14


P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

			Client I.D.	Raw Drinking Water	Treated		
			Sample I.D.	B14-15133-1	B14-15133-2		
			Date Collected	16-Jun-14	16-Jun-14		
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Surfactants Content	mg/L	0.05	SM-5540-C	03-Jul-14/O	< 0.05 ¹		
Total Dissolved Solids	mg/L	3	SM 2540D	30-Jun-14/O	96		
Turbidity	NTU	0.1	SM 2130	25-Jun-14/O	0.4	0.3	
Chloride	mg/L	0.5	SM4110C	26-Jun-14/O	3.0		
Fluoride	mg/L	0.1	SM4110C	26-Jun-14/O	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	26-Jun-14/O	< 0.1		
Sulphate	mg/L	1	SM4110C	26-Jun-14/O	30		
Dissolved Organic Carbon	mg/L	0.2	EPA 415.1	25-Jun-14/O	1.9		
Total Cyanide	mg/L	0.005	SM 4500CN	26-Jun-14/K	< 0.005		
Phenolics	mg/L	0.001	MOEE 3179	25-Jun-14/O	< 0.001		
Arsenic	mg/L	0.0001	EPA 200.8	25-Jun-14/O	0.0002		
Barium	mg/L	0.001	SM 3120	25-Jun-14/O	0.002		
Cadmium	mg/L	0.00002	EPA 200.8	25-Jun-14/O	< 0.00002		
Chromium	mg/L	0.002	SM 3120	25-Jun-14/O	< 0.002		
Chromium (VI)	mg/L	0.01	MOEE 3056	26-Jun-14/O	< 0.01		
Iron	mg/L	0.005	SM 3120	25-Jun-14/O	< 0.005		
Lead	mg/L	0.00002	EPA 200.8	25-Jun-14/O	< 0.00002		
Manganese	mg/L	0.001	SM 3120	25-Jun-14/O	< 0.001		
Selenium	mg/L	0.001	EPA 200.8	25-Jun-14/O	< 0.001		
Silver	mg/L	0.00002	EPA 200.8	25-Jun-14/O	< 0.00002		
Zinc	mg/L	0.005	SM 3120	25-Jun-14/O	< 0.005		

¹ Subcontracted to Niagara Analytical



Gord Murphy

Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.