

C.O.C.: ---

REPORT No. B14-26840

Report To:

Municipality of Kimmirut

P.O Box 120,

Kimmirut Nu X0A 0N0

Attention: Saqiqtaq Tamela

Caduceon Environmental Laboratories

2378 Holly Lane

Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 15-Oct-14

JOB/PROJECT NO.:

DATE REPORTED: 31-Oct-14

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

			Client I.D.		Raw Drinking Water - Pump House			
			Sample I.D.		B14-26840-1			
			Date Collected		07-Oct-14			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Surfactants Content	mg/L	0.05	SM-5540-C	28-Oct-14/O	< 0.05 ²			
TDS (Calc. from Cond.)	mg/L		Calc.	20-Oct-14	133			
Total Organic Carbon	mg/L	0.2	EPA 415.1	20-Oct-14/O	2.3			
Chloride	mg/L	0.5	SM4110C	16-Oct-14/O	3.5			
Fluoride	mg/L	0.1	SM4110C	16-Oct-14/O	< 0.1			
Nitrate (N)	mg/L	0.1	SM4110C	16-Oct-14/O	< 0.1			
Nitrite (N)	mg/L	0.1	SM4110C	16-Oct-14/O	< 0.1			
Sulphate	mg/L	1	SM4110C	16-Oct-14/O	42			
Phenolics	mg/L	0.001	MOEE 3179	30-Oct-14/O	< 0.001			
Arsenic	mg/L	0.0001	EPA 200.8	16-Oct-14/O	< 0.0001			
Barium	mg/L	0.001	SM 3120	16-Oct-14/O	0.006			
Cadmium	mg/L	0.00002	EPA 200.8	16-Oct-14/O	< 0.00002			
Chromium (VI)	mg/L	0.01	MOEE 3056	18-Oct-14/O	< 0.01 ¹			
Copper	mg/L	0.002	SM 3120	16-Oct-14/O	< 0.002			
Total Cyanide	mg/L	0.005	SM 4500CN	21-Oct-14/K	< 0.005			
Iron	mg/L	0.005	SM 3120	16-Oct-14/O	< 0.005			
Lead	mg/L	0.00002	EPA 200.8	16-Oct-14/O	< 0.00002			
Manganese	mg/L	0.001	SM 3120	16-Oct-14/O	0.002			
Selenium	mg/L	0.001	EPA 200.8	16-Oct-14/O	< 0.001			
Silver	mg/L	0.00002	EPA 200.8	16-Oct-14/O	< 0.00002			
Zinc	mg/L	0.005	SM 3120	16-Oct-14/O	< 0.005			

¹ Chromium (VI) result is based on total chromium

² Subcontracted to Niagara Analytical



M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Gord Murphy
Lab Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.