



P.O.Box 119  
Gjoa Haven, NU X0B1J0  
TEL: 867-360-6338  
FAX: 867-360-6369

NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYINGI

File: 3BM-KUG  
Tel: (867) 982-6500  
Fax: (867) 982-3060

Oct. 16, 2006

Mayor Derrick Power  
Hamlet of Kugluktuk  
P. O. Box 271  
Kugluktuk, Nunavut X0B 0E0

**Subject: 2004 Annual Report**

Dear Mayor Derrick Power,

The **Nunavut Water Board** (NWB) has reviewed the 2004 Annual Report, which is to fulfill the requirement of **Part B Item 1**, water licence **NWB3KUG0308**.

The **NWB** understands that the Hamlet installed a truck dump logging system in May 2004 from your 2003 Annual Report, but the Hamlet still estimated the sewage by adding 15% of fresh water rather than using the truckloads' data. The **NWB** recommends that the Hamlet utilize the installed truck dump logging system to generate useful and accurate discharge information. The **NWB** also would like to remind that as per Part B, Item 1 the Hamlet is to submit 2005 Annual Report prior to March 31<sup>st</sup>. The NWB has yet to receive this report and requests that it is provided immediately.

If you require assistance whatsoever please feel free to contact the undersigned at (867) 360-6338ext.27 or [tech4@nwb.nunavut.ca](mailto:tech4@nwb.nunavut.ca).

Sincerely,

Zhong Liu  
Technical Advisor