



ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: **3BM-KUG1520**

June 08, 2018

Donald LeBlanc
Senior Administrative Officer
Hamlet of Kugluktuk
P.O. Box 271
Kugluktuk, NU X0B 0E0

Email: sao@kugluktuk.ca

RE: NWB Technical Review of 2017 Annual Report for the Hamlet of Kugluktuk; Water Licence No. 3BM-KUG1520

Dear Mr. LeBlanc:

The Nunavut Water Board (NWB) has completed a technical review of the 2017 Annual Report.

On March 26, 2018, the NWB acknowledged receipt of the Annual Report and provided it to the Kitikmeot distribution list for information. No comments have been received to date.

The technical review of the Annual Report found that additional information is necessary to meet the following requirements of the Licence:

- Part B, Item 1b: The Annual Report shall contain:

the daily, monthly, and annual quantities, in cubic metres, of freshwater obtained from Monitoring Station KUG-1;

The Annual Report did not provide volumes from KUG-1, volumes in cubic metres, or daily volumes. Monthly and annual volumes in Litres from the Fluid Manager Water Delivery System was provided. Since there is no Water storage in the Water Supply Facility, this volume, if explained, could be an effective surrogate for KUG-1.

- Part B, Item 1c: The Annual Report shall contain:

the daily, monthly and annual quantities in cubic metres of sewage effluent discharged at Monitoring Station KUG-3;

The Annual Report did not provide any volume information from KUG-3. While the

statement “estimated discharge of sewage waste based on quantities used” was included, the column for “Quantity of Sewage Waste Discharged” is blank.

- Part B, Item 1d: The Annual Report shall contain:

the monthly and yearly quantities of authorized Waste – bulky metal, hazardous, wood and soil—accepted at the Solid Waste Facilities;

The Annual Report did not provide any information on quantities of solid waste.

Please provide this information in the 2018 Annual Report and all future reports. If for some reason data or information is not available, include a discussion indicating:

- What information is missing;
- Why it was not provided; and
- Steps being made to provide it in the future.

The NWB would like to take this opportunity to remind the Licensee about additional submission requirements within the Licence beyond the Annual Report. The Licence requires submissions under:

- Part E, Item 2;
- Part E, Item 5;
- Part E, Item 6;
- Part E, Item 7;
- Part F, Item 1;
- Part F, Item 2;
- Part F, Item 3;
- Part G, Item 1; and
- Part H, Item 11.

The NWB strongly recommends that the Licensee address issues identified in 2017 by the Inspector¹. Please provide a brief summary of work done to address concerns or deficiencies listed in the inspection reports and/or compliance reports prepared by an Inspector or other parties in the 2018 Annual Report.

¹ Indigenous and Northern Affairs Canada (INAC) Inspection Report, July 10, 2017.

Should you have any questions, please feel free to contact me, Dave Baines, at (867) 360-6338 (extension 29), at your earliest convenience.

Sincerely,

Dave Baines
Nunavut Water Board,
Technical Advisor

Cc: Distribution List – Kitikmeot