

Parameter	Maximum Concentration of Any Grab Sample	REP-4 Results			
		29-Jun-12	July	August	September
BOD ₅	80 mg/L	<6.0 mg/L			
Total Suspended Solids	100 mg/L	11.0 mg/L			
Fecal Coliforms	1x10 ⁴ CFU/100 mL	430 CFU/100 mL			
Oil and Grease	No visible sheen	<2 mg/L			
pH	Between 6 and 9	7.76			