



3BM-REP1520 Renewal Application response to comments

Graham2, Anna (EC) <anna.graham2@canada.ca>

Tue, Dec 15, 2020 at 5:28 PM

To: Richard Dwyer <richard.dwyer@nwb-oen.ca>

Cc: "EE Nord RPN NU / EA North PNR NU (EC)" <ec.eenordrpnnu-eanorthpnrnu.ec@canada.ca>

Hi Richard,

GN-CGS has provided responses to most of the comments, and there are commitments to provide several plans in March 2021.

However, ECCC Comment 3 was not sufficiently responded to. ECCC acknowledges that a new pre-treatment retention lagoon will be constructed, however, the design document notes that the natural wetland will continue to be relied on for primary treatment. As it was stated that in 2012 that the wetland was overloaded, it is unclear whether the assumed treatment efficiencies of the wetland are accurate. ECCC therefore continues to recommend that a comparison of quality at entry and at discharge from the wetland system to confirm assumptions on treatment capacity since it will continue to be relied upon for primary treatment.

Apologies for the delay.

Regards,

Anna Graham

Environmental Assessment Officer

Environmental Protection Operations Directorate

Environment and Climate Change Canada / Government of Canada

Anna.Graham2@canada.ca /Tel: 819-938-4051

Anna Graham

Agente de l'évaluation environnementale

Direction des activités de protection de l'environnement

Environnement et changement climatique Canada / Gouvernement du Canada

Anna.Graham2@canada.ca /Tél: 819-938-4051

From: Richard Dwyer <richard.dwyer@nwb-oen.ca>

Sent: December 10, 2020 5:03 PM

To: Graham2, Anna (EC) <anna.graham2@canada.ca>

Subject: Re: FW: 3BM-REP1520 Renewal Application response to comments

Hi Anna,

The NWB looks forward to receiving response next week.

Regards,

Richard

[Redacted signature]

[Quoted text hidden]