



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᓅᓂᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File: 3BM-PAN0207

December 11, 2007

The following information is provided in review of an application for Municipal Water Licence Renewal for the Hamlet of Pangnirtung in the Qikiqtaaluk Region.

Subject: Assessment of Administrative Compliance for Municipal Water Licence Renewal

The Nunavut Water Board ("NWB") has taken the opportunity upon the receipt of the application for renewal of Licence 3BM-PAN0207 on November 20, 2007 to review the public registry files and confirms that the following information is on file with the NWB, with respect to requirements of the Licence and is available upon request, for review along with the application.

LICENCE

Original Licence issued: December 1, 2002 (NWB); January 1, 1991 (NWT Water Board)

Renewal of Licence: NA

Amendment issued: NA

Licence expiry: November 31, 2007

SCOPE, DEFINITIONS AND ENFORCEMENT

Inspection Report:

Year and date of Inspection:

Jul 30, 2002

Jun 30, 2003

2004 to 2006

Received:

Jul 30, 2002

Aug 8, 2003

Not received

Issues raised: The Sewage Disposal Facility was not treating sewage properly and Solid Waste Disposal Facility had also problem due to seepage.

Compliance Report:

•

GENERAL CONDITIONS

Annual Report:

Year Reporting:

2002

Received:

Apr 10, 2003

Licence No. 3BM-PAN0207

2003
2004 to 2006

Apr 30, 2004
Not received

WATER USE

Fees Provided: Not Applicable

-

WASTE DISPOSAL

Notification of Discharge provided: No any condition in the licence for notification of waste disposal

MODIFICATION AND CONSTRUCTION

As-built plans/drawings submitted: NA

OPERATION AND MAINTENANCE

Operation and Maintenance Plan required by: December 1, 2003

- Not Submitted

ABANDONMENT AND RESTORATION

Required six (6) months prior to closure of any licensed facilities.

- No Plans Submitted to date.

MONITORING PROGRAM

All data collected under the Monitoring Program to be submitted with the Annual Report.

- Incomplete

Prepared by:

Devendra Bhandari
Technical Advisor
Nunavut Water Board