

C.O.C.: ---

REPORT No. B15-01869

Report To:

Hamlet of Pangnirtung

P.O. Box 253,

Pangnirtung Nunavut X0A 0R0 Canada

Attention: Billy Qaqasiq

Caduceon Environmental Laboratories

2378 Holly Lane

Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 27-Jan-15

JOB/PROJECT NO.: WW

DATE REPORTED: 04-Feb-15

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.	Influent	Effluent		
			Sample I.D.	B15-01869-1	B15-01869-2		
			Date Collected	21-Jan-15	21-Jan-15		
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
BOD	mg/L	3	SM 5210B	28-Jan-15/O	461	4	
Total Suspended Solids	mg/L	3	SM 2540D	28-Jan-15/O	332	3	
COD	mg/L	5	SM 5220D	04-Feb-15/O	1410	11	



M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Gord Murphy

Lab Supervisor