

Your life Votte raterence

NS124-174447****

March 11, 1998

Ms. Dionne Filiatrault Technical Advisor Nunavut Water Board P.O. Box 119 Gjoa Haven, NT X0E 1J0

Dear Dionne:

Re: Pangnirfung Sewage Treatment Facility Planning Study

Further to your request of February 9, 1998 I have reviewed the above mentioned plan. As the proposal is a definite improvement over the existing facility I have only minor comments and are as follows:

- By approving this plan does the Nunavut Water Board approve the "go-ahead" of construction or is the Hamlet still required to submit an application to amend the current water licence?
- Table 6.4 on page 9 of the plan lists the effluent quality requirements, however, on page 5 of the plan it indicates that there is concern over the contamination of clam beds in that area. If the area is harvested for shellfish a requirement to analyse for Fecal Coliforms should be included and is already listed in the current licence.

I have attached the comments of Mr. Paul Smith, Nunavut District Office, to this letter as the report was also sent to him.

If you would like to discuss anything further, please feel free to contact me at (403)669-2658 or Mr. Paul Smith of the Nunavut District Office at (819)979-4407.

Sincerely,

Shannon Pagotto
Regional Coordinator
Water Resources Division

c.c. Nunavut District encl.

Canada

DECEIVED MAR I 1 1998

e.H.