



NWB Tools

Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>

shut down notice for WWTP of Pangnirtung during construction.

Erik Skiby <erik.skiby@nwb-oen.ca>

Thu, May 8, 2014 at 4:11 PM

To: "Roy, Bhabesh" <Broy@gov.nu.ca>

Cc: "Ruediger, Ralph" <RRuediger@gov.nu.ca>, wthistle@gov.nu.ca, "Westwell, Bill"

<BWestwell@gov.nu.ca>, pfuentes@gov.nu.ca, pang_sao@qiniq.com, dmarceau@kudlik.biz,

steven.burden@exp.com, stephen.bliss@exp.com, David Hohnstein <david.hohnstein@nwb-oen.ca>, Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>

Mr. Roy Bhabesh,

The Nunavut Water Board ("NWB" or "Board") acknowledges receipt of your letter dated May 01, 2014 regarding the shutdown of the Wastewater Treatment Plant (WWTP) during the optimization process of the WWTP, and to fulfill the requirement for Part E, item 3 of the 3BM-PAN0810. After review of the information, The Board at this time cannot accept the proposed modification request at this time due to an expired Licence.

To help us further assess the situation could you please clarify some of the following questions/points:

- Could you please confirm location of PAN-3, and where discharge is occurring/ released?

The Board understanding is that during construction, effluent discharge will continue from the Pipe at Station PAN-3.

- Although the notice indicates that testing will be conducted for the parameters in the License, there is no indication that the Licensee plans to meet the criteria for the parameters in the License, Also there appears to be no contingency plan provided if effluent does not meet/exceed requirements. Could you please confirm?
- The Notice indicates that exp. services is the design consultant and exp Services is the contractor. However, the only information the NWB has on file regarding the proposed Modifications is from Dillon Consulting Ltd and the draft final Report entitled "Pangnirtung Waste Water Treatment Plant: Comprehensive Performance Evaluation" dated August 2007. Has Exp services provided there own plan for Optimization? Is there anymore information on the planned modification? Any further information or clarification you can provide would be helpful?

If you have any questions, please contact me at your earliest convenience by e-mail to erik.skiby@nwb-oen.ca or by phone at 867 360 6338.

