



Cambridge Bay, Northwest Territories, Canada X0E 0C0 Tel. (403) 983-7328 Fax. (403) 983-2253

File # 500-100-10

Kojo Kumi
Municipal Engineer
Municipal and Community Affairs
Cambridge Bay, NT

Marla

During recent duty trips to Pelly Bay and Taloyoak, concerns with respect to the community water supply were brought to my attention.

- Periodically, Pelly Bay experiences salt intrusion which forces the community to draw water directly from the river. The drinking water is consequently chlorinated by hand, a hit and miss situation at best;.
- Taloyoak occasionally draws water directly from the river because the pump allegedly is undersized and is not able to keep up to the demand.

These are unacceptable conditions, and contravene the Public Water Supply Regulations. Please notify this office in writing as to what corrective action will be taken.

Robert H. H. H. H.

Robert Phillips, CPHI(C)
Senior Environmental Health Officer

c.c. Elwood Johnston, SAO, Taloyoak
Marla Limousin, SAO, Pelly Bay

APPENDIX 1