

Parameter	Units	Bulk Supply		Community Building		Hotel	
		A	B	A	B	A	B
Phenols	mg/L	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001
Potassium	mg/L	0.94	1.0	0.81	0.76	0.84	0.87
Sodium	mg/L	5.5	5.2	4.6	4.3	4.6	5.0
Sulphate	mg/L	1.4	1.4	1.4	1.4	1.4	1.4
TKN	mg/L	<0.3	<0.3	<0.3	<0.3	<0.3	0.4
TOC	mg/L	1.7	1.7	1.8	1.7	2.0	1.9
Total Phosphorus	mg/L	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
TSS	mg/L	<1.0	<1.0	1.6	1.0	<1.0	1.4
PCBs	mg/L	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001

PCB analyses were performed by Axys Analytical Services Limited.