

REVISION DATE: September 26, 1997

REPORTING REQUIREMENTS: Pelly Bay (Open file) A

LICENCE CLASS: Unlicensed GNWT/Hamlet

CONDITIONS APPLYING TO WATER SUPPLY

Water Supply: Kugajuk River
~11,000 cubic metres per year

CONDITIONS APPLYING TO WASTE DISPOSAL

Solid waste facility 2 km from the Hamlet
Lagoon Seasonal discharge t
Sewage Disposal Effluent Standards:

Parameter	Max. Avg. Conc.	Max. Conc. Grab.
Fecal Coliform	CFU/dL	
BOD	mg/l	
Total Suspended Solids	mg/l	
Oil and Grease	mg/l	
pH	6.0-9.5	

DESCRIPTION	JAN.	FEB.	MARCH	APRIL	MAY	JUNE	JULY	AUGUST	SEPT.	OCT.	NOV.	DEC.
APPLICATION												
1. Correspondence A												
2. Water Supply B												
3. Waste Disposal												
i. Solid Waste B												
ii. Sewage Waste												
iii. Waste Oil												
iv. Other												
INSPECTION REPORT							24,1997B					

Comments:

- A Request copy of old file from DIAND. NWB file lost in the fire. Licence Adm. Retrieve file from the CD-Rom
- Application filed with the NWB September 1997 sent back incomplete. Plans to attend KIA AGM October 15 Assist community in completing the application form.
- B Inspection Concerns:

REVISION DATE: September 26, 1997

- i. Water Supply concerns in summer with low river flow/high tides problems with salt water intrusion. Hamlet request 5" extension to the intake and placement of a salt water intrusion alarm. MACA has not addressed this as yet.
- ii. Solid waste facility well maintained runoff diverted away from the site. Site needs fencing and warning signs. No burning took place last year. Lack of granular cover material. Waste oil segregated. Hamlet in process of determining suitability of cost sharing a waste oil furnace with NTPC.
- iii. Lagoon gyke failure in June. No improvements were made to the system. Suggest an overflow pipe/armoured trench be installed. Warnings signs required. Spill not reported.