



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: 3BM-PEL0712/F2

January 22, 2010

Andre Larabie, SAO
Hamlet of Kugaaruk
PO Box 205
Kugaaruk, NU X0B 1K0
Email: sao_kug@qiniq.com

RE: Spill Contingency Plan Approval for Licence 3BM-PEL0712, Part F Item 2, Type “B”

Dear Mr. Larabie,

The Nunavut Water Board (“NWB”) received the Plan entitled “Hamlet of Kugaaruk, NU, Spill Contingency Plan, Sewage and Solid Waste Sites” dated October 6, 2009, on October 13, 2009. On December 10, 2009, the NWB acknowledged receipt of the Plan and distributed it for a public review period with a deadline of January 15, 2010. Submissions were received from Indian and Northern Affairs Canada, Environment Canada and the Government of Nunavut – Department of Environment. Following a review of the plan and submissions, the document fulfills the requirements of the Licence and has been approved by the NWB under the motion number **2009-18-L08**. Although the Plan is functional, to address minor issues raised by the parties, the NWB requires an addendum to the approved plan within sixty (60) days of the date of this letter. The addendum is to include or address the following:

1. A 24-hour contact number for the response personnel;
2. Measures to notify the public who may be adversely affected by a spill;
3. Include quantities, locations and environmental impact for antifreeze;
4. A detailed site-specific map of appropriate scale, which includes facility locations, buildings, roads, culverts, environmentally sensitive areas, fuel storage locations, hazardous material storage, response equipment, drainage patterns and local water bodies;
5. Spill contingency plans for the water facilities;
6. The current plan (section 1.9) mentions no formalized preventative measures are in place. This should be expanded to include all preventative measures in practice. Consideration should be given to formalizing preventative measures;
7. MSDS should be current within 3 years, the Licensee is advised to keep this section current;

8. Update Contact Info for the following
 - a. EC contact should be replaced with Emergency Duty Officer 1-866-845-6037
 - b. GN contact should be replaced with 867-975-7700.

Should you have any questions, please feel free to contact the undersigned at 867-360-6338 ext 25 or by email at sjoseph@nunavutwaterboard.org.

Yours truly,

Original Signed By:

Sean Joseph
Technical Advisor

cc: Kitikmeot Distribution List
Jennifer Spencer – Dillon Consulting Limited