

C.O.C.: 126488

REPORT No. B07-32335

**Report To:**

Hamlet of Pond Inlet  
P.O Box 379  
Pond Inlet, Nunavut, X0A 0S0

**Attention:** Mike Richards

**Caduceon Environmental Laboratories**

2378 Holly Lane  
Ottawa, Ontario, K1V 7P1  
Tel: 613-526-0123  
Fax: 613-526-1244

DATE RECEIVED: 22-Oct-07

JOB/PROJECT NO.:


DATE REPORTED: 30-Oct-07

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

Parameter:		BOD	Total Suspended Solids			
Units:		mg/L	mg/L			
M.D.L.:		3	3			
Reference Method:		SM 5210	SM 2540			
Date Analyzed:		25-Oct-07	24-Oct-07			
Client I.D.	Sample I.D.	Date Collected				
Sewage Lagoon	B07-32335-1		90	60		
Taking at Number #4	B07-32335-2		81	56		

  
\_\_\_\_\_  
Krystyna Pipin, M. Sc.  
Lab Supervisor

M.D.L. = Method Detection Limit

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B07-31475

**Report To:**

**Hamlet of Pond Inlet**  
P.O Box 379  
Pond Inlet, Nunavut, X0A 0S0

**Attention:** Bhabesh Roy

**Caduceon Environmental Laboratories**

2378 Holly Lane  
Ottawa, Ontario, K1V 7P1  
Tel: 613-526-0123  
Fax: 613-526-1244

DATE RECEIVED: 12-Oct-07

JOB/PROJECT NO.:

DATE REPORTED: 23-Oct-07


P.O. NUMBER:

SAMPLE MATRIX: Water

WATERWORKS NO.

			Client I.D.:	Lagoon Raw Water	Leakage Water	Fresh Water from Water Reservoir	Treated Water from Supply Line
			Sample I.D.:	B07-31475-1	B07-31475-2	B07-31475-3	B07-31475-4
			Date Collected:				
Parameter	Units	M.D.L.	Reference Method	Date Analyzed			
Total Coliform	cts/100mL	1	MOE E3371	12-Oct-07	> 200000	53000	5
E coli	cts/100mL	1	MOE E3371	12-Oct-07	> 200000	< 10 <sup>1</sup>	< 1
BOD	mg/L	3	SM 5210	17-Oct-07	99	54	--
Total Suspended Solids	mg/L	3	SM 2540	16-Oct-07	34	156	--

1. Diluted due to matrix interference

  
Gord Murphy  
Lab Supervisor

M.D.L. = Method Detection Limit

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.

C.O.C.: ---

**REPORT No. B07-34682**

**Report To:**

**Hamlet of Pond Inlet**  
P.O Box 379  
Pond Inlet, Nunavut, X0A 0S0

**Attention:** Jonah Koonark

**Caduceon Environmental Laboratories**

2378 Holly Lane  
Ottawa, Ontario, K1V 7P1  
Tel: 613-526-0123  
Fax: 613-526-1244

DATE RECEIVED: 12-Nov-07

JOB/PROJECT NO.:

DATE REPORTED: 20-Nov-07

P.O. NUMBER:


SAMPLE MATRIX: Water

WATERWORKS NO.

			Client I.D.		Truck			
			Sample I.D.		Dumping Place			
			Date Collected		B07-34682-1			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Total Suspended Solids	mg/L	3	SM 2540	18-Nov-07/	180			
BOD	mg/L	3	SM 5210	13-Nov-07/	427			

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

  
Gord Murphy  
Lab Supervisor

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.

C.O.C.: ---

REPORT No. B07-33259

**Report To:**

**Hamlet of Pond Inlet**  
P.O Box 379  
Pond Inlet, Nunavut, X0A 0S0

**Caduceon Environmental Laboratories**

2378 Holly Lane  
Ottawa, Ontario, K1V 7P1  
Tel: 613-526-0123  
Fax: 613-526-1244

**Attention:** Mike Richards

DATE RECEIVED: 29-Oct-07

JOB/PROJECT NO.:

DATE REPORTED: 31-Oct-07

P.O. NUMBER:

SAMPLE MATRIX: Water

WATERWORKS NO.

Parameter	Total Coliform	E coli			
Units	cts/100mL	cts/100mL			
M.D.L.	1	1			
Reference Method	MOE E3371	MOE E3371			
Date Analyzed/Site	30-Oct-07/	30-Oct-07/			
Date Analyzed/Site					
Client I.D.	Sample I.D.	Date Collected			
Water Sample	B07-33259-1		> 20000000	224000 <sup>1</sup>	

1. Passed holding time, run by request

*K. Pipin*

Krystyna Pipin, M. Sc.  
Lab Supervisor

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Accredited by the Standards Council of Canada and CAEAL for specific tests.

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior written consent from Caduceon Environmental Laboratories.