From:	Sean Joseph
To:	hamletpond_sao@qiniq.com
Cc:	Phyllis Beaulieu
Subject:	Licence No. 3BM-PON1012 Renewal Application - Preliminary Technical Review
Date:	Thursday, May 24, 2012 11:35:51 AM

Dear Ms. Dobson:
The Preliminary Technical Review (PTR) conducted for the above-mentioned file determined that the following requirements, which remain outstanding under the existing licence No. 3BM-PON1012, must be addressed before the application could be processed by the Nunavut Water Board (NWB or Board):

1. Solid Waste Disposal Facilities update report, required under Part F, Item 1;
2. Updated consolidated Operations and Maintenance (O&M) Manual, required under Part F, Item 2;
3. Inspection report for engineered facilities related to the management of water and waste, required under Part F, Item 3;
4. Abandonment and Restoration (A&R) Plan for the Old Sewage Lagoon and Temporary Sewage Disposal Facility, required under Part G, Item 1; and
5. Quality Assurance/Quality Control (QA/QC) Plan, required under Part G, Item 13;

In addition the above requirements, the Board requests that the Licensee provide information on the following for consideration with the licence renewal application:

1. Preliminary results of inspections carried out on Sewage Lagoon by exp. services Inc.;
2. Timeline for the installation of Monitoring wells at the landfill;
3. Details on the new waste management site that will be designed and constructed to accommodate a variety of waste; and
4. Timeline for the resolving issues associated with the Bulky Metal site;

Should you have any comments or questions, please do contact me at your earliest convenience.

Regards,

Sean Joseph
Technical Advisor
Nunavut Water Board
Phone: 867-360-6338 Ext. 25
Fax: 867-360-6369
Email: sjoseph@nunavutwaterboard.org