
From: "Jim Wall" <nwbtech@polarnet.ca>
To: <nwblic@polarnet.ca>
Sent: Tuesday, August 27, 2002 10:11 AM
Subject: Fw: Lagoon upgrade at Pond Inlet

----- Original Message -----

From: "Michael Roy" <roymjp@inac.gc.ca>
To: <nwbtech@polarnet.ca>
Sent: Tuesday, August 27, 2002 8:38 AM
Subject: Re: Lagoon upgrade at Pond Inlet

> Hello Jim,
>
> Regarding the Pond Inlet sewage lagoon upgrade, I only have two small
comments to make.
>
> First, the proposed road to the sludge farm does not appear to have any
turnaround capability. I'm not sure if this is truly required or not - I
suppose a vehicle could just back out until the turnaround pad - but I
figured I'd mention it just in case.
>
> My second comment is more of a question than a comment. It relates to the
lagoon drainage outfall system, which appears to be a pipe built through the
berm, with a manhole to access the pipe and valves. I'm just curious if
there are means to prevent the liquid in the pipe from freezing up in the
winter, thus bursting the pipe. I'll admit to not being very knowledgeable
about pipes and their maintenance in a cold/permafrost region, thus I'm
curious as to how this works. However, I would assume that the engineers
must have taken cold temperatures into account, and thus the system will
likely work fine. This question is therefore more for my own curiosity and
is NOT intended to prevent the project from proceeding until more
information is supplied.
>
> If you have any questions or concerns, please feel free to contact me.
>
> Sincerely,
>
>
>
> Michael Roy
> Qikiqtani Regional Coordinator, Water Resources
> INAC - Nunavut Regional Office
> P.O. Box 2200, Iqaluit, NU, X0A 0H0,
> (867) 975-4555
> fax: (867) 975-4560
> roymjp@inac.gc.ca
>

> >>> "Jim Wall" <nwbtech@polarnet.ca> 08/23/02 09:33pm >>>

> Good evening:

>

> Please find attached a series of engineered drawings, as well as a cover letter describing proposed construction at the Pond Inlet Sewage Lagoon. The NWB is accepting written concerns and comments with regards to this project before August 27, 2002. Thank you in advance for your quick response to this request. Please accept my apologies for any inconvenience that may result from the tight timeline for requested response, which is necessitated by the limited time available to the Hamlet for construction.

>

>

> Sincerely,

>

> Jim Wall

> Technical Advisor

> Nunavut Water Board

> P.O. Box 119

> Gjoa Haven, NU X0B 1J0

> Tel: 867-360-6338

> Fax: 867-360-6369

> Email: nwbtech@polarnet.ca

>

>