

NOTES

- FOR ACCESS MANHOLE LID FRAMING PLANS 6mm THK. GALV. STEEL PLATE LID NOT SHOWN FOR CLARITY.
- ALL WELDS AND ABRASIONS TO BE REPAIRED WITH TWO COATES OF GALVCON.

- 1220mm DIA. HDPE DR 32.5 MANHOLE WALL
- ACCESS MANHOLE LID FRAMING PLAN FOR ARRANGEMENT 19mm DIA. GALV. NUT, BOLT & WASHER (8 REQ'D) SEE
- SEE ACCESS HATCH FRAMING PLAN FOR ARRANGEMENT 19mm DIA. GALV. NUT, CARRIAGE BOLT & WASHER (4 REQ'D)
- 6mm THK. GALV. STEEL PLATE ACCESS HATCH COVER
- 6mm THK. GALV. STEEL PLATE MANHOLE LID
- 6mm THK. x 75mm DEEP GALV. STEEL BAND, WELD TO LID
- AND BOLTED TO HDPE MANHOLE 75x75x8 GALV. ROLLED ANGLE CONTINUOUS ALL AROUND
- 55x55x6 GALV. ANGLE SEE LID FRAMING PLAN
- 55x55x6 GALV. ANGLE SEE ACCESS COVER FRAMING PLAN
- ALL AROUND WEATHER TIGHT 12.5mm DIA. RUBBER GASKET IN ROUTERED SLOT CONTINUOUS
- ⇉ 25mm WIDE \times 6mm THK. RUBBER GASKET, MASTIC TO UNDERSIDE OF HATCH COVER (TYP. 4 SIDES)
- ACCESS HATCH COVER HINGE (TYP. OF 2/PER) SEE DETAIL-3
 - ACCESS HATCH COVER HASP & LIFTING HANDLE SEE DETAIL-2
 - HDPE MANHOLE WALL 1600mm DIA. HDPE DR 32.5 MANHOLE WALL
 - HDPE LIFTING HOOK SEE FRAMING PLAN FOR ARRANGEMENT
- 52mm HDPE LIFTING HOOK C/W 25mm DIA. HOLE (4 REQ'D)

NOTE: DIMENSIONS IN METRES



UPGRADE & EXPANSION SEWAGE LAGOON

JOB TITLE

POND INLET, NU

F.S.C. JOB NO. 2002-0420

ENGINEERS AND ARCHITECTS Sulle 202:107 Main Street Whitehasse, V.I. Canada FERGUSON SIMEK CLARK

CLARIFICATION 3

3° 3	SHEET	RK	CHECKED BY	RW/SD	DRAWN BY	WO/RK	DESIGNED BY
SK-3	DRAWING NO	2002-0420	JOB NUMBER	JULY 26, 2002	DATE	1:25	SCALE