



NWB Tools

Karén Kharatyan <karen.kharatyan@nwb-oen.ca>

Re: Amendment WL of Qikiqtarjuaq

Karén Kharatyan <karen.kharatyan@nwb-oen.ca>

Tue, May 6, 2014 at 11:39 AM

To: "Roy, Bhabesh" <BRoy@gov.nu.ca>

Cc: Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>, "Ruediger, Ralph" <RRuediger@gov.nu.ca>, "Toonoo, Timoon" <TToonoo@gov.nu.ca>, "Thistle, Wayne" <WThistle@gov.nu.ca>, "Westwell, Bill" <BWestwell@gov.nu.ca>, "munqik@qiniq.com" <munqik@qiniq.com>

Hi Bhabesh,

Thank you for the additional information. When looking at the Plan for Compliance it was noticed that for some items the Status of Compliance is defined as **In compliance** which may not necessarily be the case.

For example under Part D, Item 7 the Licensee was required to submit for Board approval the Wetland Treatment Assessment that includes, but not limited...Although the Plan for Compliance states that *wetland were the part of the Design Brief of waste-water treatment facility and submitted to NWB prior to construction of the Sewage Lagoons*, however no information regarding Wetland Treatment Assessment was provided to the Board.

Part F item 1 required that the Licensee submit for the Board approval revised Operation and Maintenance Plans for (i). Water Storage; (ii) Sewage Treatment facility; (iii) Solid Waste Facility. The updated Operation and Maintenance (O&M) Plan for Water Reservoir, Sewage Lagoon and Solid Waste Disposal Facility completed by Nuna Burnside in September 2010, wasn't approved at that time as intervener comments and recommendations weren't addressed by the Licensee.

Part F, Item 4 required an annual Geotechnical Inspection to be carried out for all engineered facilities. No information was provided about those inspections.

Part F, Item 6 required the Licensee to submit to the Board approval a revised "Environmental Emergency Contingency Plan for Waste, Sewage and Solid Waste Operations.." The above mentioned O&M Plan contained a Section 8.0 Environmental Emergency Plan. However, as the O&M Plan wasn't approved that means the Environment Emergency Plan wasn't approved either. The stated attached letter provides a brief information about the draining out/cleaning the liner/inspecting the reservoir that cannot serve as a rational for the approval of the Environmental Emergency Plan.

This is to advise you that in the case if the renewal application is accepted and a renewal licence is issued by the Board, the above mentioned terms and conditions (but not limited to them) are still to be addressed.

You are also advised that some additional information may be required once the application and associated documents are distributed for the public review and comments are received from parties.

Regards,



Karén Kharatyan, Ph. D- ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ

Technical Advisor- Conseiller Technique

ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT

ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ

www.nwb-oen.ca

P.O. Box 119
Gjoa Haven, NU, X0B 1J0

C.P. 119
Gjoa Haven (Nunavut), X0B 1J0

ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ
ᑎᓄᓐᓂᓐ ᑎᓄᓐᓂᓐ

Titigaqvia 119
Uqhuqtuuq, NU, X0B 1J0

Tel / Téléphone / ᑎᓄᓐᓂᓐ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᑎᓄᓐᓂᓐ / Fax-kut: (867) 360-6369
Toll Free / 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(s) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courriel électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.

Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Fri, May 2, 2014 at 11:36 AM, Roy, Bhabesh <BRoy@gov.nu.ca> wrote:

Hi Phyllis,

Please find attached the amendment WL to delete Toxicity Test from the Hamlet water licence in the renewal process.

Thanks.

Bhabesh

Bhabesh Roy, M.A.Sc., P.Eng.

Municipal Planning Engineer

Community Government Services

Baffin Region, Government of Nunavut

P.O.Box 379, Pond Inlet, X0A 0S0

Ph-[867 899 7314](tel:8678997314)

Fax-[867 899 7328](tel:8678997328)

E-mail: broy@gov.nu.ca