



Robert Hunter <robert.hunter@nwb-oen.ca>

Request for Additional Information

Nidhi Singh <nidhi.singh@nwb-oen.ca>

Wed, Aug 28, 2024 at 4:02 PM

To: Bhabesh Roy <br13858@gmail.com>, qikasao@qiniq.com

Cc: Licensing Department <licensing@nwb-oen.ca>, Ali Shaikh <ali.shaikh@nwb-oen.ca>

Hi Daisy and Bhabesh,

The preliminary review of the renewal and amendment application indicates some missing information which is required to process the application. The additional information required is as follows:

1. The Licence (3BM-QIK1924) required submitting 6 plans under Part F, Item 1. The application package includes two plans (Spill Contingency and QA/QC); however, the rest are still missing (sub-items b to e). Please refer to Part F, Item 1 of the Licence for a detailed explanation.
2. The previous inspection and Licence mention the use of a mobile pump and boulders to dam up the Tulugak River as a contingency for water uptake. The current Licence does not authorize this activity and the renewal application does not request a change in method of water withdrawal from gravity to pumping. Please confirm the current and proposed method of water withdrawal from the Tulugak River.
3. Part H, Item 13 of the Licence requires the submission of a cover letter from an accredited laboratory confirming the acceptance of the QA/QC Plan which is missing from the Plan.
4. The QA/QC Plan also mentions Appendix F with a certificate of accreditation from the Canadian Association for Laboratory Accreditation (CALA). However, the Plan does not have appendices E and F.
5. On June 26, 2024, we received a notice from the Municipality of Qikiqtarjuaq regarding emptying the water reservoir to inspect the liner of the bed. Can you please provide an update regarding the findings of the inspection?

Please let me know how much time would be required to submit the above information. Thank you!

Regards,
Nidhi Singh
Technical Advisor
Nunavut Water Board