



ᐱᐸᐸᐸᐸᐸᐸ ᐱᐸᐸᐸᐸᐸᐸ
MUNICIPALITY OF QIKIQTARJUAQ

P. O. Box 4
Qikiqtarjuaq, NU X0A 0B0
Tel. (867) 927-8832 Fax (867) 927-8120

Nunavut Water
Board

MAY 11 2004

Public Registry

2003 Annual Report to Nunavut Water Board
for the Municipality of Qikiqtarjuaq

1. The following information is compiled pursuant to the requirements of Part B, Item 1, of Water Licence **NWBB3QIK0106**, issued to the Municipality of Qikiqtarjuaq.

- b), c). The monthly and annual quantity, in cubic metres, of water pumped from the Tulugak River or reservoir and the monthly and annual quantity of waste discharged to the sewage disposal facilities (including quantity of bagged sewage).

> Also fulfils SNP (Part B, Item 1 a, Item 2, & Schedule I C 1 & 2)

Month being Reported	Water pumped from Tulugak River or reservoir (in m ³)	Sewage disposed of at the sewage disposal facility (approximate amt as sewage not metered)	Amount of bagged sewage disposed of at the sewage disposal facility (# of bags)
January	1,761	1,761	0
February	1,644	1,644	0
March	1,790	1,790	0
April	1,796	1,796	0
May	1,812	1,812	0
June	1,641	1,641	0
July	1,693	1,693	0
August	1,578	1,578	0
September	1,880	1,880	0
October	1,843	1,843	0
November	1,715	1,715	0
December	1,750	1,750	0
Annual Total	20,903	20,903	0

Note: 1 m³ equals 1000 litres

- d) No Sewage Solids removed from the lagoon

- e) A detailed record of major maintenance work carried out on the water supply and waste disposal facilities:



ᑭᑭᑭᑭᑭᑭ ᑭᑭᑭᑭᑭᑭ
MUNICIPALITY OF QIKIQTARJUAQ

P. O. Box 4

Qikiqtarjuaq, NU X0A 0B0

Tel. (867) 927-8832 Fax (867) 927-8120

- Used divers to clean sediment off bottom of water reservoir liner and conducted a visual inspection of liner condition (liner is littered with thousands of holes and will require replacement)

f) Unauthorized discharges:

None

g) A description of any abandonment and restoration work carried out at areas where water supply or waste disposal facilities have been abandoned.

None

h) Any summary on any water use or waste disposal studies requested by the Board.

No requests made

i) Updates or revisions to Operation and Maintenance Plans:

None

j) Any other details requested by the Board by November 1st:

No requests made

Additional Information:

- persistent pH problems with water supply – have been unsuccessful in balancing pH to aesthetic objective as outlined in the *Guidelines for Canadian Drinking Water Quality*.
- Levels of faecal coliform and biological oxygen demand breach the effluent quality standards and concentrations of ammonia and phenols exceed the *Canadian Water Quality Guidelines for the Protection of Freshwater Aquatic Life*. Toxicity Indicator (IC₅₀) 5.3% for sewage disposal – have been unsuccessful in correcting this problem, an engineer may be required.
- Interest in fluoridation for water supply.
- O&M Plan is pending funding approval from C&GS

cc Constantine Bodykevich, WRO, INAC fax to 867 979 6445 / 975 4560
 Community Technical Officer, C&GS - Baffin fax to 867 897 3633