

**ANNUAL REPORT  
FOR THE HAMLET OF QIKIQTARJUAQ, 2015**

---

**YEAR BEING REPORTED: 2015**

The following information is compiled pursuant to the requirements of **Part B, Item 1** of Water License # 3 BM -QIK 1419 issued to the Hamlet of Qikiqtarjuaq.

- i) - iii) tabular summaries of all data generated under the “Monitoring Program”; monthly and annual quantities in cubic metres of freshwater obtained from all sources; monthly and annual quantities in cubic metres of each and all wastes discharged;

Attached are quantities of water used as reported in our On Tap Water Delivery System and the estimated discharge of sewage waste based on quantities used.

<b>Month Reported</b>	<b>Quantity of Water Obtained from all sources (litres)</b>	<b>Quantity of Sewage Waste Discharged (Estimated)</b>
<b>January 2015</b>	1,811,339.30	Same
<b>February 2015</b>	1,622,934.80	Same
<b>March 2015</b>	1,768,755.00	Same
<b>April 2015</b>	1,721,178.90	Same
<b>May 2015</b>	1,683,524.70	Same
<b>June 2015</b>	1,681,311.00	Same
<b>July 2015</b>	1,692,470.40	Same
<b>August 2015</b>	1,671,579.50	Same
<b>September 2015</b>	1,705,839.30	Same
<b>October 2015</b>	1,776,307.10	Same
<b>November 2015</b>	1,809,459.90	Same
<b>December 2015</b>	1,819,155.00	Same
<b>ANNUAL TOTAL</b>	<b>20,763,385.00</b>	<b>20,763,385.00</b>

Note: The water consumption volume is considered equal to the discharge volume for each month because there is no meter at the end of the discharge pipe.

## ANNUAL REPORT FOR THE HAMLET OF QIKIQTARJUAQ, 2015

---

- iv. a summary of modifications and/or major maintenance work carried out on the Water Supply and Waste Disposal Facilities, including all associated structures and facilities;
- 
- Land Farm project is halfway constructed. Recently department of housing did a feasibility study on the current status and they are looking for an option to immediately complete this project.
- Water Reservoir was drained out last summer and inspected the liner at the bed. Hamlet tried to install an elbow at the intake pipe but failed. They will be attempting this summer again.
- v. a list of unauthorized discharges and summary of follow-up action taken;
- 
- No spill occurred in the Environmental Facilities during the reporting report.
- vi. a summary of any abandonment and restoration work completed during the year and an outline of any work anticipated for the next year;
- 
- An elbow will be installed at the end of the intake pipe this summer to draw fresh water from the reservoir.
- vii. a summary of any studies requested by the Board that relate to waste disposal, water use or reclamation, and a brief description of any future studies planned;
- 
- The possibility of leakage through the liner of the Water Reservoir was checked and found that water does not pass through the liner. The water reservoir is safe. However, second inspection is scheduled this summer.
- viii. any other details on water use or waste disposal requested by the Board by November 1st of the year being reported; and
- 
- Hamlet inspected the status of the liner. Hamlet also did the erosion protection of the front bank of the stream which is the hamlet's potable water source.
- ix. updates or revisions to the approved Operation and Maintenance Plans.
- 
- The O&M manuals are available. The Hamlet is operating Water Truck fill station, Sewage Lagoon and Waste site following the guidelines of the existing O&M manuals.
-

**ANNUAL REPORT  
FOR THE HAMLET OF QIKQTARJUQ, 2015**

---

**ADDITIONAL INFORMATION THAT THE LICENSEE DEEMS USEFUL:**

---

Department of Housing is looking for additional funding to complete the construction of the land farm. Once construction is complete, the O&M manual will be available.

---

**FOLLOW-UP REGARDING INSPECTION/COMPLIANCE CONCERNS:**

---

Hamlet is working with CGS for INAC inspection concerns and Water Licence Compliancy. Hamlet is keeping close contact with the newly formed Water licence Compliance Group (WLCG) and receiving direction to move forward. They are engaged in extended sampling program as established by CGS.

---

The Lab Test Results for 2015 are submitted in a separate document.