

C.O.C.: DW 121569

REPORT No: 23-032704 - Rev. 0

Report To:

Municipality of Qikiqtarjuaq
P.O. Box 4
Qikiqtarjuaq, NU

CADUCEON Environmental Laboratories

2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Samuel Nuqingaq

DATE RECEIVED: 2023-Nov-21
DATE REPORTED: 2023-Dec-06
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT:
P.O. NUMBER:

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
Anions (Liquid)	2	OTTAWA	PCURIEL	2023-Nov-21	A-IC-01	SM 4110B
Colour (Liquid)	2	OTTAWA	AWILSON	2023-Nov-22	A-COL-01	SM 2120C
Cond/pH/Alk Auto (Liquid)	2	OTTAWA	SBOUDREAU	2023-Nov-21	COND-02/PH-02/A LK-02	SM 2510B/4500H/ 2320B
Cyanide Total (Liquid)	2	KINGSTON	JMACINNES	2023-Nov-27	CN-001	SM 4500-CN-E
DOC/DIC (Liquid)	2	OTTAWA	VKASYAN	2023-Nov-23	C-OC-01	EPA 415.2
HAA's (Liquid) (Subcontracted)	2	SGS_LAKEFIELD	SISLAM	2023-Nov-29	Subcontracted	Subcontracted
ICP/MS Total (Liquid)	2	OTTAWA	AOZKAYMAK	2023-Nov-23	D-ICPMS-01	EPA 6020
ICP/MS (Liquid)	2	OTTAWA	AOZKAYMAK	2023-Nov-23	D-ICPMS-01	EPA 200.8
ICP/OES Total (Liquid)	2	OTTAWA	NHOGAN	2023-Nov-24	D-ICP-01	SM 3120B
ICP/OES (Liquid)	2	OTTAWA	NHOGAN	2023-Nov-24	D-ICP-01	SM 3120B
Mercury (Liquid)	2	OTTAWA	TBENNETT	2023-Nov-22	D-HG-02	SM 3112B
Mercury (Liquid) Lab Filtered	2	OTTAWA	TBENNETT	2023-Nov-22	D-HG-02	SM 3112B
Ammonia (Liquid)	2	KINGSTON	KDIBBITS	2023-Nov-29	NH3-001	SM 4500NH3
PHC F1 (Liquid)	2	RICHMOND_HILL	FLENA	2023-Nov-24	C-VPHW-01	MECP E3421
PHC F2-4 (Liquid)	2	KINGSTON	STHOMPSON	2023-Nov-25	PHC-W-001	MECP E3421
SVOC - Semi-Volatiles (Liquid)	2	KINGSTON	EASIEDU	2023-Nov-22	NAB-W-001	EPA 8270D
Total Organic Carbon (TOC)	2	OTTAWA	VKASYAN	2023-Nov-23	C-OC-01	EPA 415.2
TSS (Liquid)	2	KINGSTON	KKHUTSYEVA	2023-Nov-24	TSS-001	SM 2540D
Turbidity (Liquid)	2	OTTAWA	AWILSON	2023-Nov-22	A-TURB-01	SM 2130B
UV Trans. (Subcontracted)	2	TESTMARK	SISLAM	2023-Nov-22		Subcontracted
VOC-Volatiles Full (Water)	2	RICHMOND_HILL	FLENA	2023-Nov-24	C-VOC-02	EPA 8260

µg/g = micrograms per gram (parts per million) and is equal to mg/Kg

F1 C6-C10 hydrocarbons in µg/g, (F1-btex if requested)

F2 C10-C16 hydrocarbons in µg/g, (F2-naph if requested)

F3 C16-C34 hydrocarbons in µg/g, (F3-pah if requested)

F4 C34-C50 hydrocarbons in µg/g

This method complies with the Reference Method for the CWS PHC and is validated for use in the laboratory.

Any deviations from the method are noted and reported for any particular sample.

nC6 and nC10 response factor is within 30% of response factor for toluene:

nC10, nC16 and nC34 response factors within 10% of each other:

C50 response factors within 70% of nC10+nC16+nC34 average:

Linearity is within 15%:

All results expressed on a dry weight basis.

Unless otherwise noted all chromatograms returned to baseline by the retention time of nC50.

Unless otherwise noted all extraction, analysis, QC requirements and limits for holding time were met.

If analyzed for F4 and F4G they are not to be summed but the greater of the two numbers are to be used in application to the CWS PHC

QC will be made available upon request.


Shelly Lozo

Microbiology Supervisor

CADUCEON Environmental Laboratories Certificate of Analysis


Final Report

REPORT No: 23-032704 - Rev. 0

R.L. = Reporting Limit

NC = Not Calculated

Test methods may be modified from specified reference method unless indicated by an *



Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report

REPORT No: 23-032704 - Rev. 0

					Client I.D.	Truck #97-109	Truck #97-109 - Total Metals	Truck #97-110	Truck #97-110 - Total Metals
					Sample I.D.	23-032704-1	23-032704-2	23-032704-3	23-032704-4
					Date Collected	2023-Nov-16	2023-Nov-16	2023-Nov-16	2023-Nov-16
Parameter	Units	R.L.	Limits	DWG		-	-	-	-
Alkalinity(CaCO3) to pH4.5	mg/L	5				<5		<5	
TDS (Calc. from Cond.)	mg/L	3				11		9	
Conductivity @25°C	uS/cm	1				22		18	
pH @25°C	pH units	-				6.16		6.18	
Colour	TCU	2				<2		<2	
Turbidity	NTU	0.1				1.1		1.2	
Fluoride	mg/L	0.1	1.5	MAC		<0.1		<0.1	
Chloride	mg/L	0.5				4.2		3.5	
Nitrate (N)	mg/L	0.05	10.0	MAC		0.08		0.09	
Sulphate	mg/L	1				<1		<1	
Total Suspended Solids	mg/L	3				<3		<3	
Ammonia (N)-Total (NH3+NH4)	mg/L	0.05				<0.05		<0.05	
Dissolved Organic Carbon	mg/L	0.2				1.2		1.0	
Total Organic Carbon	mg/L	0.2				1.2		1.0	
Cyanide (Total)	mg/L	0.005	0.2	MAC		<0.005		<0.005	
Hardness (as CaCO3)	mg/L as CaCO3	0.02				1.82		1.59	
Aluminum	mg/L	0.01				0.08		0.08	
Barium	mg/L	0.001	1	MAC		0.001		0.001	
Boron	mg/L	0.005	5	MAC		<0.005		<0.005	
Calcium	mg/L	0.02				0.30		0.24	
Copper	mg/L	0.002				0.009		0.008	


Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report

REPORT No: 23-032704 - Rev. 0

					Client I.D.	Truck #97-109	Truck #97-109 - Total Metals	Truck #97-110	Truck #97-110 - Total Metals
					Sample I.D.	23-032704-1	23-032704-2	23-032704-3	23-032704-4
					Date Collected	2023-Nov-16	2023-Nov-16	2023-Nov-16	2023-Nov-16
Parameter	Units	R.L.	Limits	DWG		-	-	-	-
Iron	mg/L	0.005				0.061		0.054	
Manganese	mg/L	0.001				0.002		0.002	
Potassium	mg/L	0.1				0.2		0.1	
Sodium	mg/L	0.2	20	MAC		3.8		2.7	
Zinc	mg/L	0.005				0.010		0.013	
Aluminum (Total)	mg/L	0.01					0.04		0.04
Barium (Total)	mg/L	0.001					0.001		0.001
Boron (Total)	mg/L	0.005					<0.005		<0.005
Calcium (Total)	mg/L	0.02					0.30		0.33
Copper (Total)	mg/L	0.002					0.026		0.005
Iron (Total)	mg/L	0.005					0.070		0.034
Manganese (Total)	mg/L	0.001					0.002		0.001
Potassium (Total)	mg/L	0.1					0.2		0.2
Sodium (Total)	mg/L	0.2					3.5		2.9
Zinc (Total)	mg/L	0.005					0.012		0.006
Arsenic	mg/L	0.0001	0.01	MAC		<0.0001		<0.0001	
Cadmium	mg/L	0.000015	0.005	MAC		<0.000015		<0.000015	
Chromium	mg/L	0.001	0.05	MAC		<0.0010		<0.0010	
Lead	mg/L	0.00002	0.010	MAC		0.00028		0.00049	
Selenium	mg/L	0.001	0.05	MAC		<0.001		<0.001	
Uranium	mg/L	0.00005	0.02	MAC		<0.00005		<0.00005	


Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report

REPORT No: 23-032704 - Rev. 0

					Client I.D.	Truck #97-109	Truck #97-109 - Total Metals	Truck #97-110	Truck #97-110 - Total Metals
					Sample I.D.	23-032704-1	23-032704-2	23-032704-3	23-032704-4
					Date Collected	2023-Nov-16	2023-Nov-16	2023-Nov-16	2023-Nov-16
					DWG	-	-	-	-
Parameter	Units	R.L.	Limits						
Arsenic (Total)	mg/L	0.0001					<0.0001		<0.0001
Cadmium (Total)	mg/L	0.000015					<0.000015		<0.000015
Chromium (Total)	mg/L	0.001					<0.001		<0.001
Lead (Total)	mg/L	0.00002					0.00108		0.00014
Selenium (Total)	mg/L	0.001					<0.001		<0.001
Uranium (Total)	mg/L	0.00005					<0.00005		<0.00005
Mercury	mg/L	0.00002	0.001	MAC			<0.00002		<0.00002
Mercury (Filtered)	mg/L	0.00002	0.001	MAC		<0.00002		<0.00002	


Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report

REPORT No: 23-032704 - Rev. 0

					Client I.D.	
					Truck #97-109	Truck #97-110
					Sample I.D.	
					23-032704-1	23-032704-3
					Date Collected	
					2023-Nov-16	2023-Nov-16
Parameter	Units	R.L.	Limits	DWG	-	-
Benzene	µg/L	0.5	1	MAC	<0.5	<0.5
Bromodichloromethane	µg/L	2			<2	<2
Bromoform	µg/L	5			<5	<5
Chloroform	µg/L	1			2	<1
Dibromochloromethane	µg/L	2			<2	<2
Ethylbenzene	µg/L	0.5	140	MAC	<0.5	<0.5
Total Trihalomethanes	µg/L	6	100	MAC	<6	<6
Toluene	µg/L	0.5	60	MAC	<0.5	<0.5
Xylene, m,p-	µg/L	1			<1	<1
Xylene, m,p,o-	µg/L	1.1	90	MAC	<1.1	<1.1
Xylene, o-	µg/L	0.5			<0.5	<0.5
PHC F1 (C6-C10)	µg/L	25			<25	<25
PHC F2 (>C10-C16)	µg/L	50			<50	<50
PHC F3 (>C16-C34)	µg/L	400			<400	<400
PHC F4 (>C34-C50)	µg/L	400			<400	<400


Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON Environmental Laboratories Certificate of Analysis

Final Report

REPORT No: 23-032704 - Rev. 0

Parameter	Units	R.L.	Limits	DWG	Client I.D.	
					Truck #97-109	Truck #97-110
					Sample I.D.	
					Date Collected	
					23-032704-1	23-032704-3
					2023-Nov-16	2023-Nov-16
					-	-
Acenaphthene	µg/L	0.05			<0.05	<0.05
Acenaphthylene	µg/L	0.05			<0.05	<0.05
Anthracene	µg/L	0.05			<0.05	<0.05
Benzo[a]anthracene	µg/L	0.05			0.31	<0.05
Benzo(a)pyrene	µg/L	0.01	0.01	MAC	0.21	<0.01
Benzo(b)fluoranthene	µg/L	0.05			0.30	<0.05
Benzo(b+k)fluoranthene	µg/L	0.1			0.6	<0.1
Benzo(g,h,i)perylene	µg/L	0.05			0.33	<0.05
Benzo(k)fluoranthene	µg/L	0.05			0.32	<0.05
Chrysene	µg/L	0.05			0.32	<0.05
Dibenzo(a,h)anthracene	µg/L	0.05			0.31	<0.05
Fluoranthene	µg/L	0.05			0.19	<0.05
Fluorene	µg/L	0.05			<0.05	<0.05
Indeno(1,2,3,-cd)Pyrene	µg/L	0.05			0.32	<0.05
Methylnaphthalene,1-	µg/L	0.05			<0.05	<0.05
Methylnaphthalene,2-(1-)	µg/L	1			<1	<1
Methylnaphthalene,2-	µg/L	0.05			<0.05	<0.05
Naphthalene	µg/L	0.05			0.12	0.08
Phenanthrene	µg/L	0.05			<0.05	<0.05
Pyrene	µg/L	0.05			0.18	<0.05
Total PAH	µg/L	0.1			3.0	0.1

Shelly Lozo
Shelly Lozo

Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

Subcontracted Analyses

Parameter	Units	R.L.	Limits	Client I.D.	Truck #97-109	Truck #97-110
				Sample I.D.	23-032704-1	23-032704-3
				Date Collected	2023-Nov-16	2023-Nov-16
				DWG	-	-
Total Haloacetic Acids (HAA5)	µg/L	5.3	80	MAC	<5.3	<5.3
(Mono) Chloroacetic Acid	µg/L	4.7			<4.7	<4.7
Bromoacetic Acid	µg/L	2.9			<2.9	<2.9
Dichloroacetic Acid	µg/L	2.6			4.0	2.6
Dibromoacetic Acid	µg/L	2.0			<2.0	<2.0
Trichloroacetic Acid	µg/L	5.3			<5.3	<5.3
UV Transmittance	%	-			98.4	98.4

DWG - Drinking Water Guidelines

ODWS - Ontario Drinking Water Standards

AO - Aesthetic Objectives

IMAC - Interim Maximum Acceptable Concentration

MAC - Maximum Acceptable Concentration

ODWO - D-5-5 Objective

OG - Operational Guidelines

WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances**Maximum Acceptable Concentration****Truck #97-109****Found Value****Limit**

Benzo(a)pyrene

0.21

0.01



Shelly Lozo

Microbiology Supervisor