


Volume 3 - Sewage Treatment and Future System Expansion

Final Report - Revision 1

May, 1999



INTERNAL	
PC	JP
LA	
OM	
TA	
BS	
ST	
ED	
CEO	
BRD	
EXT.	

Volume 3 - Sewage Treatment and Future System Expansion

Resolute Bay, NT

Public Works & Services
Government of the Northwest Territories

98-5748-01-01

Submitted by
**Dillon Consulting
Limited**

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 INTRODUCTION	1
1.1 General	1
1.2 Scope of work	3
2.0 EXISTING DATA REVIEW	4
2.1 Community Data	4
2.2 Population Projection	4
2.3 System Description	5
3.0 REGULATORY COMPLIANCE OF THE UTILIDOR SYSTEM	10
3.1 The Public Health Act	10
4.0 MODELLING	11
4.1 Water Distribution Network	11
4.1.1 Introduction	11
4.1.2 Existing Conditions	11
4.1.3 Future Conditions	11
4.1.4 Hydraulic Model (EPANET)	11
4.2 Sanitary Sewer System	15
4.2.1 Introduction	15
4.2.2 Existing Conditions	15
4.2.3 Future Conditions	15
4.2.4 Capacity Utilization Analysis	16
5.0 IMPACT STUDY	19
5.1 Introduction	19
5.2 Potential Impacts of Discharging Sewage Waste to the Marine Environment	19
5.3 Existing Environment	21
5.3.1 Physical Environment	22
5.3.2 Water Quality	22
5.3.3 Phytoplankton	24
5.3.4 Zooplankton	25
5.3.5 Benthic Invertebrates	25
5.3.6 Fisheries and Marine Mammals	26

TABLE OF CONTENTS (Continued)

	<u>Page No.</u>
5.4 Public and Regulatory Agency Consultation	26
6.0 REMEDIAL SYSTEM NEEDS	29
6.1 Water Mains	29
6.2 Sewage Discharge	30
REFERENCES	32

APPENDICES

Appendix A - Pipe Network Model Results

Appendix B - Cost Estimate Data

Appendix C - Impact Study - Community Consultation

1.0 INTRODUCTION

1.1 General

The Hamlet of Resolute Bay is serviced by a water supply system that uses a utilidor system to deliver water to houses and commercial users, and collect the sewage from these users. The water supply and sewage disposal systems are comprised of several components, namely:

- The raw water source known as Char Lake
- The Char Lake pumphouse
- The water supply line from the Char Lake pumphouse to the Water Treatment Plant (WTP)
- The utilidor system that is comprised of the water distribution system and the sewage collection system
- The Sewage Treatment Plant
- The sewage outfall.


The above components are shown in **Figure 1.1** and will be described in more detail in the body of the report. Previous studies (UMA 1996) assessed each of the system components for condition, expected remaining life and required remedial action to be undertaken to extend the current facility life to 20 years. The results of this study indicated that in general the facility components are well maintained, and will meet the Hamlet's requirements for the next 20 years. The exception is the utilidor system that has experienced a number of failures over the past 5 to 7 years. The increase in failures is of significant concern to the utilidor maintainers and the Hamlet Council.

The GNWT, Department of Municipal and Community Affairs (MACA) owns the assets of the water and sewer systems. The Department of Public Works & Services (DPW&S) completes the operation and maintenance on the systems. The GNWT has identified the transfer of the community assets to the communities as a priority. In this vein, the GNWT intends to transfer the water and sewer system to the Hamlet of Resolute Bay. Prior to the transfer of the facilities, the systems are to be upgraded to meet the requirements of the Hamlet for the 20 year design life. Dillon was retained to review the system in this light, and develop an upgrading plan for the sewage and water systems assuming that the piped distribution system will be maintained in the community. Three reports were produced, namely;

Volume 1 - Utilidor Upgrade

Volume 2 - Water System Building Assessment

Volume 3 - Sewage treatment and Future System Expansion



1.2 Scope of work

The scope of work for this volume relates to the sewage discharge and the potential for the future expansion of the utilidor system.. A summary of the scope of work is described below:

- Complete a review of the existing documentation.
- Complete a site investigation to update the previous work.
- Complete a community consultation to determine the current perception of the impacts to the environment created by the sewage discharge.
- Debrief the system operator on his concerns, and review the system operator's records of the system.
- Complete a hydraulic model of the system to determine the requirement for system upgrades as the community grows.

2.0 EXISTING DATA REVIEW

2.1 Community Data

Resolute Bay is located on the south coast of Cornwallis Island and is about 1,660 km north east of Yellowknife and 1,550 Km north west of Iqaluit. The community is located at latitude N74-43-01 and longitude W94-58-10 (NAV CANADA). The average daily minimum and maximum temperatures for July and January are 1.3°C & 6.8°C and -35.8°C & -28.5°C respectively. An average of 50.4 mm of rainfall and 97.3 cm of snowfall for a total of 139.6 mm of precipitation is received each year (Environment Canada).

The community was founded in the early 1970's when it was decided to relocate the existing community from the beach area near the existing south camp to the present location. The development of the community and the initial infrastructure was based on a projected population of some 1,500 people. The expected growth was not realized and the current population is slightly less than 200 persons.

2.2 Population Projection

To be able to develop the system requirements it is necessary to determine the design flow rates for the piped system. The flow rates are based on the population of the community and the expected per capita consumption. The historic populations and per capita water use rates are based on the records found at the Hamlet's office, MACA's records and in previous reports (UMA, 1993, 1996). The population projections are based on the data supplied by the Bureau of Statistics. These are as follows:

Table 2.2.1
Population Projects from the Bureau of Statistics

Year	Population
1991	171
1992	174
1993	178
1994	181
1995	184
1996	197
2001	224
2006	238

The consumption is based on the formula developed by MACA (MACA, 1986) and on the historic consumption of the community. The formulae for predicting water consumption of communities with piped water distribution and populations less than 2,000 people is:

$$\text{Daily Consumption} = 225 * (1 + 0.00023 * (\text{Population})) * \text{Population}$$

Based on this formula and the population projections shown in Table 2.2.1, the projected annual consumption for the Hamlet of Resolute Bay for the next 20 years can be predicted. The system uses bleed water from the watermains to provide freeze protection to the sewer mains. The bleed water is not metered. The total water pumped into the system is metered, and the individual consumers are metered. The resultant of the water supplied to the system and the metered volume of the consumers is the total of the system losses. The total system losses include the bleed water, losses due to watermain breaks, and water losses within the system. Prior to 1996, this value was fairly constant at approximately 38,000 m³ per year. As a result of increased problems with the system the amount of bleed water has increased in 1996 to 52,000 m³ and again in 1997 to 56,000 m³. At the time of reporting, the Hamlet was projecting an annual total consumption for 1998/99 of 55,000 m³ of which 45,000 m³ would be the bleeders and other system losses. For the purposes of water consumption projections the value of 45,000 m³ of bleed water and other system losses is used. The projected annual consumption is shown in Table 2.2.2.

2.3 System Description


The following is a description of the complete water and sewage system from the up gradient intake to the down gradient sewer outfall. **Figure 2.1** illustrates this system in a schematic diagram.

Char Lake

- A ductile iron gravity intake line extends from Char Lake to wet wells in the Char Lake Pump House.
- Char Lake Pump House tempers the water using a hot water injection into the wet wells. Diesel fired boilers are used to heat the injection water. The tempered water is pumped through the 150 mm heat traced and insulated HDPE Water Supply Main to the Water Storage Reservoir at the Water Treatment Plant (WTP).
- Two jockey pumps and two demand pumps are operated in the Char Lake Pump House. Typically one jockey pump operates 24 hours a day, with one demand pump coming on for less than one hour per day. The second jockey pump and second demand pump are on-line standby pumps and are brought on-line automatically if the first pump fails.
- The Char Lake Pump House pumps are controlled from a level controller located in the Water Storage Reservoir. The controller has a high level alarm, jockey pump off, jockey pump on, demand pump off, demand pump on, and low level alarm control levels.
- A standby diesel engine generator is situated in the Char Lake Pump House in case of loss of power to the Pump House.

Table 2.2.2
Population and Consumption Projections

Design Year	Year	Population	Growth Rate	Consumption lcd	Consumption Annual (historic)	Consumption Annual (MACA)	Bleeders Annual	Total Volume (Historic)	Total Volume (MACA)	Daily Average (Historic)	Daily Average (MACA)
	1991	171		145	9,050,175		38,400,000	47,450,175		130,000	
	1992	174	0.0175	145	9,208,950		38,400,000	47,608,950		130,435	
	1993	178	0.0230	145	9,420,650		38,400,000	47,820,650		131,015	
	1994	181	0.0169	145	9,579,425		38,400,000	47,979,425		131,450	
	1995	184	0.0166	145	9,738,200		38,400,000	48,138,200		131,885	
	1996	197	0.0707	145	10,426,225	16,911,678	51,868,684	62,294,909	68,780,362	142,106	188,439
	1997	205	0.0406	145	10,849,625	17,629,425	55,801,509	66,651,134	73,430,934	152,881	201,181
	1998	209	0.0195	145	11,061,325	17,989,204	45,000,000	56,061,325	62,989,204	123,288	172,573
0	1999	214	0.0239	145	11,325,950	18,439,779	45,000,000	56,325,950	63,439,779	123,288	173,808
1	2000	221	0.0327	145	11,696,425	19,072,170	45,000,000	56,696,425	64,072,170	123,288	175,540
2	2001	224	0.0136	145	11,855,200	19,343,762	45,000,000	56,855,200	64,343,762	123,288	176,284
3	2002	227	0.0134	145	12,013,975	19,615,693	45,000,000	57,013,975	64,615,693	123,288	177,029
4	2003	228	0.0044	145	12,066,900	19,706,413	45,000,000	57,066,900	64,706,413	123,288	177,278
5	2004	233	0.0219	145	12,331,525	20,160,576	45,000,000	57,331,525	65,160,576	123,288	178,522
6	2005	237	0.0172	145	12,543,225	20,524,587	45,000,000	57,543,225	65,524,587	123,288	179,519
7	2006	238	0.0042	145	12,596,150	20,615,684	45,000,000	57,596,150	65,615,684	123,288	179,769
8	2007	239	0.0042	145	12,649,298	20,707,204	45,000,000	57,649,298	65,707,204	123,288	180,020
9	2008	240	0.0042	145	12,702,671	20,799,148	45,000,000	57,702,671	65,799,148	123,288	180,272
10	2009	241	0.0042	145	12,755,249	20,891,119	45,000,000	57,755,249	65,891,119	123,288	180,523
11	2010	242	0.0042	145	12,810,093	20,984,318	45,000,000	57,810,093	65,984,318	123,288	180,779
12	2011	243	0.0042	145	12,864,144	21,077,548	45,000,000	57,864,144	66,077,548	123,288	181,034
13	2012	244	0.0042	145	12,918,423	21,171,212	45,000,000	57,918,423	66,171,212	123,288	181,291
14	2013	245	0.0042	145	12,972,931	21,265,310	45,000,000	57,972,931	66,265,310	123,288	181,549
15	2014	246	0.0042	145	13,027,669	21,359,846	45,000,000	58,027,669	66,359,846	123,288	181,808
16	2015	247	0.0042	145	13,082,638	21,454,821	45,000,000	58,082,638	66,454,821	123,288	182,068
17	2016	248	0.0042	145	13,137,839	21,550,239	45,000,000	58,137,839	66,550,239	123,288	182,329
18	2017	249	0.0042	145	13,193,273	21,646,100	45,000,000	58,193,273	66,646,100	123,288	182,592
19	2018	250	0.0042	145	13,248,941	21,742,407	45,000,000	58,248,941	66,742,407	123,288	182,856
20	2019	251	0.0042	145	13,304,843	21,839,163	45,000,000	58,304,843	66,839,163	123,288	183,121



LEGEND

—>>> WATERMAIN BLEEDERS

—>>> WATER

—>>> SEWER

DILLON
CONSULTING

PROJECT	HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE	PROJECT NUMBER 98-5748
TITLE	EXISTING SYSTEM SCHEMATIC	DATE OCT 98
		FIGURE NUMBER FIG 2.1

Water Treatment Plant

- The Water Storage Reservoir is a steel 530 m³ vertical steel tank constructed above grade. The tank is insulated and is freeze protected by the use of hot water injection.
- The Water Treatment Plant uses diesel fired boilers to provide tempering water for the Water Storage Reservoir hot water injection.
- The distribution water to the community is chlorinated using calcium hypochloride through injection pumps.
- The WTP uses pumps to provide distribution flow. The pressure is maintained at approximately 170 kPa (25 psi) at the WTP (October 1998 reading), and approximately 600 kPa (85 to 90 psi) at the low end of distribution system. The difference between the discharge pressure and the low end main pressure is the result of the static head difference in the mains due to elevation changes. The supply pump runs continuously at a constant rate of 1,700 rpm. The flow to the distribution mains is not regulated. Whatever water is not used within the distribution system is returned to the reservoir through the 150 mm return line.

Utilidor

- The distribution system is a looped HDPE insulated pipeline. The pipes are mostly 200 mm in diameter with two sections of 150 mm supply line and a 150 mm return line.
- Water is supplied to users (approximately 60 buildings) through a 20 mm copper heat traced (Stage 1A only) and insulated services. A return service is also installed from each building to the water main. Flow is moved continuously through the supply and return services by a small recirculation pump (1/4 h.p.) located in each building.
- The return water is directed back to the Water Storage Reservoir.
- The building sewage is collected using 100 mm insulated HDPE sewers to the sewer mains.
- The water and sewer services are in a common insulated jacket. The latent heat from the recirculation of the water services is used to freeze-protect the sewer service.
- Bleed water from the water mains is also used to provide freeze protection to the sewer mains during power failures when the water service recirculation pump is not operating.
- The sewer mains are gravity run 150 mm insulated HDPE. These are installed in the same trench as the watermain.
- The sewer mains and water mains are accessed through common concrete cast in place Access Vaults (AVs). The AVs contain all valves, hydrants, pipe connections and sewer clean outs.
- The sewer main is freeze-protected by the use of bleed water from the watermain to the sewermain. The bleeders are unmetered and located in the AVs.

Sewage Discharge

- The sewer mains join at the low end of the community and flow by gravity to a comminutor building.
- The sewage is macerated in this facility and discharged by gravity through an outfall pipe to the

shore line of the marine environment.

There have been several changes to the system since the original design. Some of these changes have been incorporated into the O&M manuals. The changes recorded during the site investigation completed on October 20 to 22, 1998 are from the discussions with the DPW Maintainer, Mr. Neil MacDonald, the Hamlet Administration, Mr. Dan Leman & Mr. Ralph, and from the existing documentation are as follows:

- A heat trace has been installed in the Water Supply Line from the Char Lake Pump House to the WTP in 1993. Five access vaults have been installed along this line as well. (Record Drawings)
- Two jockey pumps have been installed in the Char Lake Pump House.
- The utilidor heat trace system was abandoned in 1984 due to corrosion problems. (UMA, 1996)
- All electrical devices and service were removed from the Access Vaults in 1998. This includes the sump pumps, heat trace, and AV heaters. (N. Macdonald)
- The line to Block 1 is abandoned due to a freeze-up prior to 1986. The Health Centre water service currently uses the abandoned water main as a carrier pipe. The other buildings in this area are connected to the water and sewer mains between AV2 & 3. (N. MacDonald) The sewer service to the Health Centre is still in operation (D. Leman).
- The Hydrant in AV 20 was removed prior to 1986.
- AV 15 was never installed during the original construction. (N. MacDonald)
- A new hydrant was installed in 1998 in AV 13, (N. MacDonald)
- The valves in AV3 were replaced in 1998. These are the valves that were indicated to leak in the UMA 1996 report, but were incorrectly identified as AV2 valves in the UMA report (N. MacDonald).
- A new valve was installed in AV30 in 1998. This allows the section of main between AV21 and AV30 to be shut off. (N. MacDonald)
- The ventilation systems for the WTP and Char lake Pump House have been disabled and are blocked up in the winter. Combustion air for the facility burners is supplied through building envelope infiltration. It is reported by the DPW Maintainer that the buildings are very leaky and have poor insulation.

With respect to the utilidor system, there are no known changes made from the original construction other than the changes noted above. The complete system description and components is found in three sets of O&M Manuals. Copies of these manuals are stored in the community, DPW&S Iqaluit, and DPW&S Yellowknife.

3.0 REGULATORY COMPLIANCE OF THE UTILIDOR SYSTEM

3.1 The Public Health Act

The NWT Public Health Act (PHA) regulates the supply of potable water to consumers, and the methods for the collection of waste in the NWT. The applicable sections of the PHA are the "Consolidation of Public Water Supply Regulations, P-23" (PHA P - 23) and the "Consolidation of Public Sewerage Systems Regulations" (PHA P - 22). No other sections of the Public Health Act would relate directly to the water supply and sewage collection system. With respect to the utilidor system the requirements are set out in the in Part III of the PHA-P23.

The utilidor meets the requires of Part III of PHA-P23 except for the requirements of section 20.9 which states:

"Where water and sewer pipes are contained in a utilidor, there shall be adequate provision for drainage in order to prevent contamination of the water supply during repairs to the system."

The AV's contain both water and sewer pipes. The sewer clean out covers have been removed to allow infiltration water to drain out of the AVs. This is an annual problem, as each spring run off water enters the AV and must be removed. This occurs from about June to October (N. MacDonald) and then the remaining water is pumped out of the AVs. The clean out cover remains open year round. This creates concern that in the event of a water main break a negative pressure in the watermain can be created within an upstream AV from a syphoning effect of the down stream main. If the watermain is not completely sealed, or during the repair of the water main, there is the possibility of cross contamination from the open sewer clean out. This is greatly reduced if the clean out is closed and sealed prior to the start of any maintenance on the water main system.

The PHA P - 22 has two requirements that are of issue for the utilidor system. The first is the same as described above. The second is the requirement for treatment for the sewage. The PHA P - 22 states in Part IV article 9:

"Sewage treatment systems shall be designed to provide for adequate protection of the receiving water considering the possible uses of the receiving water"

This issue does not particularly relate to the operation of the utilidor system, but is raised as the UMA, 1996 report indicates that the Public Health Department required that sewage treatment is needed to meet the requirements of the Department. Based on the above section of the act, which is the only section of the PHA that addresses sewage treatment, there appears to be no specific requirement for treatment other than to protect the receiving body of water.

4.0 MODELLING

4.1 Water Distribution Network

4.1.1 Introduction

This section summarizes the development of the water distribution analysis model for the existing system and the 5 year proposed residential development in Resolute Bay, NT. Results of the analysis and recommendations are included.

4.1.2 Existing Conditions

There is approximately 2,500 m of pipe in the water distribution system. All water mains are 200 mm HDPE pipe with the exception of three 150 mm sections. A constant pressure of 150 kPa (20 psi) is provided at the water treatment plant to the distribution system. There are 20 mm bleeds into the sanitary sewer in AV17, AV19, AV22, and AV25. The outflow through these bleeds is approximately 5.25 l/s each.

The water is constantly being recirculated within the system with the aid of a 150 mm return line to the water treatment plant.

4.1.3 Future Conditions

An area to the southwest of the current community is proposed for 37 new residential lots. This will require approximately 1,090 m of 200 mm additional water main. A commercial area to the northwest is proposed but not expected to be developed within the next 5 years and therefore not included in the scope of this project. The connections to the existing system will be made at AV17 and AV11.

4.1.4 Hydraulic Model (EPANET)

EPANET is a computer program that performs extended simulation of hydraulic and water quality behaviour within pressurized pipe networks. A network can consist of pipes, nodes, pumps, valves and storage tanks or reservoirs. EPANET tracks the flow of water in each pipe, the pressure at each node, and the height of water in each tank during a multi-time period simulation. EPANET Version 1.1e was developed by the Water Supply and Water Resources Division, National Risk Management Research Laboratory of the U.S. Environmental Protection Agency in Cincinnati, Ohio.

4.1.4.1 *Model Setup and Assumptions*

Since the network is relatively small, each pipe is modelled individually. Existing details such as slopes, diameters, elevations and the configuration were obtained from the as-built drawings obtained from PW&S. Elevations and slopes for the proposed development were interpreted from contour mapping. A schematic diagram is shown for existing conditions in **Figure 4.1** and for future conditions in **Figure 4.2**.

The Hazen-Williams head loss equation is used. ($h=fn(C,d,L,q)$)

The Hazen-Williams coefficient (C) for HDPE pipe is assumed to be 110.

The return line to the water treatment plant is modelled with a check valve to ensure one direction of flow. The node at the end of the return line is modelled as a reservoir with a constant elevation equal to the inflow elevation at the plant. The water reservoir is modelled with a constant head of 17.3 m to simulate the a constant pressure of 150 kPa (20 psi) leaving the plant.

Demands in Resolute Bay are based on an estimated number of units of 63 in the existing model and 113 for the future conditions, and 5 people per unit.

Unit consumption rates are as follows:


Average Day	225 Lpcd
Maximum Day	450 Lpcd
Peak Hour	900 Lpcd

Total water use in a community can be estimated as a function of residential water use(RWU) (MACA, 1986).

Total water use= $RWU*(1+(.00023*population))$ for a community of less than 1000 people.

Total water use is used in the model, residential and commercial flows are not distinguished.

The allocation of demands is based on the as-built drawings and approximated for the future development. For both existing and future conditions the following scenarios are modelled. Average day demand, maximum day demand, peak hour demands and average day demands plus fire flow at the worst location. The results of these runs is in appendix A.

EPANET Resolute Bay October 1998 *Existing* Conditions Schematic

Figure

4.1

EPANET Resolute Bay October 1998

Future Conditions Schematic




FIGURE 4.2

The fire flow rate based on MACA criteria is 3600 l/min for 2 hours during average day demands. Fire flows were simulated at the edges of the network and at the highest elevations to determine the worst case scenario and verify fire flows can be met. For existing conditions a fire at AV4 has the lowest pressures associated with it but the minimum pressure of 150 kPa can be easily maintained. For future conditions a fire at AV201 has the lowest pressures associated with it, but again the minimum of 150 kPa is maintained throughout the system.

The model was also run with pipe diameters of 150 mm instead of 200 mm to determine if the pipe size can be reduced, as the Community has not grown to the anticipated size. The model indicates that the 150 mm size is not sufficient to maintain the fire flow requirements.

4.2 Sanitary Sewer System

4.2.1 Introduction

This section summarizes the utilization of the existing sanitary sewer system, and estimates the peak hour flows for the 5 year proposed residential development in Resolute Bay, NT. Results of the analysis and recommendations are included.

4.2.2 Existing Conditions

There is approximately 2,500 m of sanitary sewer pipe. Most sewers are 150 mm HDPE pipe with five 200 mm sections at the downstream end of the system. There are 20 mm bleeds into the sanitary sewer in AV17, AV19, AV22, and AV25. The inflow through these bleeds is approximately 5.25 l/s each.

4.2.3 Future Conditions

An area to the southwest of the current community is proposed for 37 new residential lots. This will require approximately 768.5 m of 200 mm additional sewer pipe. A commercial area to the northwest is proposed but not expected to be developed within the next 5 years and therefore not included in the scope of this project. The connection to the existing system will be made at AV32. In addition to the existing 20 mm bleeds into the sanitary sewer, they were also added to AV201 and AV203 to prevent freezing.

4.2.4 Capacity Utilization Analysis

The full flow capacity of a circular pipe can be calculated using Manning's equation ($Q=1/n*(A*R^{2/3}*S^{1/2})$).

Model Setup and Assumptions

Each pipe with its details is identified in the spreadsheet shown for existing conditions in Table 4.1 and for the proposed development in Table 4.2. Existing details such as slopes, diameters, and the configuration were obtained from the as built drawings obtained from PW&S. Slopes for the proposed development were interpreted from contour mapping.

A schematic diagram is shown for existing conditions in **Figure 4.11** and for future conditions in **Figure 4.12**. The Manning's n coefficient for HDPE pipe is assumed to be 0.013.

Demands in Resolute Bay are based on an estimated number of units of 63 in the existing model and 113 for the future conditions, and 5 people per unit.

Unit consumption rates are as follows:

Average Day	225 Lpcd
Maximum Day	450 Lpcd
Peak Hour	900 Lpcd

Total water use in a community can be estimated as a function of residential water use(RWU) (MACA, 1986).

Total water use= $RWU*(1+(.00023*population))$ for a community of less than 1000 people.

It is assumed that waste water is equal to water use.

Results

Nearly all pipe in the system have adequate capacity to carry the peak hour flows. The exception is between AV11 and AV32 in the existing system due to a small slope, and between AV 11 and AV35 in the future system. The problem is solved by replacing the sewer pipes at these locations with 250 mm diameter pipe.

EPANET Resolute Bay October 1998 Existing Conditions Schematic




FIGURE 4 11

EPANET Resolute Bay October 1998

Future Conditions Schematic




FIGURE 4.12

5.0 IMPACT STUDY

5.1 Introduction

This section presents an overview of the Environmental Impact Study (EIS) of the Hamlet's current sewage discharge practices to Resolute Bay. This study was initiated as a follow-up to a previous water and sewer facilities study by UMA Engineering Ltd. (1996). That study identified potential concerns relating to the Hamlet's sewage discharge with respect to health issues and components of the Federal Fisheries Act relating to the discharge of a deleterious substance.

The UMA Report reviewed the correspondence from the Baffin Region Medical Health Officer, and indicated that the sewage disposal system does not comply with the Public Health Act because, *"the discharge of sewage is directly into the ocean without any prior treatment"*. However, the sewage does receive some treatment in the form of dilution from the bleed water.

There is uncertainty whether or not the sewage discharge complies with the Federal Fisheries Act as it relates to the introduction of a deleterious substance to a waterbody. It is not known if the current discharge would be considered deleterious, however, the UMA report states that the preparation of a DFO position brief on Resolute Bay is being considered. Currently, the status of the development of this position paper is unknown.

This EIS is based on existing environmental information for Resolute Bay, discussions with local residents, and Dillon's experience with similar studies (e.g. Repulse Bay Sewage Discharge -Preliminary Impact Assessment 1998). A major component of the EIS is a review of potential impacts of sewage discharge to the marine environment based on existing information. The EIS characterizes the existing environment of Resolute Bay including physical habitat characteristics, water quality, and marine flora and fauna. As part of this task data gaps or deficiencies have been identified to provide direction for a more detailed environmental assessment.

5.2 Potential Impacts of Discharging Sewage Waste to the Marine Environment

When wastewater is discharged to marine waters there are possible implications for the surrounding marine environment. The following discussion is intended to provide background regarding the potential environmental impacts of sewage to the marine environment.

The Department of Indian Affairs and Northern Development (DIAND, 1987), indicates that the principal components of sewage and the potential effects of these components to the receiving water body can be summarized in the following manner:

- *Organic Matter:* organic compound degradation may reduce the dissolved oxygen (DO) concentration of a receiving water body

- *Settleable Solids:* the benthic community structure may be altered if settling solids modify the particle size distribution of the sediments; localized anaerobic conditions may be a consequence of organic sediment decay
- *Inorganic Nutrients:* increased nitrogen and phosphorus levels could lead to increased primary production and hence decreased dissolved oxygen levels from microbial degradation of plant biomass at the sediments
- *Pathogenic Organisms:* the receiving water body may receive disease-causing bacteria and viruses
- *Residual Chlorine:* any chlorine remaining in the effluent that was used to reduce pathogenic micro-organism levels may be toxic to fish (not an issue in Resolute Bay)
- *Suspended Solids:* increased turbidity may alter fish migration patterns and reduce the amount of light available for photosynthesis
- *Floatables:* slowly degradable materials (i.e. fats, oils, plastic, rubber) may be aesthetically offensive if floating on the receiving water surface

Several of the impacts mentioned above are expanded upon in the following discussion as they relate to sewage discharge from coastal communities into the marine environment.

Of particular concern relating to impacts to the receiving environments is a potential decreased DO concentration due to the breakdown of organic matter, as well as the oxidation of hydrogen sulfide, ammonia, methane and iron compounds (DIAND, 1987). Anoxic conditions have been known to cause fish mortality in marine waters. Problems can arise where there is inadequate dilution or dispersion of an arctic communities sewage discharge which may result in anoxic conditions in the marine environment even when discharge is at relatively low volumes of sewage. DO reductions can also be exacerbated due to the long periods of ice-cover that effectively prevent atmospheric re-aeration. DIAND (1987) concluded that negligible decreases in dissolved oxygen levels could be expected in Arctic waters due to the small size of any one outfall, if dilutions greater than 100 to 200:1 are achieved.

The DO content immediately above the sediment and in its interstitial spaces may also decrease significantly due to organic compound decomposition. If the water at the level of the sediment were to become anoxic, this would have implications for the benthic and fish communities inhabiting this zone. In fact, Birtwell *et al.* (1983) suggested that the sediment chemical environment was a factor in the observed decrease in fish numbers near the sewage outfall of the Fraser River estuary. The accumulation of particulate organic matter may also have an effect on benthic invertebrates in the area and alter the relationships between benthic and pelagic trophic levels. Otte and Levings (1975) reported alterations

in the benthic community associated with a sewage outfall discharging to the mud flats of the Fraser River estuary increased. The authors observed an increase in the number of individuals, biomass, and species with increasing distance from the discharge. The extent of impacts to the benthos community is dependent on many factors such as: the degree of deposition; the presence or absence of toxic materials; the decomposition rate of the organic matter; and any change to the characteristics of the sediment (i.e. particle size) (DIAND, 1987).

In addition to organic loading and decreased dissolved oxygen levels being potential consequences of sewage discharge, nutrient levels may increase in the marine environment, resulting in the stimulation of primary production. Welch (1980) has suggested that enhanced primary production as a result of increased nutrient levels may lead to increases in zooplankton production and biomass. However, during the open-water season, Arctic marine waters are likely nitrogen-limited, in addition to being light-limited when the sea is covered with ice (DIAND, 1987). Thus, it is unlikely that nitrogen loading from the relatively small sewage outfalls in the north will result in stimulating primary production to any noticeable degree. Furthermore, because zooplankton and phytoplankton are moved continuously through well-circulated areas, any local changes in species composition would likely not significantly alter the structure of the community (DIAND, 1987).

The potential impact of micro-organisms may also be a concern when sewage is discharged into Arctic marine waters. Faecal coliforms, such as *E. coli*, may contaminate local invertebrate species and hence pose a risk to human health if any of these organisms are harvested for consumption by the residents. Shellfish are of particular concern because they are filter feeders and tend to concentrate bacteria in their tissues. This makes shellfish harvesting for human consumption a potential risk. Coliform bacteria have a much higher survival in the Arctic, due to the cold temperatures and because there is less ultra violet light to provide natural disinfection in the winter months (DIAND, 1987).

It is suggested by DIAND, 1987 that sewage discharge to the marine environment from small northern communities may have an insignificant environmental impact at a regional level. There could be minimal impact at the local level if sewage is discharged to a not well-mixed waters where the effluent is not diluted. Any effects to the receiving water from raw or partially treated sewage may be limited to localized benthic impacts (DIAND, 1987). In addition, sewage generation rates for Resolute Bay, both in the present and predicted for future years, are relatively small.

5.3 Existing Environment

Information regarding the existing environment of Resolute Bay is extremely limited, and is generally restricted to marine studies completed in the early 1970's (see summary by Buchanan and Ragnit 1978). Several of the studies provide descriptions and information regarding the general marine biological characteristics of the Resolute Bay and Wellington Channel. Study components include physical measurements, phytoplankton, zooplankton, benthos, and fish.

The following sections provide brief summaries for each of these components or areas:

5.3.1 Physical Environment

The physical data summarized in this section is related to tides and winds. Tidal influences experienced by Resolute Bay are considerably less than those observed in other areas in the eastern Arctic. Resolute Bay has a mean tidal variation of 1.3 m and a maximum tidal variation of 2.1 m (UMA 1996).

Wind speed and direction information is particularly noteworthy as they have a direct effect on physical oceanography of an area and can play an important role in the behaviour and distribution of any pollutant. Mean wind speeds for Resolute Bay are reported to be between 10.4 and 12.6 mph with a predominant wind direction from the northwest (Bitello 1973 cited in Buchanan and Ragnit 1978).

5.3.2 Water Quality

Water quality monitoring has been completed periodically for the sewage discharge to Resolute Bay. The water quality data includes a small sub-set of parameters from the final sewage discharge into Resolute Bay as well as from a station located 5-10 meters down current of the final discharge. Additional water quality information is available for comparative purposes for run-off from the solid waste disposal facility and for Char Lake waters.

Water quality data related to the sewage discharge are parameters pH, conductivity, total suspended solids, dissolved solids, biochemical oxygen demand (BOD), turbidity, total nitrogen, ammonia-N, nitrate, total phosphorus, and coliform bacteria. The effluent has not been characterized with respect to other parameters of potential concern such as metals or organics. Metal levels have been evaluated however, for the run-off from the solid waste disposal facility and for Char Lake.

The results of water quality monitoring completed between 1992 and 1997 for the Resolute Bay sewage discharge are presented in Table 5.1. Relevant guidelines and criteria have been included for comparison where possible. The solid waste site is not the subject of this assessment and is not discussed further in this report.

Generally, water quality is quite variable between sampling periods, although in all cases within relevant guidelines or criteria. The high variation is not surprising given that sampling likely took place over a wide range of physical conditions and as such may reflect tidal differences, wind- and wave-induced differences, etc.

Table 5.1

Water Quality Parameters at the sewage discharge to Resolute Bay and at a station located 5-10meters downcurrent of the discharge (data supplied by DIAND).

Parameter	Guideline/ Criteria	Sewage Discharge at End of Pipe (Stn 1571-3)					Resolute Bay ¹ (Stn 1571-4)	Water Licence Criteria
		July 17, 1992	June 28, 1993	Aug. 17, 1994	July 26, 1996	July 8, 1997	July 17, 1992	
CONVENTIONAL PARAMETERS								
pH	7.0-8.7 ²	7.2	7.24		7.82	8.00; 8.03	7.39	6 to 9
Conductivity (uS/cm)	-	450	304			201	420	
Total Suspended Solids (mg/L)	1203	27	19	<3	10	15; 15	26	80
Dissolved Solids (mg/L)	-			260				
BOD (mg/L)	1003				76	15; 18		120
Turbidity (NTU)	-		15	2.9				
NUTRIENTS								
Nitrates/ Nitrites (mg/L)	-	<0.01	1.26	2.21			<0.01	
Ammonia-N (mg/L)	124			1.41	0.721	0.561; 0.597		
Nitrate (mg/L)	-			2.2				
Total Phosphorus (mg/L)	-	1.3	1.115	0.219			0.691	
BACTERIA								
Total Coliform (CFU/dL)	-				300,000	2,600,000		
Faecal Coliform (CFU/dL)	-				110,000	210,000		

Notes:

- 1- Resolute Bay 10m down current from discharge pipe.
- 2- CCME Interim Marine and Estuarine Water Quality Variable (December 1996)
- 3- Effluent discharge to a marine bay or fjord (Guidelines on the Discharge of Treated Municipal Wastewater in the Northwest Territories, 1992)
- 4- BCMoELP (Nordin 1990) cited in BCMoELP (1995) - water quality criteria for saltwater life. Ammonia to (T = 0°C; Salinity 30g/kg; pH = 7.6)

The range of pH, 7.0 to 8.7, is recommended by the Canadian Water Quality Interim Guidelines for marine and estuarine environments (CCME 1996). The guideline also states that within this range, pH should not vary by more than 0.2 pH units from the natural pH expected at that time. This is intended to protect marine organisms which have narrow pH tolerances. During the July 1992 sampling, the pH 5-10 meters down current of the effluent discharge point is almost 0.2 pH units higher than the pH at the point of discharge (Table 5.2) indicating that the sewage effluent may be resulting in a slight decrease in pH in the immediate vicinity of the discharge.

TSS levels were somewhat variable between sampling periods which is not surprising given that sewage strength will vary over the day. Diurnal testing of the sewage discharge would be required to determine daily/weekly peaks for this parameter.

The Faecal and Total Coliform tests varied considerably (10 fold) over the tests. Like TSS this is an indication of varied sewer strengths. The fact that the FC levels are high when the BODs is low can not be explained. Logically, these levels should follow somewhat similar trends.

5.3.3 Phytoplankton

The following information regarding phytoplankton communities is summarized from Bain *et. al.* (1977 cited in Buchanan and Ragnit 1978).

Common "spring" phytoplankton species reported in the area include *Nitzschia grunowii*, followed to a less extent by *Nitzschia seriata*, and *Thalassiosira nordenstioeldii*. Common "Summer" phytoplankton species include *Chaetoceros socialis*. No differences in phytoplankton populations observed between sites sampled under ice and those sampled in open water, most likely due to the presence of strong southward moving currents in Wellington Channel. Similarly, phytoplankton communities demonstrated no consistent depth preference, again most likely due to physical influences such as tidal action and light intensity.

Phytoplankton communities reported along the Resolute Passage ice-edge sampled in early July exhibited low standing stock and differed considerably in composition from populations in the Wellington Channel.

Particularly noteworthy is a study by Welch and Kalff (1975 cited in Buchanan and Ragnit 1978) which presents measurements of marine photosynthesis and respiration in Resolute Bay. The authors reported chlorophyll concentrations in the water ranging from 0.001 - 0.1 mg/m³ during the winter to 15 mg/m³ in August. This information could potentially provide an interesting comparison to current conditions within Resolute Bay.

Potential impacts to phytoplankton populations due to the sewage discharge to the bay are expected to be minimal and restricted to the area in the immediate vicinity of the discharge point. Increased loadings of nutrients may result in a localized increase in phytoplankton productivity, however the magnitude of

this increase would be determined by overall nutrient loadings, characteristics of the mixing zone, and physical aspects such as tidal and weather (ie. wind, waves, etc.) effects.

5.3.4 Zooplankton

Thirty-five zooplankton species were identified by Bain *et al.* (1977). The community was numerically dominated by copepods such as *Pseudocalanus* spp., but in terms of biomass the community was dominated by the copepods *Calanus glacialis* and *Calanus hyperboreus*. Barnacle nauplii were also extremely abundant in some samples. Unlike phytoplankton, pelagic and under-ice fauna are generally less abundant (Green and Steele 1975 cited in Buchanan and Ragnit 1978).

As with phytoplankton, potential impacts to zooplankton populations inhabiting Resolute Bay would most likely be minimal and restricted to the area in the immediate vicinity of the discharge point. Increased phytoplankton productivity due to nutrient loadings could potentially result in an associated increase in zooplankton productivity, but any increases would be expected to be small.

5.3.5 Benthic Invertebrates

Dominant benthic invertebrates reported (Green and Steele 1975 cited in Buchanan and Ragnit 1978) in Resolute Bay include:

- clams (*Mya truncata*)
- brittle star (*Ophiura sarsi*)
- starfish (*Lepasterias groenlandicus*)
- mud shrimp (*Sclerocrangon boreas*)
- isopods (*Munnopsis typica*)
- whelk (*Buccinum belcheri*)

Motile invertebrates such as amphipods are often concentrated at the tidal surface and as such provide an important food source to shorebirds and seabirds and fish, particularly Arctic char (Ellis and Wilce 1961).

Benthic invertebrates, including shellfish, within the sewage discharge area could potentially be impacted by contaminant loadings. Unlike phytoplankton and zooplankton which are directly influenced by tides and water currents, benthos form a relatively sedentary population which continually exposed (to varying degrees) to diluted sewage and associated contaminants, and as such, the health of the organisms reflect the quality of the environment they inhabit. Shellfish, such as clams can also bioaccumulate various contaminants such as metals. Shellfish also filter out coliform bacteria from the water column, resulting in a potential health risk to humans if the shellfish are harvested.

5.3.6 Fisheries and Marine Mammals

Available information regarding fish and marine mammal communities is extremely limited for Resolute Bay.

Fish species reported in the area include arctic cod (*Boreogadus saida*), and ninespine stickleback (*Pungitius pungitius*). All fish were found to be actively feeding on amphipods. Several species of marine mammals are reported in the Resolute Bay area including Narwhal (*Monodon monoceros*), bowhead (*Balena mysticetus*), and white whales (*Delphinapterus leucas*).

Given the relatively low levels of discharge of sewage to Resolute Bay, fish and marine mammals communities are not likely to be directly impacted. Nutrient enrichment of the bay may in fact result in a localized increase in primary and secondary production (phytoplankton, zooplankton, benthos) which could potentially provide a greater food source for fish.

5.4 Public and Regulatory Agency Consultation

In an effort to further determine the status of a "Position Paper or Brief"(UMA 1996) regarding current sewage treatment and disposal for the Hamlet of Resolute Bay and authored by Fisheries and Oceans Canada and/or Environment Canada, several attempts have been made to contact appropriate staff from both federal agencies. However, no new information has been provided to establish what requirements may or may not be needed to further explore regulatory issues. This being the case, it is still unclear whether or not there are issues and concerns relating to sewage disposal that justify those requirements of the *Act*.

On November 4, 1998 an information session and consultation meeting was held at the Hamlet of Resolute Bay. This session was to provide Hamlet administrators and residents information regarding this study. An introduction to this study was provided to identify the scope of work being completed. The main focus of the meeting was to discuss the current and historical operational practices of sewage outfall and the perceived and potential environmental effects of the discharged wastes to the marine environment.

Consultation with the community consisted of an evening meeting at the Hamlet's community center. The meeting received publication through radio, television and newsprint media one week and again, one day prior to the event to ensure that community members were given adequate notice and the opportunity to attend.

Approximately 20 members of the community, including three Hamlet councilors and the Hamlet's Senior Administrative Officer (SAO), attended the session. Dillons' staff presented a study overview and described the intended scope of work through the use of overhead slides. One member of the community assisted in the presentation of materials to the community group by providing language translation

services for both the presentation of information and follow-up inquiries from local residents. A copy of Dillon's presentation is provided in Appendix 1.

Provided below is a summary of those comments, questions and discussions brought forward by community members at the meeting;

- During certain times of the open water season and when specific wind patterns exist the smell of sewage is very apparent within the Hamlet;
- What were the concerns raised under the NWT Health Act, with respect to the sewage issue?
- What is a cut off population for which the existing type of utilidor facility structure is not appropriate?
- How far out into the bay does effluent travel beyond the immediate discharge point?
- During the open water season the beach or shoreline area, in the vicinity of the sewage outfall, is used as an access point for boating;
- The current discharge location is not considered appropriate, as it is limiting the community development, small boat access, and there are olfactory problems during the summer period;
- Successful hunters will bring their animals (primarily seals) to the beach area where they are partially butchered;
- Some hunting does occur in Resolute Bay. Baffin Health Board was to have conducted a study to determine any impact from the sewage outfall. Therefore the people of Resolute Bay submitted some food samples (seals, whales that were captured from all over, including the Bay) to DFO, but no results are available so far. Some seal liver and fat studies were also to have been conducted;
- Due to DFO's long-time presence in Resolute, they should be able to provide some information and documents to Dillon with respect to sewage issues;
- Resolute Bay is not a heavily fished area, due to the lack of fish. Shellfish and clams are not typically collected from the Bay area, but it was suggested that they be studied as these food items are considered as a delicacy by the local people;
- Schools of cod are noted to inhabit the bay area in the vicinity of the outfall, especially when forced close to the shore as a result of feeding whales in the area;
- The bay area is not specifically used by the community for fishing and the cod that are forced

into the near shore area are not typically fished;

- Raw sewage is visible along the shoreline area in close proximity to the outfall location;
- No particular care is taken with respect to the substances being flushed. It is unknown (to the people of Resolute) whether DPW has any problems with their cleaning facility;
- There were several questions raised with respect to the acceptability of the current system (only grinding, no treatment) and constant flow towards the Bay. The community suggested that they would like an upgrade to a cleaning process to be done (e.g., filters at the very least) or any other appropriate improvement;
- Although significant concerns regarding the discharge of sewage at this location were not voiced, the potential impacts of the discharged sewage to the marine environment were identified as not being well known to the community;
- Should there be the potential for impact to the marine environment at this location it was noted that further study should be conducted to confirm it's significance and to identify/incorporate potential changes to the current sewage treatment system that would minimize those impacts and any community concern;
- One alternative identified was the relocation of the piped outfall location from its' existing location to a location south along the shoreline away from shoreline areas of use;
- Deep water discharge (e.g., 10-20 m off shore) would also be an acceptable alternative, from the prospective of the boat access, quick freezing which typically happens in the winter (which would be avoided if the discharge would be somewhere further from the shore), and to establish a deeper water discharge location and the enhancement of potential mixing;
- Discussion included the identification of requirements of the federal *Fisheries Act* and how it might apply to the current sewage treatment system and discharge at Resolute Bay;
- Compliance requirements of the Nunuvut Water Board and the associated water licence were also discussed resulting in the identification of current and historical licence compliance with the required discharge requirements.

In summary, no significant issues were raised by the community with regard to the discharge of sewage to the marine environment. However, they acknowledged that they were not totally familiar with what maybe the potential impacts. Certain activities that involve the processing of hunted seals and other mammals are conducted within the Bay and near shore areas the sewage smells and wastes are obvious to the residents at certain times. Certain food items, such as clams, are opportunistically harvested from the outfall area. Based on these issues it was noted that further consideration of these potential impacts should be reviewed.

6.0 REMEDIAL SYSTEM NEEDS

6.1 Water Mains

Future Capacity

The system was designed for a population of 1,500 people and a consumption of 225 lcd. The total daily average consumption for the original design was approximately 340,000 l/day. The projected 20 year demand based on the current growth rate and bleeder rate is approximately 183,000 l/day. Section 4 developed and completed a model for the distribution system to verify that there is sufficient capacity for the peak demand and the fire flow requirements. The model indicates that the fire flow demand is met by operating a valve in AV3 during the fire flow conditions. This should be verified as part of the standard operating procedures for the facility Maintainer.

One section of sewer main AV11 to AV32 is required to be increased to 250 mm to meet the design flows.

The flow requirements for the proposed new subdivision can be met through the expansion of the existing system. The new areas can be serviced with a 150 mm pipe line for the Water mains and the sewer mains.

The model was also run using 150 mm piping throughout the system. This run indicates that the 150 mm size will not meet the 20 year demand of the community. Therefore all replacement piping should maintain the 200 mm pipe size for the water main.

It should be noted that a significant amount of the system capacity is consumed through the use of the bleeders. These bleeders are not metered for flows. It would be useful to have actual measurements of the bleeder flows, bleed water temperature, as well as sewer pipe temperatures throughout the system. These measurements can be used to assess the required bleeder rates with the intent to reduce the overall bleed water consumption. As the community expands, this will become necessary to allow for the expansion of the system beyond the 20 year horizon to the 40 year planning horizon. The metres can be mechanical type metres, identical to house water metres. They should be read on a weekly bases and recorded by the Hamlet, and/or the system Maintainer. The cost to install the metres would be approximately \$2,000 per unit.

The measurement of the sewer temperatures should be completed for each leg of the sewer system. This will allow for the balancing of the bleed water. The sewer flow temperature should be measured weekly and recorded by the Hamlet and/or DPW&S Maintainer. The temperature metres can be installed for approximately \$1,000 per unit.

Once a year of data is collected, the information can be used to determine the required flows on a seasonal bases for the bleeder system. This will need to be fine tuned through the continued recording

of the bleeder flow metres and the sewer temperature readings.

6.2 Sewage Discharge

The limited water quality data collected from the sewage discharge to Resolute Bay, and a sampling location 5-10 metres down current from the discharge location, tends to indicate that there is localized impacts to the marine receiving environment. The extent or magnitude of these impacts cannot be determined in detail based on the extremely limited data collected to date for water quality and for the biota inhabiting the marine receiving environment.

The Hamlet of Resolute Bay currently meets the discharge requirements of their water licence issued by the Nunavut Water Board. It is also apparent from the results that the strengths of the sewage could be increased two or three times and still meet compliance. This may occur in the bleeding rate is decreased over time.

Regardless of the bleeder rate, the total mass loadings of the contaminant to the receiving environment will remain consistent. The long term environmental and human impacts are more related to the mass loading, rather than the concentration of the discharge. There are impacts related to “shocks” to the marine system created by sudden increases in the contaminants of concern. This would be related to at shore organisms, only. As such, a reduction in the bleeding rate by 1 or 2 fold is not expected to impact the effects of the sewage and the receiving environment. To determine the long term impact of the sewage mass loadings, there is the requirement to collect and assess data at the marine environment. A summary is shown in **Table 5.2**.

Table 5.2
Summary of Information Required for Detailed Impact Assessment

Information/Data Required	Rationale
Physical	
- tidal information, wind speeds, wind directions, wave climate, etc.	- this information will help determine the magnitude and extent of any plume, etc. - also help address any dilution issues - much of this information should be readily available from Environment Canada
Chemical (i.e. water and sediment quality)	
- more detailed characterization of effluent and receiving environment water quality.	- current annual sampling results do not provide the necessary detail to assess diurnal variation in effluent characteristics - the current program also does not assist in the determination of the spatial extent of any effluent plume - this information would be used to determine average effluent concentrations
- include a control location in any sampling program perhaps in an adjacent bay	- control site data will provide a good comparison to sewage discharge results
- evaluation of dissolved oxygen levels within Resolute Bay	- given concerns with respect to oxygen depletion in the bay it would be worthwhile to determine oxygen levels in the bay particularly under the ice-cover.
- characterize sediment quality with the receiving environment	- determine distribution of any contaminants within the marine sediments - sampling program would be designed to delineate impacts from the sewage discharge and those potentially from the solid waste disposal site.
Biological	
Shellfish, such as clams (<i>Mya truncata</i>) should be sampled to assess potential shellfish contamination	- elevated coliform levels observed in the vicinity of the discharge could potentially result in shellfish contamination - clams are also excellent biomonitors for other contaminants such as metals.
Benthic-invertebrate communities	- benthic invertebrates provide excellent indicators of overall environmental quality - benthos information can be related back to water and sediment quality data to assess impacts

REFERENCES

- Guidelines for the Investigation, Design, Construction and Remediation of Buried HDPE Sewer Systems in the Eastern Arctic, Agra Earth & Environmental, March 1996.
- Construction of Water and Sewer Servicing Stage 1A - New Townsite, Resolute Bay, NWT, UMA, 1977
- Report on Subsurface Soil Conditions for Proposed Sewage Treatment Plant, Water Reservoir and Pumphouse at Char Lake, Resolute Bay, NWT, UMA, 1975.
- Report on Study of Pollution Control Systems, Resolute Bay, NWT, UMA, 1974.
- Installation of Intake Pipe Char Lake, Resolute Bay, NWT, Underwater Specialists, 1976.
- General Development Plan, Resolute Bay, NWT, UMA, December 1977.
- 1992 Sewer Rehabilitation Manhole 62 to 63, HBT Agra, November 16, 1992, James Anklewich, BSc, P. Eng.
- Assessment of Sewer Collapse Problems, Iqaluit, NWT, Hardy BBT Limited, January 1990, Alan Hanna, M. A. Sc, P. Eng.
- British Columbia Ministry of Environment Lands and Parks. 1995. Approved and Working Criteria for Water Quality - 1995. Water Quality Branch, Environmental Protection Department. 44pp.
- Birtwell, I.K., G.L. Greer, M.D. Nassichuk, and I.H. Rogers. 1983. Studies on the Impact of Municipal Sewage Discharged onto an Intertidal Area Within the Fraser River Estuary, British Columbia. Canadian Technical Report of Fisheries and Aquatic Sciences, No. 1170.
- Buchanan, R. A. and W. E. Ragnit. 1978. The Marine Ecology of Lancaster Sound and Adjacent Waters: An Annotated Bibliography - Environmental Studies 7. Report prepared by LGL Limited, Environmental Research Associates, Toronto, Ontario for the Institute of Ocean Sciences.
- Canada Flight Supplement, Canada and North Atlantic Terminal and Enroute Data, November, 1997, Natural Resources Canada. Published under the authority of NAV CANADA.
- Department of Indian Affairs and Northern Development. 1987. Sewage Waste Discharge to the ArcticMarine Environment. Environmental Studies No. 55. Prepared by Stanley Associates Engineering Ltd.

Draft Report on Iqaluit Sewer Monitoring Program, Iqaluit, Northwest Territories, HBT Agra Limited, July 1993, Alan Hanna, M.A.Sc, P. Eng.

Draft Guidelines for the Remediation of Collapsed HDPE Pipes in Iqaluit, HBT Agra Limited

Ellis, D.V. and R. T. Wilce. 1961. Arctic and subarctic examples of intertidal zonation. Arctic 14:224-235.

Happy Valley Sewer Main Collapse Inspection, HBT AGRA, February, 1992, James Anklewich, BSc, P. Eng.

Otte, G. and C.D. Levings. 1975. Distribution of Macroinvertebrate Communities on a Mud Flat Influenced by Sewage, Fraser River Estuary, British Columbia. Fisheries and Marine Service, Technical Report No. 476.

UMA Engineering Ltd. 1996. Resolute Bay, NWT Water and Sewer Facilities Investigation. Final Report. Report prepared for the Government of the Northwest Territories, Public Works and Services.

Welch, E.B. 1980. Ecological effects of waste water. Cambridge University Press, Cambridge. 337 pp.

APPENDIX A

Pipe Network Model Results

[TITLE]

EPANET Resolute Bay October 1998 Run 1 Existing Conditions

;Vavle at AV3 open

[JUNCTIONS]

Node	Elevation (m)	Demand (homes)	Pattern
101	71.68		
2	36.48		
3	25.44	2	
103	25.44		
4	26.51	3	
5	18.78	4	
6	16.55	4	
106	16.55	2	
7	14.12		
107	14.12	3	
8	12.96	4	
108	12.96	1	
9	11.60	5	
10	9.65		
11	9.14	3	
12	12.95	3	
13	13.82	1	
14	16.87	3	
16	19.66	1	
17	22.77		
18	21.50		
19	22.34	5	
20	21.14	3	
21	20.93	2	
121	20.93		
22	28.17	1	
23	17.11	2	
25	19.41	4	
27	16.72	2	
28	13.72	3	
29	17.08	1	
30	20.48	1	

[DEMANDS]

MULTIPLY .01302 ;225 lpcd * 1/(24*3600) * 5 peolpe/dwelling

;

; System bleeds (l/s)

Node	Demand	Pattern
17	5.25	
19	5.25	
22	5.25	
25	5.25	
30	1	2
4	1	3

;

;

;

[TANKS]

Node (m)	Elevation (m)	Initial (m)	Minimum (m)	Maximum (m)	Diameter (m)
1	88.98				

101 71.68

[PIPES]

Pipe	Start	End	Length (m)	Diameter (m)	C
1	1	2	211.15	200	110
2	2	3	118.26	200	110
; open valve between 3 and 103 for fire flows					
103	103	101	329.41	150	110 CV
203	3	103	10.0	200	110
3	3	21	70.71	200	110
4	4	103	93.38	200	110
5	5	4	86.74	200	110
6	106	5	41.59	200	110
107	106	107	41.45	200	110
108	107	108	22.86	200	110
109	9	108	22.57	200	110
7	6	7	41.45	200	110
8	7	8	22.86	200	110
10	10	9	46.02	200	110
11	10	11	83.82	200	110
12	12	11	78.82	200	110
14	14	13	78.16	200	110
16	16	14	83.23	200	110
17	17	16	80.36	200	110
18	18	17	50.94	200	110
19	19	18	24.24	200	110
20	20	19	76.45	200	110
21	21	20	48.23	200	110
22	22	20	105.20	150	110
23	13	23	98.15	200	110
25	25	23	98.27	150	110
26	27	12	86.00	200	110
27	28	27	69.27	200	110
28	8	28	91.03	200	110
29	29	6	66.75	200	110
30	30	29	60.66	200	110
31	121	30	41.89	200	110
32	23	121	70.33	200	110

[PATTERNS]

;Pattern 1: first hour is avg day, second is max day,
; third is peak hour, others are avg day plus fire

1 1.0 2.0 4.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0 1.0
2 0.0 0.0 0.0 60.0 60.0 0.0 0.0 0.0 0.0 0.0 0.0
3 0.0 0.0 0.0 0.0 0.0 60.0 60.0 0.0 0.0 0.0 0.0
4 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
5 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0

[TIMES]

DURATION 6

PATTERN TIMESTEP 1

[OPTIONS]



UNITS SI

MAP exist.map

[END]


NETWORK SCHEMATIC

EPANET Resolute Bay October 1998 Run 1 Existing Conditions (6:00 hrs)



NO CONNECTION AT AV3-AV103


EPANET Resolute Bay October 1998 Run 1 Existing Conditions (5:00 hrs)




FIRE AT 4

Min pressure } not met at 4 nodes.
of 150 kPa


EPANET Resolute Bay October 1998 Run 1 Existing Conditions Avg Day




EPANET Resolute Bay October 1998 Run 1 Existing Conditions Max Day



EPANET Resolute Bay October 1998 Run 1 Existing Conditions Peak Hour



EPANET Resolute Bay October 1998 Run 1 Existing Conditions Avg Day plus Fire at 4



[TITLE]

EPANET Resolute Bay October 1998 Run 2 Future Conditions

; Valve at AV3 open

[JUNCTIONS]

	Node	Elevation (m)	Demand Pattern (homes)

;	101	71.68	
	2	36.48	
	3	25.44	2
	103	25.44	
	4	26.51	3
	5	18.78	4
	6	16.55	4
	106	16.55	2
	7	14.12	
	107	14.12	3
	8	12.96	4
	108	12.96	1
	9	11.60	5
	10	9.65	
	11	9.14	3
	12	12.95	3
	13	13.82	2
	14	16.87	6
	16	19.66	4
	17	22.77	
	18	21.50	
	19	22.34	5
	20	21.14	3
	21	20.93	2
	121	20.93	
	22	28.17	4
	23	17.11	2
	25	19.41	4
	27	16.72	2
	28	13.72	3
	29	17.08	1
	30	20.48	1

; future conditions, elevations are approximate

201	25.0	5
202	14.0	8
203	25.0	5
204	14.0	8
205	13.0	3
206	13.0	5
32	9.0	3

DEMANDS]

MULTIPLY .01302 ;225 lpcd * 1/(24*3600) * 5 people/dwelling

System bleeds (l/s)

	Node	Demand	Pattern
,	17	5.25	
	19	5.25	
	22	5.25	
	25	5.25	
	201	5.25	
	203	5.25	
	201	1	2

```


205      1      3
32      1      4
;
;
[TANKS]
;-----
;   Node      Elevation      Initial      Minimum      Maximum      Diameter
;   (m)        (m)          (m)          (m)          (m)          (m)
;-----
;   1          88.98
101      71.68
;
[PIPES]
;-----
;   Pipe      Start      End      Length      Diameter      C
;   (m)        (m)          (m)          (m)          (m)
;-----
;   1          1          2          211.15          200          110
;   2          2          3          118.26          200          110
;   2003       103        3          10.0           200          110
;   103        103        101        329.41          200          110      CV
;   3          3          21          70.71          200          110
;   4          4          103        93.38          200          110
;   5          5          4          86.74          200          110
;   6          106        5          41.59          200          110
;   107        106        107        41.45          200          110
;   108        107        108        22.86          200          110
;   109        9          108        22.57          200          110
;   7          6          7          41.45          200          110
;   8          7          8          22.86          200          110
;   10         10        9          46.02          200          110
;   11         10        11         83.82          200          110
;   12         12        11         78.82          200          110
;   14         14        13         78.16          200          110
;   16         16        14         83.23          200          110
;   17         17        16         80.36          200          110
;   18         18        17         50.94          200          110
;   19         19        18         24.24          200          110
;   20         20        19         76.45          200          110
;   21         21        20         48.23          200          110
;   22         22        20        105.20          150          110
;   23         13        23         98.15          200          110
;   25         25        23         98.27          150          110
;   26         27        12         86.00          200          110
;   27         28        27         69.27          200          110
;   28         8         28         91.03          200          110
;   29         29        6          66.75          200          110
;   30         30        29         60.66          200          110
;   31         121       30         41.89          200          110
;   32         23       121        70.33          200          110
;
: future conditions
;   203        17       203        122.5          200          110
;   201        203       201        105.0          200          110
;   204        203       204        157.0          200          110
;   202        201       202        157.0          200          110
;   304        202       204        105.0          200          110
;   205        204       205         70.0          200          110
;   206        205       206        122.5          200          110
;   232        206       32        157.0          200          110
;   211        32       11         91.44          200          110

```


```

[PATTERNS]
;Pattern 1: first hour is avg day, second is max day,
;          third is peak hour, others are avg day plus fire
;
1 1.0  2.0  4.0   1.0  1.0   1.0   1.0  1.0   1.0  1.0  1.0  1.0
2 0.0  0.0  0.0  60.0 60.0   0.0   0.0  0.0   0.0  0.0  0.0  0.0
3 0.0  0.0  0.0   0.0  0.0  60.0  60.0  0.0   0.0  0.0  0.0  0.0
4 0.0  0.0  0.0   0.0  0.0   0.0   0.0 60.0  60.0  0.0  0.0  0.0
5 0.0  0.0  0.0   0.0  0.0   0.0   0.0 0.0   0.0  0.0  0.0  0.0
;
;
[TIMES]
DURATION 8
PATTERN TIMESTEP 1
[OPTIONS]
UNITS      SI
MAP future.map
[END]


```


EPANET Resolute Bay October 1998 Run 2 Future Conditions Avg Day




EPANET Resolute Bay October 1998 Run 2 Future Conditions Max Day



EPANET Resolute Bay October 1998 Run 2 Future Conditions Peak Hour



EPANET Resolute Bay October 1998 Run 2 Future Conditions Avg Day Plus Fire at AV201



RESOLUTE BAY SANITARY SEWER
 pop 209 (1998)

Assumptions 5 people per household, 225 ipcd, PF=4, n=0.013
 Total water use=RWU*(1+(.00023*Population))

Pipe	From AV	To AV	Length (m)	Incremental Dwellings	Total Dwellings	Sewage Flow (L/day) (peakhour)	Sewage Flow (m ³ /s)	Diameter (m)	Slope	Capacity (m ³ /s)	Utilization (%)
1	Plant	AV2	211.53	0	0	0	0.0000	0.150	0.1160	0.052	0.0
2	AV2	AV3	118.26	2	2	9433	0.0001	0.150	0.0790	0.043	0.3
3	AV3	AV21	70.85	1	3	14149	0.0002	0.150	0.0595	0.037	0.4
32	AV21	AV23	70.33	3	6	28298	0.0003	0.150	0.0565	0.036	0.9
*25	AV25	AV23	98.27	4	4	18865	0.0055	0.150	0.0199	0.021	25.5
23	AV23	AV13	98.15	1	11	51879	0.0059	0.150	0.0280	0.025	23.0
*17	AV17	AV16	80.36	0	0	0	0.0053	0.150	0.0364	0.029	18.1
16	AV16	AV14	83.23	2	2	9433	0.0054	0.150	0.0321	0.027	19.6
14	AV14	AV13	78.18	2	4	18865	0.0055	0.150	0.0422	0.031	17.5
13	AV13	AV12	23.45	0	15	70745	0.0113	0.150	0.0455	0.032	34.8
26	AV27	AV12	86.00	4	4	18865	0.0002	0.150	0.0450	0.032	0.7
12	AV12	AV11	78.82	3	22	103759	0.0117	0.150	0.0432	0.032	37.0
*20	AV19	AV20	76.45	7	7	33014	0.0056	0.150	0.0157	0.019	29.5
*22	AV22	AV20	105.20	1	1	4716	0.0053	0.150	0.0659	0.039	13.8
21	AV20	AV21	48.23	1	9	42447	0.0110	0.150	0.0060	0.012	93.2
31	AV21	AV30	41.89	0	9	42447	0.0110	0.150	0.0089	0.014	76.5
30	AV30	AV29	60.66	2	11	51879	0.0111	0.150	0.0561	0.036	30.8
29	AV29	AV6	66.75	4	15	70745	0.0113	0.150	0.0077	0.013	84.7
5	AV4	AV5	86.74	7	7	33014	0.0004	0.150	0.0889	0.045	0.8
6	AV5	AV6	41.59	2	9	42447	0.0005	0.150	0.0503	0.034	1.4
7	AV6	AV7	41.45	3	27	127341	0.0120	0.150	0.0584	0.037	32.5
8	AV7	AV8	22.86	2	29	136773	0.0121	0.150	0.0401	0.030	39.6
28	AV28	AV8	91.03	6	6	28298	0.0003	0.150	0.0056	0.011	2.9
9	AV8	AV9	29.57	0	35	165071	0.0124	0.150	0.0464	0.033	37.8
10	AV9	AV10	46.02	5	40	188653	0.0127	0.150	0.0430	0.032	40.2
11	AV10	AV11	83.82	1	41	193369	0.0127	0.200	0.0057	0.025	51.4
311	AV11	AV32	91.44	0	63	297128	0.0244	0.200	0.0028	0.017	140.8
33	AV32	AV33	91.14	0	63	297128	0.0244	0.200	0.0060	0.025	96.2
34	AV33	AV34	88.09	0	63	297128	0.0244	0.200	0.0131	0.038	65.1
35	AV34	AV35	39.32	0	63	297128	0.0244	0.200	0.0084	0.030	81.3

*3/4" bleed into sewer, .00525 m³/s

APPENDIX B

Cost Estimate Data

FALL ARREST EQUIPMENT

ANCHORAGE CONNECTORS

Anchor connectors meet the many needs and applications of fall protection users in construction, industrial and maintenance markets. These connectors must be attached to a structure that can support a 5,000 pound static pull and can only be used by one worker. All the anchor connectors meet the requirement of OSHA 1926.502 and ANSI 110.14.

L-D-1 LT ANCHOR

Unique D-shape is designed specifically to eliminate rollout. Made of drop forged steel, cadmium/zinc plating and forged steel. Single attached fastener with nut and washer is easy to install and can be mounted in a variety of positions. Deal with the retractable lifelines. Maximum working load of 310 lbs.



I-BEAM CLAMP

The beam clamp is a steel anchorage connector designed for use with horizontal I-beams, beams and W-beams. This steel cast construction features a steel attachment point to prevent twisting of the worker's lanyard or connecting device. Clamps come in two sizes: Model SD006 fits beams up to 9" wide; Model SD007 can be used on beams up to 12 1/2" wide. Working load of 310 lbs. maximum. Colour: Red with black handle.



WEBBING/HOOK ANCHOR

Designed to utilize anchorage to folding, pipe or angle iron. Features a large, 2 1/2" snap hook for easy one-hand installation and a D-ring to accommodate the connecting device. No tools required. Made of forged steel, zinc plated hardware with 1 3/4" nylon webbing.



D. HOOK ANCHOR W/SHOCK ABSORBER

This anchorage connector offers the same benefits as Model SD008, but includes a Sofstop™ shock absorber to reduce the forces of falling.



E. CROSS-ARM STRAP

Designed to wrap around I-beams and other structures forming a secure attachment point for lanyards and other connecting devices. Manufactured from 2" nylon webbing for maximum strength, the strap features a 2" forged D-ring on one end which slips through a 3" D-ring on opposite end to form a secure anchor. Available in 6 feet length.



F. BEAM TROLLEY

Steel beam trolley creates an anchorage point that moves with the work for maximum mobility. Accommodates I-beams from 3" to 8" wide, and is ideally suited for the attachment of lanyards, carabiners and retractable lifelines. Working load 310 lbs.



G. CROSS-ARM STRAP W/SHOCK ABSORBER

Designed to form a secure, low cost anchorage point for various connecting devices. Features 2" nylon webbing, forged D-rings and an integral Sofstop™ shock absorber which greatly reduces the force of falling. Install on beams, pipes and railings is easily accomplished. No tools required.



Model No.	Description	Each
SD001	D-Bolt anchor	\$ 61.02
SD006	Beam clamp, 9" wide	352.00
SD007	Beam clamp, 12 1/2" wide	505.00
SD008	Webbing/hook anchor	122.00
SD538	Hook anchor w/shock absorber	151.00
SD009	Cross-arm strap	34.97
SD010	Beam trolley	324.00
SD539	Cross-arm strap w/shock absorber	112.00

CSA Z94.1.92 APPROVED HARD HATS (A-SAFE)

Weights less than 19.5 ozs. High-density polyethylene outer shell provides all-round impact and penetration protection. Universal slots will accept all attachment systems. Expanded polystyrene inner shell prevents injuries from lateral, side and back impacts. Choice of ratchet or pinlock type suspension. 6 point suspension system comes with 2 adjustment levels for headband on front and rear tab for additional stability and comfort. 4 point pinlock self-sizing suspension is also available. Sliding mechanism on rear tabs allow for centering of hat on head. Crown pad and sweatband for user comfort. Meets CSA Z94.1.92.

CONFINED SPACE RESCUE SYSTEMS

Accessing confined spaces involves a number of life threatening hazards, including the possibility of a vertical fall or being overcome by fumes or gases. Confined space access, rescue and retrieval systems are designed to provide a safe means of accessing a confined space area. In an emergency, confined space systems allow rescuers to retrieve injured or unconscious workers without exposing themselves to similar potential hazards. Confined space systems meet all applicable OSHA, CSA and ANSI standards. A standard confined space system for fall protection and emergency retrieval. Includes a retrieval/retracting lifeline, 7 foot tripod, pulley block, winch bracket and a full body harness. Where primary access is unavailable, a drum winch can be used as primary access into the confined space. In addition to the drum winch, a retrieval lifeline is used as a secondary backup for fall protection and rescue. The drum winch can be used to lower and raise materials after the worker has accessed the confined space, while still ensuring rescue in the event of an emergency.




Model No.	Description	Each
SE139	7' Aluminum telescopic tripod 10,000 lbs. rated	\$ 1003.00
SA057	Bi-directional retrieval/retracting lifeline S/S wire 60'	2468.00
SD698	Tripod mounting bracket	326.00
SD699	Pulley block	263.00
SD700	Drum winch 55' galvanized steel wire and bracket	1055.00
SA046	Full body harness, one size	89.44

ROOF ANCHOR KITS

Installs on steep-pitched or flat surface roofs. When roofing is complete, it is easily removed and ready for the next job. Includes 25 foot or 50 foot 5/8" nylon rope lifeline, carabiner, rope grab with 24" Sofstop™ shock absorbing lanyard, Duralite harness (fits medium to extra large), two reusable roof anchors, 20 pan head sheet metal screws, instructions, instructional video, and carrying bag. Replacement roof anchor brackets with screws available. Meets OSHA regulations.


Model No.	Description	Each
SD011	Roofers kit, 25'	\$491.00
SD012	Roofers kit, 50'	508.00
SD013	Roof anchor brackets	28.56



ROOFSTRIDER KIT

Kit is easily installed with a hammer and features 360° rotation for great working mobility and provides workers with constant protection through long, hard hours of work. Built to perform, protect, under tough conditions and on steep roofing angles. The retractable lifeline unit easily attaches to the four-legged roof mounting assembly with two integral push pins. The foot pad on the roof mounting assembly are easily adjustable to fit variable roof pitches and should be attached to a roof with 16d nails. System must be installed in accordance with the manufacturer's instructions. Allowing hands free worker mobility, the locking snap hook of the retractable lifeline unit attaches to the back dee ring of the roofer's harness. If a slip or fall should occur, the inertia brakes of the retractable lifeline unit activate, keeping cable payout to two feet or less. The complete kit consists of a self-contained 25 foot or 50 foot retractable lifeline, four-legged roof mounting assembly, DuraLite Harness, 24 16d cement-coated nails, instructions, instructional video, and carrying bag. Complies with OSHA's Construction Fall Protection Standard 1926.500.

Model No.	Description	Each
SD541	Roof strider Kit, 25'	\$2053.00
SD542	Roof strider Kit, 50'	2072.00



Model No.	Suspension	Colour	Each
SA650	Ratchet	Sky Blue	\$31.31 \$28.18
SA651	Ratchet	White	31.31 28.18
SA652	Ratchet	Yellow	31.31 28.18
SC064	Pinlock	White	\$23.55 \$21.20
SC065	Pinlock	Yellow	23.55 21.20

Other colours available upon request.



PERSONAL GAS MONITORS & AIR MONITORS

PERSONAL GAS MONITOR

Features:

- Available in one, two, or three gas models
- High visibility LCD shows continuous gas identification
- Adjustable audible and visual alarms
- Simple operation with one-step zeroing
- Automatic calibration
- Interchangeable alkaline or NiCad batteries
- Rugged and lightweight

Simple and intuitive, the *Bodyguard* monitor detects the presence of oxygen, combustibles and toxic gases. It is available as a one-gas, two-gas or three-gas monitor, and can easily be upgraded in the field for any combination of gases.

Two versions are now available. The basic unit simply displays gases and battery life. The only button is for the backlight. This unit is ideal for confined space entry and applications where user interface is minimal, such as oil, and petroleum refining, waste water treatment, coal mines and general industry.

The advanced version includes peak displays and the option of latching alarms for use in similar applications. On both versions, buttons are clearly marked for easy identification.

Rugged and water resistant, the *Bodyguard* monitor can withstand the most abusive conditions. Adjustable audible and visual alarms help to ensure user safety.

Bodyguard uses alkaline or nickel-cadmium batteries. Battery packs are interchangeable and easily replaceable. The water-resistant case is made of high-strength alloy, coated for added durability. Visual alarms on the front and bottom of the instrument ensure visibility from all angles. The audible alarm uses alternating tones to make sure it can be heard in noisy environments. Built-in diagnostics continually monitor the functionality of the unit. A confidence light on the bottom of the instrument lets the user know that it is working properly.

Each *Bodyguard* comes with a calibration cup, screwdriver and a durable leather case. The case provides added protection and allows the *Bodyguard* to be carried easily on a belt, harness or shoulder strap. A Confined Space Kit is available for mobile applications like construction, utilities and hazmat teams. It includes a hand-aspirated pump, tubing and personal alarm packaged in a durable *Pelican*-brand case for storing the instrument and accessories.

Specifications:

Gases Detected & Range:

Oxygen:	0 - 30%
Combustible Gases:	0 - 100% LEL (0 - 5% CH ₄)
Carbon Monoxide:	0 - 999 ppm
Hydrogen Sulfide:	0 - 500 ppm

Sampling Method:

Diffusion; pump (optional)

Power Supply:

2 "AA" alkaline or NiCad battery pack

Battery Life:

10 - 12 hours

Operating Conditions:

-4 to 122°F (-20 to 50°C); 0 to 99% RH, non-condensing

Dimensions:

2.87" x 1.62" x 4.73" (7.3 x 4.1 x 12.0 cm)

Weight:

14 oz (392 g)

Safety Rating:

Intrinsically safe for use in Class I, Division 1 & 2, Groups A, B, C and D and Class II, Divisions 1 & 2, Groups E, F and G hazardous areas. UL, MSHA, CSA and CENELEC approvals pending.

Model No.	Description	Each
BASIC UNITS		
HM550	1 Gas Personal Monitor, O ₂	\$1165.00
HM551	1 Gas Personal Monitor, LEL	1195.00
HM552	1 Gas Personal Monitor, CO	1265.00
HM553	1 Gas Personal Monitor, H ₂ S	1265.00
HM554	2 Gas Personal Monitor, O ₂ , LEL	1495.00
HM555	3 Gas Personal Monitor, O ₂ , LEL, CO	1795.00
HM556	3 Gas Personal Monitor, O ₂ , LEL, H ₂ S	1795.00

ADVANCED UNITS		
HM557	1 Gas Personal Monitor, O ₂	\$1240.00
HM558	1 Gas Personal Monitor, LEL	1265.00
HM559	1 Gas Personal Monitor, CO	1340.00
HM560	1 Gas Personal Monitor, H ₂ S	1340.00
HM561	2 Gas Personal Monitor, O ₂ , LEL	1560.00
HM562	3 Gas Personal Monitor, O ₂ , LEL, CO	1860.00
HM563	3 Gas Personal Monitor, O ₂ , LEL, H ₂ S	1860.00

ACCESSORIES

HM564	Confined Space Kit	\$375.00
HM565	Calibration Kit	210.00

PERSONAL GAS MONITOR

Features:

- Capable of monitoring 10 different gases
- High visibility LCD shows continuous gas concentrations
- Audible and visual alarms
- Easy to operate
- Water resistant
- Interchangeable alkaline or NiCad batteries
- Compact and lightweight

The *Canary* offers personal protection in a compact, reliable instrument. Portable monitoring for 10 different gases allows you the freedom to work in any environment without the worry of atmospheric hazards. A factory installed, gas specific sensor on the top of the instrument monitors the surrounding air to alert you to changes in air quality.

Ten gas versatility makes this instrument easily adaptable for monitoring in a variety of hazardous areas. The range of industry applications is vast including steel manufacturing, pulp and paper mills, oil and petrochemical refineries, water and wastewater treatment, chemical plants, offshore drilling, and more.

Weighing just 10 ounces, the *Canary* is easily carried in a shirt pocket or with its convenient belt clip. An optional carrying case with neck strap is also available.

A red flashing LED and audible alarm let the user know when a dangerous situation occurs and an LCD display gives accurate readings of the amount of gas encountered. Once the gas concentration has dropped out of alarm range, the *Canary* automatically resets. A push-button backlight and dust and water resistant case allow you to work under many conditions.

For added security, a green LED confidence light flashes every three seconds, letting you know the instrument is working properly and battery levels are adequate. The *Canary* can be powered by four "AA" size alkaline batteries or a rechargeable Nicad pack.

Maintenance on the *Canary* is fast and easy, to get you on the job quickly and allow you to make necessary changes in the field. Zeroing the *Canary* can be done in just one step. Simply open the cover below the display and adjust the preset zero until the display shows the correct reading. Sensor replacement can also be done with minimum effort. Remove the back cover and batteries, unplug the used sensor and replace it with a new sensor.

Specifications:

Gases Detected & Range:

Oxygen:	0 - 25% O ₂
Methane:	0 - 100% LEL CH ₄
Carbon Monoxide:	0 - 500 ppm CO
Hydrogen Sulfide:	0 - 50 ppm H ₂ S
Sulfur Dioxide:	0 - 10 ppm SO ₂
Chlorine:	0 - 5 ppm Cl ₂
Nitrogen Dioxide:	0 - 10 ppm NO ₂
Hydrogen Chloride:	0 - 10 ppm HCl
Hydrogen Cyanide:	0 - 25 ppm HCN
Ammonia:	0 - 50 ppm NH ₃

Sampling Method:

Diffusion

Power Supply:

4 "AA" alkaline or NiCad battery pack

Operating Conditions:

14 to 122°F (-10 to 50°C); 0 to 90% RH, non-condensing

Dimensions:

2.5" x 1.5" x 4.5" (6.4 x 3.8 x 11.4 cm)

Weight:

Less than 10 oz (268 g)

Safety Rating:

Intrinsically safe for use in Class I, Division 1, Groups A, B, C and D. CSA certified.


Model No.	Description	Each
HM566	Personal Gas Monitor, O ₂	\$595.00
HM567	Personal Gas Monitor, CH ₄	855.00
HM568	Personal Gas Monitor, CO	870.00
HM569	Personal Gas Monitor, H ₂ S	870.00
HM570	Personal Gas Monitor, SO ₂	895.00
HM571	Personal Gas Monitor, Cl ₂	930.00
HM572	Personal Gas Monitor, NO ₂	930.00
HM573	Personal Gas Monitor, HCl	980.00
HM574	Personal Gas Monitor, HCN	980.00
HM575	Personal Gas Monitor, NH ₃	980.00

AIR MONITORS

The monitor shows an immediate colour change in the presence of a specific gas. Compare colour on badge to chart which indicates OSHA and ACGIH time limit for exposure, to find precise accumulation or exposure to a substance. No laboratory analysis required. Ideal for monitoring areas for accumulation and ceilings, for monitoring critical joints, and for sampling the environment to indicate the ppm present. Exposed monitors may be retained as a permanent record.

Note: Supplied in cartons of 10 badges.

Model No.	Critical Level	Toxic Substance	Colour Change	Each
HD654	25 ppm	Ammonia	Yellow - Blue	\$48.00
HF169	1 ppm	Chlorine	White - Yellow	48.00
HF746	.1 ppm	Hydrazine	White - Yellow	48.00
HF902	10 ppm	Hydrogen Sulfide	White - Brown	48.00
HK247	5 ppm	Nitrogen Dioxide	White - Yellow	48.00
HK278	.1 ppm	Ozone	White - Brown	48.00
HF223	50 ppm	Carbon Monoxide	Tan - Black	48.00



REGULATION FIRST AID KITS

REGULATION FIRST AID KITS CONT.

New!

NEW BRUNSWICK FIRST AID KITS

Component	Contents CSST plus	
Product Description	1 - 9 Emp.	10 - 100 Emp.
First aid manual	1	1
Scissors 5 1/2"	1	1
Tweezers	1	1
Assorted safety pins (12)	1	1
Plastic adhesive strips 3/4" x 3" sterile	-	25
Plastic adhesive strips 1" x 3" sterile	25	25
Gauze pad sterile 4" x 4"	5	24
Gauze bandage 3" x 10 yds.	-	4
Gauze bandage 2" x 10 yds.	1	-
Pressure bandage 4" sterile	2	4
Triangular bandage	2	6
Adhesive tape 1" x 10 yds.	1	2
Eye pad oval sterile	2	4
Peroxide 100 ml.	1	1
P.E.G. water soluble burn ointment 65 g.	1	1
Latex gloves (1 pair)	1	1
Emersafe pocket mask	1	1
Cotton tipped applicators 3" (100)	1	1
Hand cleansers	24	36
Tongue depressors	2	6

Model No.	No. of Employees	Box Dimensions W" x H" x D"	Unit/Box	Each
PLASTIC				
SD790	1 - 9	10 x 7 x 3	16	\$29.74
SD791	10 - 100	13.5 x 9.5 x 3	36	57.51
METAL				
SD792	1 - 9	7 x 10 x 3	16	\$43.55
SD793	10 - 100	13.5 x 9.5 x 3	36	65.83
BULK REFILLS				
SD794	For 1 - 9 employees			\$26.13
SD795	For 10-100 employees			41.82

NEWFOUNDLAND & LABRADOR FIRST AID KITS

New!

Component	Contents		
Product Description	1 - 5 Emp.	6 - 14 Emp.	15 - 200 Emp.
First Aid manual	1	1	1
Accident record book	1	1	1
Instrument kit in unit box	1	1	1
		(12) pack safety pins	
		(1) splinter tweezers	
		(1) pair scissors	
Pressure bandage, 4" sterile	2	2	6
Plastic strips, 1" x 3" sterile	12	16	32
Gauze pad sterile, 3" x 3"	12	16	32
Triangular bandage	4	6	6
Adhesive tape 1" x 5 yds.	-	1	2
Tubular dressing w/applicator	-	-	1
Fingertips large sterile	-	-	10
Knuckle bands sterile	-	-	10
Peroxide 100 ml.	1	1	1
Adhesive tape 1/2" x 5 yds.	1	-	-
Pair latex gloves	1	1	1

Model No.	No. of Employees	Box Dimensions W" x H" x D"	Unit/Box	Each
PLASTIC				
SD796	1 - 5	7.5 x 5 x 3.5	10	\$15.61
SD797	6 - 14	10 x 7 x 3	16	20.87
SD798	15 - 200	10 x 10 x 3	24	45.27
METAL				
SD799	1 - 5	7.5 x 5 x 3	10	\$27.85
SD800	6 - 14	7 x 10 x 3	16	33.11
SD801	15 - 200	10 x 10 x 3	24	50.53
BULK REFILLS				
SD802	For 1 - 5 employees			\$12.16
SD803	For 6 - 14 employees			15.61
SD804	For 15 - 200 employees			29.58

NORTHWEST TERRITORIES FIRST AID KITS

New!

Optional items not included in kits, should be ordered separately.

Component	Contents		
Product Description	Kit #1	Kit #2	Kit
First Aid manual	1	1	1
Accident record book	1	1	1
Latex gloves large (1 pair)	5	5	5
Instant cold pack	-	-	3
Emersafe pocket mask / one way valve	2	2	1
Fabric adhesive strips 3/4" x 3" sterile	50	100	100
Fabric adhesive strips 1" x 3" sterile	50	100	100
Gauze pad 2" x 2" sterile	-	12	12
Gauze pad 3" x 3" sterile	6	6	54
Pressure bandage 2" sterile	-	-	6
Pressure bandage 3" sterile	-	-	6
Pressure bandage 4" sterile	1	1	6
Field dressing 6" sterile	-	4	-
Pressure bandage 6" sterile	-	5	-
Combine pad 7 1/2" x 8" sterile	-	-	6
Combine pad 8" x 10" sterile	1	5	5
Eye pad oval sterile	2	6	6
Double adhesive strips for eye pads	2	3	6
Elastic bandage 3" x 5 yds.	1	3	6
Elastic pressure bandage 6" sterile	1	1	1
Gauze bandage 2" x 5 yds.	6	10	10
Gauze bandage 1" x 10 yds.	-	1	1
Adhesive tape 1" x 5 yds.	1	1	2
Esmarch bandage 1 box	-	-	2
Safety pins assorted	12	12	12
Antiseptic sachet Benzalkonium	6	12	12
Antiseptic green soap 50 ml.	-	-	1
Eye wash 8 oz. sterile	-	-	1
Eye dropper	-	-	1
Eye bath	-	-	1
Eye shield	-	-	2
Tongue depressor I.W.	-	-	12
Tweezers 3 1/2"	1	1	1
X-line splinter tweezers 4.5"	-	-	1
Scissor angled lister	1	1	1
Wire splint 3 5/8" x 24"	-	1	2
Scrub (nail) brush	-	1	1
Kidney basin stainless steel	-	-	1
Steri strip skin closure 1/4" x 3"	-	-	5
Triangular bandage	2	3	12
Ammonia inhalants	-	-	20
Burn Free dressing	-	12	-
OPTIONAL ITEMS			
*Blanket, 100% wool	-	-	3
*Wood splints (set of 6)	-	-	1
*Burn Free emergency burn trauma kit	-	-	1
*Collapsible stretcher	-	-	1

Model No.	No. of Kits	Box Dimensions L" x W" x D"	Unit/Box	Each
PLASTIC				
SD805	#1	10 x 10 x 3	24	\$47.00
METAL				
SD806	#1	10 x 10 x 3	24	\$ 52.26
SD807	#2	15.5 x 12 x 4.5	-	124.00
SD808	#3	14.5 x 16.5 x 6.5	-	195.00
BULK REFILLS				
SD809	For kit #1			\$ 31.31
SD810	For kit #2			95.99
SD811	For kit #3			148.00

OPTIONAL ITEMS

Model No.	Description	Each
SE082	Blanket, 100% wool, 54" x 90"	\$ 98.01
SE077	Wood splints (set of 6 assorted)	3.83
SD857	Burn Free burn trauma kit	197.00
SC408	Collapsible stretcher	213.00

Blanket: 100% red wool. 54" x 90".
 Wooden splints: Sets of six assorted sizes; 2 of each: 2" x 8", 3" x 10", and 3" x 12".
 Collapsible stretcher: Fibre reinforced vinyl, fire retardant with a load capacity of 400 lbs. In carrying case.

Cost Estimates

Scenario 1										Scenario 2				
Total Replacement										Water & Sewer for Various Lines				
Start AV	End AV	W/M Length (m)	S/M Length (m)	W & S (m)	W Only (m)	S Only (m)	Unit Cost (\$/m)	Extension (\$)	W & S (m)	W Only (m)	S Only (m)	Unit Cost (\$/m)	Extension (\$)	
WTP														
2	205.1	205.1	205.1	205.1			\$1,927	\$395,228					\$0	
3	118.3	118.3	118.3	118.3			\$1,927	\$227,964					\$0	
4	93.3				93.3		\$1,717	\$160,196					\$0	
5	86.6			86.6			\$1,927	\$166,878	86.6			\$1,927	\$166,878	
6	41.5			41.5			\$1,927	\$79,971	41.5			\$1,927	\$79,971	
7	41.5			41.5			\$1,927	\$79,971	41.5			\$1,927	\$79,971	
8	22.9			22.9			\$1,927	\$44,128	22.9			\$1,927	\$44,128	
9	29.6			29.6			\$1,927	\$57,039	29.6			\$1,927	\$57,039	
10	46			46			\$1,927	\$88,642	46			\$1,927	\$88,642	
11	83.8			83.8			\$1,927	\$161,483	83.8			\$1,927	\$161,483	
12	78.6			78.6			\$1,927	\$151,452					\$0	
27	86			86			\$1,927	\$165,722					\$0	
28	69.2				69.2		\$1,717	\$118,816					\$0	
8	91.1			91.1			\$1,927	\$175,550					\$0	
21	70.7			70.7			\$1,927	\$136,239					\$0	
30	41.8			41.8			\$1,927	\$80,549	41.8			\$1,927	\$80,549	
29	60.7			60.7			\$1,927	\$116,969	60.7			\$1,927	\$116,969	
6	66.8			66.8			\$1,927	\$128,724	66.8			\$1,927	\$128,724	
11	91.1			91.1		91.1	\$1,542	\$140,476					\$0	
32	91.3			91.3		91.3	\$1,542	\$140,785					\$0	
33	88.1			88.1		88.1	\$1,542	\$135,850					\$0	
34	39.8			39.8		39.8	\$1,542	\$61,372					\$0	
35	60			60		60	\$1,542	\$92,520					\$0	
Stage 1a														
Total		1333.5	323.4	1541.3	162.5	370.3		\$3,106,532	521.2	0	0		\$1,004,352	
Stage 1b														
22	105.2			105.2			\$1,927	\$202,720					\$0	
25	98.3			98.3			\$1,927	\$189,424					\$0	
21	48.2			48.2			\$1,927	\$92,881					\$0	
20	76.45			76.45			\$1,927	\$147,319					\$0	
19	24.2				24.2		\$1,717	\$41,551					\$0	
18	50.9				50.9		\$1,717	\$87,395					\$0	
17	80.4			80.4		80.4	\$1,542	\$123,977					\$0	
16	83.2			83.2		83.2	\$1,542	\$128,294					\$0	
14	78.2			78.2		78.2	\$1,542	\$120,584					\$0	
13	23.3			23.3		23.3	\$1,542	\$35,929					\$0	
13	98.2			98.2		98.2	\$1,542	\$151,424					\$0	
23	70.3			70.3		70.3	\$1,542	\$108,403					\$0	
Stage 1b														
Total		633.35	203.5	328.15	75.1	433.6		\$1,429,903					\$0	
Totals		1966.85	526.9	1869.45	237.6	803.9		\$4,536,435	521.2	0	0		\$1,004,352	

Unit Costs (\$/m)		
W&S Replacement	\$1,927	
Water Only	na	
Sewer Only	na	

Unit Costs (\$/m)		
W&S Replacement	\$1,927	
Water Only	na	
Sewer Only	na	

Cost Estimates

Scenario 3					Scenario 4				
Water Only with Min. Cover Various Pipes					Replace Sewer Main where Poor Flow				
Start AV	End AV	W/M Length (m)	S/M Length 150 mm	W & S (m)	W Only (m)	S Only (m)	Unit Cost (\$/m)	Extension (\$)	Extension (\$)
WTP	2	205.1	205.1					\$0	\$0
3	3	118.3	118.3					\$0	\$0
4	4	93.3						\$0	\$0
5	5	86.6		86.6				\$134,230	\$0
6	6	41.5		41.5				\$64,325	\$0
7	7	41.5		41.5				\$64,325	\$0
8	8	22.9		22.9				\$35,495	\$0
9	9	29.6		29.6				\$45,880	\$0
10	10	46		46				\$71,300	\$0
11	11	83.8		83.8				\$129,890	\$0
12	12	78.6		78.6				\$0	\$60,601
13	13	86		86				\$0	\$0
14	14	69.2						\$0	\$0
15	15	91.1		91.1				\$0	\$0
16	16	70.7		70.7				\$0	\$0
17	17	41.8		41.8				\$64,790	\$0
18	18	60.7		60.7				\$94,085	\$0
19	19	66.8		66.8				\$103,540	\$0
20	20							\$0	\$0
21	21							\$0	\$0
22	22							\$0	\$0
23	23							\$0	\$0
24	24							\$0	\$0
25	25							\$0	\$0
26	26							\$0	\$0
27	27							\$0	\$0
28	28							\$0	\$0
29	29							\$0	\$0
30	30							\$0	\$0
31	31							\$0	\$0
32	32							\$0	\$0
33	33							\$0	\$0
34	34							\$0	\$0
35	35							\$0	\$0
Stage 1a	STP								
Total		1333.5	323.4	0	521.2	0		\$807,860	\$60,601
Stage 1b									
22	22	105.2	105.2					\$0	\$0
23	23	98.3	98.3					\$0	\$0
24	24	48.2						\$0	\$0
25	25	76.45						\$0	\$0
26	26	24.2						\$0	\$0
27	27	50.9						\$0	\$0
28	28	80.4						\$0	\$0
29	29	83.2						\$0	\$0
30	30	78.2						\$0	\$0
31	31	23.3						\$0	\$0
32	32	98.2						\$0	\$0
33	33	70.3						\$0	\$0
34	34							\$0	\$0
35	35							\$0	\$0
Stage 1b									
Total		633.35	203.5	0	521.2	0		\$807,860	\$165,495
Totals		1966.85	526.9	0	521.2	0		\$807,860	\$226,096

Unit Costs (\$/m)		
W&S Replacement	na	
Water Only	\$1,550	
Sewer Only	na	

Unit Costs (\$/m)		
W&S Replacement	na	
Water Only	na	
Sewer Only	\$771	

Cost Estimates

Scenario 5

Replace W & S Mains from AV20 to AV22

Start AV	End AV	W/M Length (m) 200 mm	S/M Length (m) 150 mm	W & S (m)	W Only (m)	S Only (m)	Unit Cost (\$/m)	Extension (\$)
WTP	2	205.1	205.1	205.1				\$0
3	3	118.3	118.3	118.3				\$0
4	4	93.3						\$0
5	5	86.6						\$0
6	6	41.5						\$0
7	7	41.5						\$0
8	8	22.9						\$0
9	9	29.6						\$0
10	10	46						\$0
11	11	83.8						\$0
12	12	78.6						\$0
13	13	86						\$0
14	14	69.2						\$0
15	15	91.1						\$0
16	16	70.7						\$0
17	17	41.8						\$0
18	18	60.7						\$0
19	19	66.8						\$0
20	20	91.1						\$0
21	21	91.3						\$0
22	22	88.1						\$0
23	23	39.8						\$0
24	24	60						\$0
STP	STP							\$0
Stage 1a Total		1333.5	323.4	1541.3	0	0	0	\$0
Stage 1b	20		105.2	105.2			\$1,927	\$202,720
22	23		98.3					\$0
25	21		48.2					\$0
21	20	48.2						\$0
20	19	76.45						\$0
19	18	24.2						\$0
18	17	50.9						\$0
17	16	80.4						\$0
16	14	83.2						\$0
14	13	78.2						\$0
13	12	23.3						\$0
13	23	98.2						\$0
23	21	70.3						\$0
Stage 1b Total		633.35	203.5	761.75	0	0		\$202,720
Totals		1966.85	526.9	2303.05	0	0	0	\$202,720

Unit Costs (\$/m)		
W&S Replacement	\$1,927	
Water Only	na	
Sewer Only	na	

From: Joe Hidalgo, P. Eng.
Project Management
Department of Public Works and Services
Fax Number: (819) 645-2116
Phone Number: (819) 645-5013
867

Date: Oct. 23, 1998

TO: KIRK GUNTHER, P. ENG.
Company: DILLON CONSULTING LTD. YELLOWKNIFE, NT
Fax Number: (867) 873-3328

Total Number of Pages Including Cover: 7

Your Reference: Unit Prices for Hume Subdivision.

Message:

Here are the prices that you were requesting.
Our plane was delayed, we almost flew over
Rankin Inlet because of bad weather here as
always.

Joe

The Original of This Fax Will Not Be Sent Unless Requested

Government of the Northwest Territories, Rankin Inlet, NT, X0C 0G0

PAKISTAN SUBMISSION
RAJAKHIL INLET
Phase 3, 1998

LIST OF UNIT PRICES
UNIT PRICE CONTRACT
SCHEDULE OF QUANTITIES AND
UNIT PRICE TABLE

APPENDIX D
Page 1 of 8

CONSULTANT

ITEM NO	DESCRIPTION	PAYMENT CLAUSE	EST. QUANTITY	UNIT	UNIT PRICE	EXTENSION	RTL Tender UNIT PRICE	EXTENSION	Sanajil Tender UNIT PRICE	EXTENSION	Kudlik Tender UNIT PRICE	EXTENSION
A1	Part A - Main & Services (Sis. 7 & 8) Rock Excavation II Req'd	02211 1.61	100	cu m	350	\$35,000	\$140.00	\$14,000.00			170.00	\$17,000.00
A2	Preliminary Inspection, II Req'd	02211 1.62	1	L.S.	\$1,000	\$1,000	\$8,500.00	\$8,500.00			\$3,000.00	\$3,000.00
A3	Also / Demolition Rock Excavation II Req'd	02211 1.63	1	L.S.	\$4,000	\$4,000	\$4,800.00	\$4,800.00	\$5,000.00	\$5,000.00	\$25,000.00	\$25,000.00
A4	Rock Localizing/Ventilation	02211 1.64	640	m	\$	\$3,700	\$15.00	\$9,600.00	\$204.00	\$124,640.00	\$15.50	\$1,520.00
A5	Install 200mm dia Watermain	02666 1.31	660	m	165	\$108,900	\$450.00	\$297,000.00	\$247.00	\$164,550.00	\$165.00	\$108,900.00
A6	Common Trench	02666 1.32	35	m	165	\$5,775	\$450.00	\$15,750.00	\$204.00	\$7,104.00	\$330.00	\$11,550.00
A7	Install 200mm dia Sanitary Sewer	02667 1.31	361	m	165	\$59,565	\$450.00	\$162,850.00	\$204.00	\$73,604.00	\$165.00	\$59,565.00
A8	Common Trench	02667 1.31	273	m	165	\$45,045	\$450.00	\$122,850.00	\$204.00	\$55,832.00	\$165.00	\$45,045.00
A9	Install 150mm dia Sanitary Sewer	02667 1.32	5	m	165	\$825	\$450.00	\$2,250.00	\$408.00	\$2,040.00	\$329.00	\$1,645.00
A10	Supply 200mm HDPE Sewer/Water	02667 1.33	1,046	m	210	\$219,660	\$128.00	\$133,888.00	\$175.15	\$183,205.90	\$127.60	\$133,169.60
A11	Supply 150mm HDPE Sewer	02667 1.33	218	m	135	\$29,430	\$99.00	\$21,522.00	\$121.70	\$26,532.60	\$96.80	\$20,910.40
A12	Supply/Access Vaults	02725 1.41	1	L.S.	40000	\$40,000	\$37,000.00	\$37,000.00	\$39,447.45	\$39,447.45	\$34,721.00	\$34,721.00
A13	Supply & Install Ladders on Ans 94-1 to 04-3 and 95-1 to 95-17	02725 1.42	7	Each	9000	\$63,000	\$10,000.00	\$70,000.00	\$7,142.86	\$50,000.02	\$6,600.00	\$46,200.00
A14	Install Access Vaults	02725 1.43	100	cu m	10	\$1,000	\$116.50	\$11,650.00	\$10.00	\$1,000.00	\$11.00	\$1,100.00
A15	Excavation (if req'd)	02721 1.42	400	cu m	15	\$6,000	\$58.00	\$23,200.00	\$16.00	\$6,400.00	\$27.00	\$10,710.00
A16	Granular Backfill (Load Haul and Place)	02721 1.45	200	cu m	50	\$10,000	\$70.00	\$14,000.00	\$16.00	\$3,200.00	\$22.00	\$4,400.00
A17	Crushed Road Gravel (Supply and Install)	02721 1.46	1	L.S.	250000	\$250,000	\$30,000.00	\$30,000.00	\$208,850.00	\$208,850.00	\$188,850.00	\$188,850.00
A18	Mobilization/Demobilization	01500 2.4	1	L.S.	250000	\$250,000	\$30,000.00	\$30,000.00	\$208,850.00	\$208,850.00	\$188,850.00	\$188,850.00
Subtotal Part A - Page 1						\$1,107,650		\$1,107,650.00		\$1,019,945.16		\$1,262,219.33

LIST OF UNIT PRICES
UNIT PRICE CONTRACT
SCHEDULE OF QUANTITIES AND
UNIT PRICE TABLE

APPENDIX D
Page 2 of 8

ITEM NO	DESCRIPTION	PAYMENT CLAUSE	EST. QUANTITY	UNIT	UNIT PRICE	EXTENSION
A19	Part A - Main & Services (Sis. 7 & 8) Install 100mm dia Water Service Caster	02665 1.31	690	m	200	\$138,000
A20	Install 150mm dia Water Service Caster	02665 1.31	40	m	250	\$10,000
A21	Install 100mm dia and 150mm dia water service pipes	02665	650	m	200	\$130,000

FD 111

CONSULTANT

RTL

SAN.

KUDLIK

A27	Install 150mm dia Sewer Service	1.3.1	40	m	200	\$9,000	\$315.00	\$12,600.00	\$219.04	\$8,761.60	\$143.00	\$5,720.00
A23	Supply 25mm Water Service Pipe	1.3.1	2,014	m	2	\$4,140	\$1.00	\$2,074.00	\$1.21	\$2,509.56	\$1.87	\$3,878.38
A24	Supply 50mm Water Service Pipe	1.3.2	40	m	10	\$400	\$4.00	\$160.00	\$5.97	\$238.80	\$2.90	\$116.00
A25	Supply 100mm Water Service canter pipe	1.3.2	600	m	80	\$55,200	\$51.00	\$35,190.00	\$353.55	\$24,394.90	\$52.80	\$36,432.00
A26	Supply 150mm Water Service canter pipe	1.3.2	40	m	100	\$4,000	\$71.00	\$2,840.00	\$104.00	\$4,160.00	\$71.50	\$2,860.00
A27	Supply 100mm HDPE Sewer Service	1.3.2	600	m	80	\$55,200	\$51.00	\$35,190.00	\$301.45	\$208,000.50	\$52.80	\$16,432.00
A28	Supply 150mm HDPE Sewer Service	1.3.2	40	m	100	\$4,000	\$71.00	\$2,840.00	\$104.00	\$4,160.00	\$71.50	\$2,860.00
A29	Supply and Install Connection to services in existing houses	1.3.2	22	ea	5000	\$110,000	\$3,990.00	\$87,780.00	\$3,701.60	\$59,435.20	\$11,000.00	\$742,000.00
Subtotal Part A - Page 2						\$1,619,708		\$2,328,134.00		\$842,751.94		\$1,786,295.71
Total Part A						\$1,619,708		\$2,328,134.00		\$842,751.94		\$1,786,295.71
Part B - Services for Sits 4 & 5 (Provisional)												
B30	Install 100mm dia Water Service	1.3.1	885	m	200	\$177,000	\$390.00	\$169,150.00	\$373.00	\$153,105.00	\$143.00	\$126,555.00
B31	Supply 25mm Water Service Pipe	1.3.1	885	m	200	\$177,000	\$390.00	\$169,150.00	\$373.00	\$153,105.00	\$143.00	\$126,555.00
B32	Supply 50mm Water Service Pipe	1.3.2	2,014	m	2	\$4,140	\$1.00	\$2,074.00	\$1.26	\$2,562.84	\$1.87	\$3,803.58
B33	Supply 100mm Water Service canter pipe	1.3.2	885	m	80	\$10,600	\$51.00	\$45,135.00	\$222.31	\$196,744.35	\$52.80	\$46,728.00
B34	Supply 100mm HDPE Sewer Service	1.3.2	885	m	80	\$10,600	\$51.00	\$45,135.00	\$60.78	\$53,790.30	\$52.80	\$46,728.00
B35	Supply and Install Connection to services in existing houses	1.3.2	33	ea	5000	\$165,000	\$11,000.00	\$363,000.00	\$3,601.60	\$125,452.80	\$8,927.50	\$291,927.50
Total Part B - Services (Provisional)						\$564,658.00		\$791,604.00		\$484,760.29		\$645,297.00
Total Summary												
Total Part A - Mains & Services (Sheets 7 & 8)						\$1,675,708.00		\$2,328,134.00		\$1,527,197.10		\$1,791,595.71
Total Part B - Services (Sheets 4 & 5) (Provisional)						\$564,658.00		\$791,604.00		\$484,760.29		\$645,297.00
Total Tender						\$2,240,366.00		\$3,119,738.00		\$2,660,957.39		\$2,436,892.71
GST						\$160,617.62		\$218,391.66		\$187,457.02		\$250,863.27
Total Tender (including GST)						\$2,400,983.62		\$3,338,129.66		\$2,848,414.41		\$2,687,755.98

PA 3

177,600,000

CELL SCHEDULE

NAUK SUBDIVISION
RAKSHI LET
Phase 4, 1999

LIST OF UNIT PRICES
UNIT PRICE CONTRACT
SCHEDULE OF QUANTITIES AND
UNIT PRICE TABLE

APPENDIX D

UNSCAET
Page 3 of 6

ITEM NO	DESCRIPTION	PAYMENT CLAUSE	EST. QUANTITY	UNIT	UNIT PRICE	EXTENSION	RTL Tender UNIT PRICE	EXT.	Sanajit Tender UNIT PRICE	EXTENSION	Kudlik Tender UNIT PRICE	EXTENSION
Part A - Mains & Services (Sis. 2 & 3)												
A1	Rock Excavation (If Req'd)	02211	100	cum	180	\$18,000	\$140.00	\$14,000.00			\$77.00	\$7,700.00
A2	Handed Inspection (If Req'd)	161 02211 162	1	L.S.	\$1,000	\$1,000	\$8,500.00	\$8,500.00			\$110.00	\$110.00
A3	Hand / Denolator Rock Excavation (If Req'd)	02211	1	L.S.	4,000	\$4,000	\$4,800.00	\$4,800.00	\$5,000.00	\$5,000.00	\$5,500.00	\$5,500.00
A4	Rock Locality Verification	163 02211 164	620	m	1	\$1,200	\$15.00	\$9,600.00			\$5.50	\$3,520.00
A5	Install 200mm dia Watermain	02666	806	m	165	\$132,960	\$450.00	\$362,700.00	\$204.00	\$164,424.00	\$165.00	\$132,990.00
A6	Corrosion Trench	131 02667	703	m	165	\$115,995	\$450.00	\$316,350.00	\$204.00	\$143,412.00	\$165.00	\$115,995.00
A7	Install 200mm dia Sanitary Sewer	131 02667	104	m	165	\$17,160	\$450.00	\$46,800.00	\$204.00	\$21,216.00	\$165.00	\$17,160.00
A8	Install 150mm dia Sanitary Sewer	131 02667	228	m	165	\$37,870	\$450.00	\$102,600.00	\$407.58	\$92,928.24	\$330.00	\$75,240.00
A9	Common Trench	132 02667	1,737	m	210	\$364,770	\$132.00	\$229,284.00	\$165.24	\$287,021.89	\$127.00	\$220,539.00
A10	Single Main	132 02667	104	m	135	\$14,040	\$102.00	\$10,608.00	\$133.62	\$13,896.48	\$96.80	\$10,067.20
A11	Supply 150mm HDPE Sewer	133 02725	1	L.S.	40000	\$40,000	\$43,000.00	\$43,000.00	\$45,498.16	\$45,498.16	\$47,631.10	\$47,631.10
A12	Supply Access Vaults	141 02725	1	L.S.	40000	\$40,000	\$37,000.00	\$37,000.00	\$39,351.58	\$39,351.58	\$39,320.60	\$39,320.60
A13	AV 97-24	142 02721	1	L.S.	40000	\$40,000	\$38,000.00	\$38,000.00	\$40,190.83	\$40,190.83	\$46,777.50	\$46,777.50
A14	AV 97-26	142 02721	1	L.S.	40000	\$40,000	\$41,000.00	\$41,000.00	\$43,512.44	\$43,512.44	\$46,514.60	\$46,514.60
A15	AV 97-27	142 02721	1	L.S.	40000	\$40,000	\$47,000.00	\$47,000.00	\$50,480.72	\$50,480.72	\$53,302.70	\$53,302.70
A16	AV 97-28	142 02721	1	L.S.	40000	\$40,000	\$37,000.00	\$37,000.00	\$39,125.64	\$39,125.64	\$39,327.20	\$39,327.20
A17	AV 97-29	142 02721	1	L.S.	40000	\$40,000	\$38,000.00	\$38,000.00	\$39,851.64	\$39,851.64	\$39,491.10	\$39,491.10
A18	AV 97-30	142 02721	1	L.S.	40000	\$40,000	\$37,000.00	\$37,000.00	\$39,328.92	\$39,328.92	\$41,661.40	\$41,661.40
A19	AV 97-31	142 02721	1	L.S.	40000	\$40,000	\$40,000.00	\$40,000.00	\$41,477.22	\$41,477.22	\$41,948.50	\$41,948.50
A20	AV 97-32	142 02721	1	L.S.	40000	\$40,000	\$40,000.00	\$40,000.00	\$33,669.42	\$33,669.42	\$31,335.70	\$31,335.70
A21	AV 97-33	142 02721	1	L.S.	40000	\$40,000	\$33,000.00	\$33,000.00	\$33,831.12	\$33,831.12	\$31,644.80	\$31,644.80
A22	AV 97-34	142 02721	1	L.S.	40000	\$40,000	\$10,000.00	\$10,000.00	\$7,000.00	\$7,000.00	\$6,600.00	\$6,600.00
A23	Install Access Vaults	02725	11	Each	90000	\$99,000	\$16.50	\$1,650.00	\$10.00	\$1,000.00	\$11.00	\$1,100.00
A24	Over-excavation (If req'd)	143 02721	100	cum	10	\$1,000	\$58.00	\$5,800.00	\$16.00	\$1,600.00	\$22.00	\$2,200.00
A25	Granular Backfill (Load 1 and 11/2)	143 02721	240	cum	15	\$1,800	\$70.00	\$16,800.00	\$16.00	\$3,840.00	\$22.00	\$5,280.00
A26	Crushed Road Gravel (Supply and Install)	146 01500	240	cum	50	\$12,000	\$141,000.00	\$141,000.00	\$137,600.00	\$137,600.00	\$247,930.66	\$247,930.66
A27	Mobile/Demolition	24	1	L.S.			\$110,000.00	\$110,000.00				
Subtotal Part A - Page 1						\$1,254,375		\$1,811,612.00		\$1,397,496.34		\$1,390,015.05

NAUK SUBDIVISION
RAKSHI LET
Phase 4, 1999

LIST OF UNIT PRICES
UNIT PRICE CONTRACT
SCHEDULE OF QUANTITIES AND
UNIT PRICE TABLE

APPENDIX D

UNSCAET
Page 4 of 6

ITEM NO	DESCRIPTION	PAYMENT CLAUSE	EST. QUANTITY	UNIT	UNIT PRICE	EXTENSION
Part A - Mains & Services (Sis. 2 & 3)						
A10	Install 100mm dia Water Service Conduit	02665 131	610	m	200	\$122,000
Pipe 100mm dia water service pipes						\$133,614.40
						\$143.03
						\$102,233.00

CONSULTANT R.T.L.

S.A.N.

KODAK

A20	Install 150mm dia Water Service Carrier Pipe c/w 1.25mm dia. and 1.50mm dia water service	07665	140	m	250	\$35,000	\$315.00	\$44,100.00	\$219.04	\$30,665.60	\$143.00	\$20,020.00
A21	Install 100mm dia Sewer Service	02665	610	m	200	\$122,000	\$315.00	\$192,150.00	\$219.04	\$133,614.40	\$143.00	\$87,230.00
A22	Install 150mm dia Sewer Service	07665	140	m	200	\$28,000	\$315.00	\$64,100.00	\$219.04	\$30,565.60	\$143.00	\$20,020.00
A23	Supply 25mm Water Service Pipe	07665	1,530	m	2	\$3,066	\$1.00	\$1,533.00	\$1.23	\$1,885.59	\$1.97	\$2,865.71
A24	Supply 150mm Water Service Pipe	02665	140	m	10	\$1,000	\$4.00	\$560.00	\$4.58	\$641.20	\$2.90	\$406.00
A25	Supply 100mm Water Service Carrier Pipe	02665	610	m	80	\$40,800	\$51.00	\$31,110.00	\$755.09	\$156,086.80	\$52.70	\$32,208.00
A26	Supply 150mm Water Service Carrier Pipe	02665	140	m	100	\$14,000	\$71.00	\$9,940.00	\$89.93	\$12,590.20	\$71.50	\$10,010.00
A27	Supply 100mm 1/8" S.C. Sewer Service	02665	610	m	80	\$40,800	\$51.00	\$31,110.00	\$266.47	\$162,546.70	\$52.00	\$32,208.00
A28	Supply 150mm HOPE Sewer Service	02665	140	m	100	\$14,000	\$71.00	\$9,940.00	\$89.93	\$12,590.20	\$71.50	\$10,010.00
A29	Supply and Install Connection To services in existing boxes	07665	28	ea	3000	\$140,000	\$3,990.00	\$111,720.00	\$3,251.60	\$91,044.80	\$8,537.50	\$250,250.00
Subtotal Part A - Page 2						\$577,966.00		\$668,413.00		\$785,945.49		\$552,458.71
Total Tender						\$1,831,441.00		\$2,460,025.00		\$2,163,441.83		\$1,932,473.77
GST							7% X "1" = "J"	\$173,601.75		\$151,440.93		\$135,273.16
Total Tender (including GST)							"1" + "J" =	\$2,653,676.75		\$2,314,882.76		\$2,067,746.93

PA. 4

difference

207,125.00

KUDUK

SAW

RTG

CONSULTANT

NUVUK SUBDIVISION
RANKIN INLET
Phase 5, 2000

LIST OF UNIT PRICES
UNIT PRICE CONTRACT
SCHEDULE OF QUANTITIES AND
UNIT PRICE TABLE

APPENDIX D
Page 5 of 6

ITEM NO.	DESCRIPTION	PAYMENT CLAUSE	EST. QUANTITY	UNIT	UNIT PRICE	EXTENSION	UNIT PRICE	EXTENSION	UNIT PRICE	EXTENSION	UNIT PRICE	EXTENSION	EXTENSION
A1	Part A - Mains & Services (Sta. 1 & 6) Rock Excavation, If Req'd	02111	100	cu m	\$40	\$4,000	140.00	14000.00			17.00	7700.00	7700.00
A2		02711	1	L.S.	\$1,000	\$1,000	8500.00	8500.00			550.00	550.00	550.00
A3		02111	1	L.S.	\$4,000	\$4,000	4800.00	4800.00	5000.00	5000.00	5500.00	5500.00	5500.00
A4	Rock Locating/Verification	02711	6.69	m	\$3	\$3,200	15.00	9000.00			5.50	3520.00	3520.00
A5	Install 200mm dia. Watermain	02667	750	m	165	\$123,750	450.00	337500.00	204.00	153000.00	165.00	123750.00	123750.00
A7	Common Trench	1.3.1	225	m	165	\$37,125	450.00	101250.00	204.00	45900.00	165.00	37125.00	37125.00
A8	Install 150mm dia. Sanitary Sewer	02667	438	m	165	\$72,270	450.00	197100.00	204.00	89352.00	165.00	72270.00	72270.00
A9	Common Trench	1.3.1	52	m	165	\$8,580	450.00	23400.00	408.00	21216.00	170.00	17160.00	17160.00
A10	Install 150mm dia. Sanitary Sewer	02667	972	m	210	\$204,120	132.00	128304.00	175.00	170391.60	127.60	124027.00	124027.00
A11	Supply 200mm HDPE Sewer/Water	02855/02867	490	m	135	\$66,150	102.00	49980.00	130.95	64165.50	96.80	47432.00	47432.00
A12	Supply Access Vaults	1.3.3	1	L.S.	40000	\$40,000	39000.00	39000.00	40810.65	40810.65	37739.90	37739.90	37739.90
A13	- AV 00-35	02723	1	L.S.	40000	\$40,000	41000.00	41000.00	42698.91	42698.91	40540.50	40540.50	40540.50
A14	- AV 00-36	1.4.1	1	L.S.	40000	\$40,000	46000.00	46000.00	48288.89	48288.89	52707.00	52707.00	52707.00
A15	- AV 00-37		1	L.S.	40000	\$40,000	35000.00	35000.00	36721.29	36721.29	39552.70	39552.70	39552.70
A16	- AV 00-38		1	L.S.	40000	\$40,000	36000.00	36000.00	37495.69	37495.69	35491.50	35491.50	35491.50
A17	- AV 00-39		1	L.S.	40000	\$40,000	46000.00	46000.00	48288.89	48288.89	49868.50	49868.50	49868.50
A18	- AV 00-40		1	L.S.	40000	\$40,000	39000.00	39000.00	41035.05	41035.05	43484.10	43484.10	43484.10
A19	- AV 00-41		1	Each	9000	\$81,000	10000.00	70000.00	7000.00	49030.00	6600.00	46700.00	46700.00
A20	Install Access Vaults	02725	100	cu m	10	\$1,000	16.50	1650.00	10.00	1000.00	11.00	1100.00	1100.00
A21	Open excavation (if req'd)	02221	240	cu m	15	\$3,600	58.00	13920.00	16.00	3840.00	16.50	3960.00	3960.00
A22	Granular Backfill (Lead Hind and Place)	02721	240	cu m	50	\$12,000	70.00	16800.00	16.00	3840.00	22.00	5280.00	5280.00
A23	(If required)	02221	1	L.S.	\$250,000	\$250,000	124300.00	124300.00	32000.00	32000.00	195637.52	195637.52	195637.52
A24	Crushed Road Grade (Supply and Install)	1.4.6	1	L.S.	\$250,000	\$250,000	124300.00	124300.00	32000.00	32000.00	195637.52	195637.52	195637.52
A25	(If required)	01500	2.4										
A26	Material/Item/Value	2.4											
A27	Material/Item/Value	2.4											
A28	Material/Item/Value	2.4											
A29	Material/Item/Value	2.4											
A30	Material/Item/Value	2.4											
A31	Material/Item/Value	2.4											
A32	Material/Item/Value	2.4											
A33	Material/Item/Value	2.4											
A34	Material/Item/Value	2.4											
A35	Material/Item/Value	2.4											
A36	Material/Item/Value	2.4											
A37	Material/Item/Value	2.4											
A38	Material/Item/Value	2.4											
A39	Material/Item/Value	2.4											
A40	Material/Item/Value	2.4											
A41	Material/Item/Value	2.4											
A42	Material/Item/Value	2.4											
A43	Material/Item/Value	2.4											
A44	Material/Item/Value	2.4											
A45	Material/Item/Value	2.4											
A46	Material/Item/Value	2.4											
A47	Material/Item/Value	2.4											
A48	Material/Item/Value	2.4											
A49	Material/Item/Value	2.4											
A50	Material/Item/Value	2.4											
A51	Material/Item/Value	2.4											
A52	Material/Item/Value	2.4											
A53	Material/Item/Value	2.4											
A54	Material/Item/Value	2.4											
A55	Material/Item/Value	2.4											
A56	Material/Item/Value	2.4											
A57	Material/Item/Value	2.4											
A58	Material/Item/Value	2.4											
A59	Material/Item/Value	2.4											
A60	Material/Item/Value	2.4											
A61	Material/Item/Value	2.4											
A62	Material/Item/Value	2.4											
A63	Material/Item/Value	2.4											
A64	Material/Item/Value	2.4											
A65	Material/Item/Value	2.4											
A66	Material/Item/Value	2.4											
A67	Material/Item/Value	2.4											
A68	Material/Item/Value	2.4											
A69	Material/Item/Value	2.4											
A70	Material/Item/Value	2.4											
A71	Material/Item/Value	2.4											
A72	Material/Item/Value	2.4											
A73	Material/Item/Value	2.4											
A74	Material/Item/Value	2.4											
A75	Material/Item/Value	2.4											
A76	Material/Item/Value	2.4											
A77	Material/Item/Value	2.4											
A78	Material/Item/Value	2.4											
A79	Material/Item/Value	2.4											
A80	Material/Item/Value	2.4											
A81	Material/Item/Value	2.4											
A82	Material/Item/Value	2.4											
A83	Material/Item/Value	2.4											
A84	Material/Item/Value	2.4											
A85	Material/Item/Value	2.4											
A86	Material/Item/Value	2.4											
A87	Material/Item/Value	2.4											
A88	Material/Item/Value	2.4											
A89	Material/Item/Value	2.4											
A90	Material/Item/Value	2.4											
A91	Material/Item/Value	2.4											
A92	Material/Item/Value	2.4											
A93	Material/Item/Value	2.4											
A94	Material/Item/Value	2.4											
A95	Material/Item/Value	2.4											
A96	Material/Item/Value	2.4											
A97	Material/Item/Value	2.4											
A98	Material/Item/Value	2.4											
A99	Material/Item/Value	2.4											
A100	Material/Item/Value	2.4											
A101	Material/Item/Value	2.4											
A102	Material/Item/Value	2.4											
A103	Material/Item/Value	2.4											
A104	Material/Item/Value	2.4											
A105	Material/Item/Value	2.4											
A106	Material/Item/Value	2.4											
A107	Material/Item/Value	2.4											
A108	Material/Item/Value	2.4											
A109	Material/Item/Value	2.4											
A110	Material/Item/Value	2.4											
A111	Material/Item/Value	2.4											
A112	Material/Item/Value	2.4											
A113	Material/Item/Value	2.4											
A114	Material/Item/Value	2.4											
A115	Material/Item/Value	2.4											
A116	Material/Item/Value	2.4											
A117	Material/Item/Value	2.4											
A118	Material/Item/Value	2.4											
A119	Material/Item/Value	2.4											
A120	Material/Item/Value	2.4											
A121	Material/Item/Value	2.4											
A122	Material/Item/Value	2.4											
A123	Material/Item/Value	2.4											
A124	Material/Item/Value	2.4											
A125	Material/Item/Value	2.4											
A126	Material/Item/Value	2.4											
A127	Material/Item/Value	2.4											
A128	Material/Item/Value	2.4											

	Q2665	420	m	200	\$84,000	315.00	132,500.00	219.00	91980.00	143.00	66060.00
A21 Install 100mm dia Sewer Service	1.3.1										
A22 Install 150mm dia Sewer Service	02685	250	m	200	\$50,000	315.00	78750.00	219.00	54750.00	143.00	35750.00
A23 Supply 25mm Water Service Pipe	1.3.1			2	\$2,850	1.00	1325.00	1.32	1749.00	1.87	2477.71
A24 Supply 50mm Water Service Pipe	1.3.2			10	\$2,500	4.00	1000.00	5.26	1315.00	2.90	725.61
A25 Supply 100mm Water Service carrier pipe	02685	420	m	80	\$33,600	51.00	21420.00	213.43	89640.60	52.80	22176.00
A26 Supply 150mm Water Service carrier pipe	1.3.2			100	\$23,000	71.00	17750.00	91.89	22972.50	71.50	17875.00
A27 Supply 100mm HDPE Sewer Service	02655	250	m	80	\$33,600	51.00	21420.00	216.78	91047.60	52.80	22176.00
A28 Supply 150mm HDPE Sewer Service	1.3.2			100	\$25,000	71.00	17750.00	222.19	55547.50	71.50	17875.00
A29 Supply and Initial Connection To services in existing squares	02655	24	ea	5000	\$120,000	3990.00	95760.00	3251.60	79038.40	8037.50	214500.00
Subtotal Part A - Page 2	1.3.2				\$522,850		\$558,535.00		\$633,270.60		\$489,474.71
Total Tender					\$1,660,645		\$1,981,679.00		\$1,586,774.07		\$1,404,021.26
GST					\$116,245		\$138,714.03		\$109,779.24		\$107,691.40
Total Tender (including GST)					\$1,776,890		\$2,120,343.03		\$1,696,554.11		\$1,511,707.71

TENDER SUMMARY

	\$ 3,338,119.66	\$ 2,789,444.41	\$ 2,611,767.01
"E"&"F"	\$ 32,455,078.62		
		\$ 2,653,828.75	\$ 2,657,746.21
"I"&"J"	\$ 31,939,641.87	\$ 2,314,882.16	
		\$ 1,678,054.11	\$ 1,587,002.71
"M"&"N"	\$ 1,776,890.15	\$ 6,782,381.28	\$ 6,267,416.75
	\$ 5,191,510.64	\$ 6,338,674.09	\$ 5,857,398.82
	\$ 5,786,552.00		
BIP			
LOCN	\$ 1,132,500.00	\$ 6,034,804.60	\$ 5,068,828.92
NORTHERN	\$ 3,770,742.47	\$ 60,000.00	\$ 112,149.55
OTHER	\$ 2,678,149.53	\$ 145,500.00	\$ 634,205.61
TOTAL	\$ 7,581,392.00	\$ 6,281,304.60	\$ 5,875,184.11
BIP Local	\$ (226,500.00)	\$ (1,706,960.92)	\$ (1,013,765.75)
BIP Norilsk	\$ (565,611.37)	\$ (9,000.00)	\$ (16,822.43)
Adjusted Tender (Excluding GST)	\$ 6,789,280.63	\$ 6,122,713.17	\$ 4,826,810.61
Adjusted Tender (Including GST)	\$ 7,264,530.27	\$ 5,481,303.09	\$ 5,164,687.31
Vaults	\$ 987,000.00	#REF!	\$ 758,340.00
Mains	\$ 675,366.00	#REF!	\$ 562,505.40
Services	\$ 243,152.00	#REF!	\$ 171,013.42
	\$ 1,905,518.00	#REF!	\$ 1,491,858.81

*** TOTAL PAGE.07 ***

COST ESTIMATES FOR RESOLUTE WATER AND SEWER CONSTRUCTION AND RETROFITTING

ASSUMPTIONS:

1. NO ROCK EXCAVATION WILL BE REQUIRED. THE BACKFILLED EXISTING TRENCH CAN BE EXCAVATED AND REUSED.
2. WHERE APPLICABLE REMOVAL OF EXISTING WATER/SEWER LINES WILL COST EXTRA.
3. LOCAL CONTRACTOR WILL BID ON THE JOB, THEREFORE MOB/DEMOb COST WILL BE LOCAL.

NOTE: ANY OTHER ASSUMPTIONS THAT ARE USED WILL BE NOTED IN ESTIMATE.

4. SERVICE LINES WILL BE REUSED, BUT SERVICE SADDLES WILL BE NEW

SCENARIO 1 - TOTAL WATER/SEWER REPLACEMENT

- (1) WATER MAIN SUPPLY AND RETURN LINES
i. SUPPLY

$$2 \text{ LINES} \times \$175/\text{m} / \text{LINE} = \$350/\text{m}$$

- ii. INSTALLATION

$$\$450 / \text{TRENCH} / \text{m} \times 1 \text{ TRENCH} = \$450/\text{m}$$

NOTE: THIS IS A TRENCH FOR SEWER ALSO
COMMON

ASSUME: COST FOR 150 IS SIMILAR TO 200 PIPE AS THERE IS ONLY A SMALL PORTION OF 150 PIPE REQUIRED.

By KAG Date OCT 27/98 Project Name UTILIDOR UPGRADE
Checked _____ Date _____ RESOLUTE BAY, NT
Page 1 of 7 Project No. 98-5748

DILLON

iii. SEWER MAIN

1 LINE X \$ 175 /m /LINE
= \$175 /m

iv. ACCESS VAULTS

COUNTED
30 AV'S
ON PROJECT

- SUPPLY VAULT \$ 40,000
- SUPPLY VAULT APPURTENANCES 900
- INSTALL VAULTS 10,000
\$50,900 /AV

NOTE: ONE ACCESS VAULT ALLOCATE PER
SECTION OF TRENCH, IE AV A TO AV B.
PER UNIT PRICE \$776/m

v. MOB/DEMOR

\$ 210,000 LUMP SUM
\$107/m

vi. REMOVE AND DISPOSE OF EXISTING PIPES

ASSUME: LANDFILL WILL ACCEPT SCRAP
PIPING WITHOUT CHARGE
TO CONTRACTOR.

TRENCHING IS ALREADY ACCOUNTED FOR
IN ITEM ii. PIPE NEEDS TO BE
CUT AND HAULED TO DUMP. SERVICE
CONNECTIONS NEED TO BE DETACHED,
PARTS TO BE SALVAGED WHERE
APPLICABLE, IE. SLIP ON FLANGES, SADDLES
ETC.

(a) DETACH SERVICES

\$50 / DETACHMENT OF CONNECTION

IE. AV4 TO AV6 — 15 CONNECTIONS

15 x \$50 = \$750

\$750 / 128m = \$5.90

(b) CUTTING AND SALVAGING (420 ft = 128m)

12m LENGTHS TO MANAGE

128m / 12m /cut = 11 CUTS

\$30 / CUT x 11 = \$330

\$330 / 128m
= \$2.60/m

NOTE EXCLUDES SALVAGING.

By KAG Date _____ Project Name _____

Checked _____ Date _____

Page 2 of 2 Project No. 985742

DILLON

(C) HAUL & DISPOSE

ASSUME TANDEM'S AVAILABLE
APX 10 SECTIONS PER TANDEM
(1 SECTION IS 3 PIPES)

LOAD AND HAUL TO LANDFILL
\$ 200 / LOAD (2 HRS OF
TRUCK TIME
AND LOADER TIME)

$$\frac{\$200 / \text{LOAD}}{128 \text{ m} / \text{LOAD}} = \$1.60 / \text{m}$$

SUM a, b, c FOR \$ / m FOR 178 m VI.

$$(\$5.90 + \$2.60 + \$1.60) / \text{m} = \$10.1 / \text{m}$$

VII. SUPPLY AND INSTALL SERVICE
CONNECTIONS TO WATER AND SEWER

ASSUME EXISTING SERVICE LINES WILL
REMAIN. ALL THAT IS REQUIRED ARE
SADDLES FOR CONNECTIONS, CONNECTING
TO EXISTING, AND SOME FILLING TO
MAINS.

\$ 200 / SADDLE

\$ 200 / EXCAVATION & COVER

\$ 100 / LABOUR

\$ 500 / CONNECTION

$$\$500 / \text{CONNECTION} \times 15 \text{ CONNECTIONS} = \$7,500$$

$$\frac{\$7,500}{128 \text{ m}} = \$58.60 / \text{m}$$

TOTAL ITEMS FOR \$ / m COST OF ENTIRE
REPLACEMENT.

$$i. + ii. + iii. + [(iv. \times \text{No. AVS}) / \text{TOTAL m}] + (v. / \text{TOTAL m}) + vi. + vii. = \$ / \text{m}$$

By _____ Date _____ Project Name _____

Checked _____ Date _____

Page 3 of 7 Project No. _____

DILLON

$$\begin{aligned}
 & \$350/\text{m} + \$450/\text{m} + \$175/\text{m} \\
 & + \left[(\$50,900 / \text{AV} \times 30 \text{ AV}) / 1966.85 \text{ m} \right] \rightarrow \$776/\text{m} \\
 & + \$210,000 / 1966.85 \text{ m} + \$10.10/\text{m} + \$58.60/\text{m} \\
 & = \$975/\text{m} + \$776/\text{m} + \$106.8/\text{m} + \$68.7/\text{m} \\
 & = \underline{\underline{\$1927/\text{m}}}
 \end{aligned}$$

\$1924 WATER & SEWER
RECYCLE AREA

WATER ONLY

INCLUDES

- SUPPLY 2 WATER LINES
- TRENCHING / INSTALLATION
- ACCESS VAULTS
- MOB / DEMOB
- REMOVE / DISPOSE OF EXISTING W/L
- NEW SADDLES & RECONNECT SERVICES

$$\$350/\text{m} + \$450/\text{m} + \$776/\text{m} + \$107/\text{m} + \$10.10/2 \text{ m} + \$58.60/2 \text{ m}$$

↑
1/2 WORK OF BOTH
FOR REMOVE & DISPOSE

↑
1/2 WORK OF BOTH
FOR RECONNECT

$$= \underline{\underline{\$1717/\text{m}}}$$

SEWER ONLY

INCLUDES

- SUPPLY 1 SEWER LINE
- TRENCHING / INSTALLATION
- ACCESS VAULTS
- MOB / DEMOB
- REMOVE / DISPOSE EXISTING SEWER
- NEW SADDLES / RECONNECT

$$\$450 + 175 + 776 + 107 + 5 + 29$$

$$= \underline{\underline{\$1542/\text{m}}}$$

By _____ Date _____ Project Name _____

Checked _____ Date _____

Page 4 of 2 Project No. _____

DILLOFF

SCENARIO 2

REPLACE FROM AV4 TO AV10 ✓
AV10 TO AV11 ✓
AV21 TO AV6 ✓
FOR BOTH WATER AND SEWER.

\$ 1927 /m PER SCENARIO 1.

SCENARIO 3

REPLACE W/M'S ONLY FOR
AV4 TO AV10
AV10 TO AV11
AV21 TO AV6

CONSTRUCT IN SHALLOW TRENCH ≤ 1 m
COVER.

i. W/M SUPPLY

\$350/m (P.1)

ii. INSTALLATION

- APX. 1/2 DEPTH OF EXISTING TRENCH
- INSTALLATION REMAINS THE SAME
REFLECT LESS EXCAVATION

\$450/m X 60% = \$270/m (P.1)

iii. NONE

iv. ACCESS VAULT COST IS CONSTANT WITH
LENGTH STILL (P.2)

\$776/m

v. MOB/DEMOL SAME \$107/m

vi. REMOVE & DISPOSE OF EXISTING PIPES

~~NONE~~ SOME

- ASSUME EXISTING W/M'S CAN REMAIN
IN PLACE ABANDONED.
- ACCOUNT FOR A/V'S REMOVAL AND
SERVICE DISCONNECTIONS.

By _____ Date _____ Project Name _____

Checked _____ Date _____

Page 5 of 7 Project No. _____

DILLON

(a) DETAIL SERVICES
\$5.9 /m (P. 2)

(b) SOME PIPE CUTTING AT JOINTS
ETC
ONLY 40% OF THE WORK
 $0.4 \times \$2.60/m = \$1.00/m$

(c) HAUL AND DISPOSE
APX. 60% WORK \$1.00 /m

added = \$7.9 /m

vii. SERVICE CONNECTIONS TO WATER
ONLY

$\frac{2}{3}$ WORK OF P. 3
 $\frac{2}{3} \times \$58.6/m = \$39 /m$

TOTAL ITEMS FOR WATER LINE REPLACEMENT
= 1 m BELOW GRADE.

i + ii + iv + v + vi + vii

$(350 + 270 + 776 + 107 + 7.9 + 39) \$/m$
 $= \underline{\underline{\$1550 /m}}$

SCENARIO 4

REPLACE SEWERS AT JOINTS.

ASSUME ACCESS VAULTS WILL REMAIN IN
PLACE. MUST REMOVE AND DISPOSE OF EXISTING

- i. NO W/M
- ii. INSTALLATION \$450 /m
- iii. SOWER \$175 /m
- iv. NONE
- v. MOB/DEMOB \$107 /m

By _____ Date _____ Project Name _____

Checked _____ Date _____

Page 6 of 7 Project No. _____

DILLON

VI. REMOVE DISPOSE OF EXISTING PIPE \$10.1/m

VII. SUPPLY & INSTALL SERVICE CONNECTIONS TO SEWER

APX 1/2 WORK

1/2 x \$58.60/m = \$29/m

TOTAL ITEMS

ii + iii + v. + vi + vii

= \$(450 + 175 + 107 + 19.1 + 27)

= \$771 / m

SAGS ON SEGMENTS

✓ AV14 - AV13

✓ AV25 - AV23

✓ AV12 - AV11

AV19 AV20 AV21

APX. DIST TO REPLACE

40 m

50 m → 10 m MORE TO

78.6 m - ALL } REFLECT ROAD

ALL PER DWS. (EQUATION)

SCENARIO 5

REPLACE WATER & SEWER FROM AV20 TO AV22

SAME COST ESTIMATES AS FOR SCENARIO 1.

\$1927 / m

By _____ Date _____ Project Name _____

Checked _____ Date _____

Page 7 of 7 Project No. _____

DILLON

APPENDIX C

Impact Study - Community Consultation

HAMLET OF RESOLUTE BAY

**1998/99
UTILIDOR UPGRADE PROJECT**

**IMPACT STUDY
COMMUNITY CONSULTATION**



HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

SCOPE OF WORK

- Review of Existing Documentation
- Complete Site Investigation of Utilidor to Update Latest Reported Information (UMA 1996)
- Review Utilidor Operations and Identify Concerns
- Complete an Assessment of the Hydraulic and Thermal Capacity of the System to meet 20 Year Design Requirements
- **Complete an Impact Study to Develop an Understanding of Potential Environmental Effects of Sewage Discharge to Resolute Bay**
- Develop a List of Utilidor Upgrades Required to meet the Hamlet's 20 Year Needs
- Develop a Plan and Cost Estimate for System Upgrades

HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

IMPACT STUDY

SCOPE OF WORK

- **Task 1 - Background Review and Consultation**

If Required Proceed

- Task 2 - Data Collection and Field Assessment
- Task 3 - Data Assessment and Reporting

HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

IMPACT STUDY

TASK 1 - BACKGROUND REVIEW AND CONSULTATION

- Review Relevant Sewage Treatment Reports, Designs, Licences, SNP Results, and Scientific Literature;
- Consult Government Agencies (i.e., Department of Fisheries and Oceans, Environment Canada, and Nunavut Water Board) to Determine Historical and Current Positions Relevant to Existing Legislation and Operations for the Community;
- **Consult the Community of Resolute Bay Regarding the Current Sewage Disposal Operations and the Needs and Requirements of an Impact Study;**
- Identify Regulatory and Licence Performance Requirements for Discharged Effluent; and
- Proceed to Task 2, if Required

HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

IMPACT STUDY

POTENTIAL IMPACTS OF SEWAGE WASTE DISCHARGE TO THE MARINE ENVIRONMENT¹

- **Organic Matter:** Organic compound degradation may reduce the dissolved oxygen concentration of a receiving marine environment.
- **Settleable Solids:** Benthic community structure may be altered due to particle size change and/or anaerobic conditions as a result of organic sediment decay.
- **Inorganic Nutrients:** Increased levels of nitrogen and phosphorous could increase primary production and therefore decrease dissolved oxygen levels at or near sediments.
- **Pathogenic Organisms:** Receiving environment may be subjected to disease-causing bacteria or viruses.
- **Residual Chlorine:** Chlorine within discharged water may be toxic to fish if levels are high enough.
- **Suspended Solids:** An increase in turbidity may alter fish behaviour and available light for primary production.
- **Floatables:** Slowly degradable materials that may be aesthetically offensive.

1 Department of Indian Affairs and Northern Development 1987. Sewage waste Disposal to the Arctic Marine Environment. Environmental Studies No. 55. Stanley Associates Engineering Ltd.

HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

IMPACT STUDY

PREVIOUSLY IDENTIFIED ISSUES ¹

- Compliance with the NWT *Health Act* as it relates to the Discharge of Untreated Sewage to the Ocean Environment
- Compliance with the Federal *Fisheries Act* as it Relates to the Disposal of a Deleterious Substance

1 Resolute Bay, NWT, Water and Sewer Facilities Investigations, Final Report. 1996. UMA Engineering Ltd.

HAMLET OF RESOLUTE BAY UTILIDOR UPGRADE PROJECT

IMPACT STUDY

COMMUNITY CONSULTATION

- Discuss with the Hamlet of Resolute Bay Waste Disposal System;
- Identify Historical and Current uses of the Marine Area where Discharge Occurs
- Identify Environmental Concerns, **if any**, Regarding the Current Disposal System; and
- Identify any Significant Changes to the Area from Past to Present.

Pipe	From AV	To AV	Length (m)	Incremental Population	Total Population	Sewage Flow (L/day)	Sewage Flow (m3/s)	Diameter (m)	Slope	Capacity (m3/s)	Utilization (%)
				houses	houses						
1	Plant	AV2	211.53	0	0	0	0.0000	0.150	0.1160	0.052	0.0
2	AV2	AV3	118.26	2	2	9520	0.0001	0.150	0.0790	0.043	0.3
3	AV3	AV21	70.85	1	3	14279	0.0002	0.150	0.0595	0.037	0.4
32	AV21	AV23	70.33	3	6	28559	0.0003	0.150	0.0565	0.036	0.9
*25	AV25	AV23	98.27	4	4	19039	0.0055	0.150	0.0198	0.021	25.5
23	AV23	AV13	98.15	1	11	52358	0.0059	0.150	0.0280	0.025	23.0
*17	AV17	AV16	80.36	2	2	9520	0.0054	0.150	0.0364	0.029	18.4
16	AV16	AV14	83.23	5	7	33318	0.0056	0.150	0.0321	0.027	20.7
14	AV14	AV13	78.16	5	12	57117	0.0059	0.150	0.0422	0.031	18.9
13	AV13	AV12	23.45	0	23	109475	0.0118	0.150	0.0455	0.032	36.2
26	AV27	AV12	86.00	4	4	19039	0.0002	0.150	0.0450	0.032	0.7
12	AV12	AV11	78.82	3	30	142794	0.0122	0.150	0.0432	0.032	38.4
*20	AV19	AV20	76.45	8	8	38078	0.0057	0.150	0.0157	0.019	29.8
*22	AV22	AV20	105.20	3	3	14279	0.0054	0.150	0.0659	0.039	13.9
21	AV20	AV21	48.23	1	12	57117	0.0112	0.150	0.0060	0.012	94.6
31	AV21	AV30	41.89	1	13	61877	0.0112	0.150	0.0089	0.014	78.1
30	AV30	AV29	60.66	2	15	71397	0.0113	0.150	0.0581	0.038	31.4
29	AV29	AV8	66.75	4	19	90436	0.0115	0.150	0.0077	0.013	86.4
5	AV4	AV5	86.74	7	7	33318	0.0004	0.150	0.0889	0.045	0.8
6	AV5	AV6	41.59	2	9	42838	0.0005	0.150	0.0503	0.034	1.5
7	AV6	AV7	41.45	3	31	147553	0.0122	0.150	0.0584	0.037	33.2
8	AV7	AV8	22.86	2	33	157073	0.0123	0.150	0.0401	0.030	40.4
28	AV28	AV8	91.03	7	7	33318	0.0004	0.150	0.0056	0.011	3.4
9	AV8	AV9	29.57	0	40	190391	0.0127	0.150	0.0464	0.033	38.7
10	AV9	AV10	46.02	5	45	214190	0.0130	0.150	0.0430	0.032	41.1
11	AV10	AV11	83.82	1	46	218950	0.0130	0.200	0.0057	0.025	52.6
*101	AV101	AV102	157.00	10	10	47598	0.0058	0.200	0.0440	0.069	8.4
102	AV102	AV104	105.00	5	15	71397	0.0061	0.200	0.0050	0.023	26.2
*103	AV103	AV104	157.00	11	11	52358	0.0059	0.200	0.0440	0.069	8.5
104	AV104	AV105	70.00	0	26	123754	0.0119	0.200	0.0440	0.069	17.3
105	AV105	AV106	122.50	5	31	147553	0.0122	0.200	0.0050	0.023	52.6
106	AV106	AV32	157.00	6	37	176112	0.0125	0.200	0.0440	0.069	18.2
311	AV11	AV32	91.44	0	76	361744	0.0252	0.200	0.0028	0.017	145.1
33	AV32	AV33	91.14	0	113	537856	0.0377	0.200	0.0060	0.025	148.5
34	AV33	AV34	88.09	0	113	537856	0.0377	0.200	0.0131	0.038	100.5
35	AV34	AV35	39.32	0	113	537856	0.0377	0.200	0.0084	0.030	125.5

* 3/4" bleed into sewer, 0.00525 m^3/s