



1. DRAIN LINE NOT SHOWN FOR CLARITY. SLOPE AT 1.0% TO INTAKE CASING.
2. COORDINATE FINAL EQUIPMENT PLACEMENT WITH MECHANICAL AND ELECTRICAL.
3. SAMPLE POINTS TO HAVE 90° ELBOWS TURNED DOWN.
4. VALVE POSITION TO ALLOW FOR VALVE OPERATION WITHOUT OBSTRUCTION.
5. INSTALL FLANGES AND UNIONS TO ALLOW FOR EQUIPMENT REMOVAL AND MAINTENANCE
6. FILTER DRAIN PIPING NOT SHOWN IN ALL LOCATIONS.

<div>Conditions of Use</div> <div>Verify elevations and/or dimensions on drawing prior to use. Report any discrepancies to Dillon Consulting Limited.</div> <div>Do not scale dimensions from drawing.</div> <div>Do not modify drawing, re-use it, or use it for purposes other than those intended at the time of its preparation without prior written permission from Dillon Consulting Limited.</div>		<div>THE ASSOCIATION OF PROFESSIONAL ENGINEERS, GEOLOGISTS AND GEOPHYSICISTS OF THE NORTHWEST TERRITORIES</div> <div>PERMIT NUMBER P-010-118</div> <div>DILLON CONSULTING LIMITED</div>	<div></div>	<div></div>	<div></div>	<div></div>	<div></div>	<div></div>	<div></div>	<div>DESIGN</div>	<div>REVIEWED BY</div>	<div>GS</div>	<div>GS</div>	<div>TALOYOAK WATER TREATMENT PLANT</div>	<div>PROJECT NO.</div>	<div>07-8107-2000</div>
						<div>3</div>	<div>ISSUED FOR TENDER</div>	<div>06/06/08</div>	<div>GS</div>	<div>JUNE 2008</div>	<div>FILTER PROCESS SYSTEM - PLAN</div>	<div>SHEET NO.</div>	<div>303</div>			
	<div>2</div>	<div>ISSUED FOR 100% CLIENT REVIEW</div>	<div>04/30/08</div>	<div>GS</div>						<div>DRAWN</div>	<div>CHECKED BY</div>	<div>NTB</div>	<div>GS</div>			
	<div>1</div>	<div>ISSUED FOR CLIENT REVIEW</div>	<div>03/15/08</div>	<div>GS</div>						<div>DATE</div>						
	<div>No.</div>	<div>ISSUED FOR</div>	<div>DATE</div>	<div>BY</div>						<div>SCALE</div>	<div>HOR: 1:500</div>	<div>VERT: 1:500</div>				